

1000 N. "D" STREET

L- B14 Valley View Add Zone C V

Sharon Perera 2-26-79

8-18

CITY OF LAS VEGAS, NEVADA

LOG NO. & AREA

CONST. VAL. \$

DEPARTMENT OF PUBLIC SERVICES
DIVISION OF BUILDING AND SAFETY

APPLICATION & BUILDING PERMIT - for:
Commercial or Public Structures

ADDRESS OF
CONSTRUCTION

1000 N. D St

OWNER

City Las Vegas

LOT(s)

BLOCK

14

SUBDIVISION

Vally View Hill

ZONE

CU

Existing structure on lot:

Dwelling ☐

Accessory Bldg. ☐

Vacant Lot ☐

Commercial Bldg. ☒

Other ☐

PROPOSED CONSTRUCTION:

Close in same windows

USE

Rec.

MATERIALS OF CONSTRUCTION:

Wood Frame ☐

Concrete Block ☒

Reinforced Concrete ☐

Steel Frame ☐

SQUARE FEET OF FLOOR AREAS:

1st

2nd

3rd

Other

TOTAL SQ. FT.

FIRE ZONE:

Occupancy Group

CONST. TYPE:

ARCHITECT:

ENGINEER:

NO. of UNITS

NO. of STORIES

Plans Submitted:

Yes ☐

No ☐

Calculations Submitted:

Yes ☐

No ☐

Sewer Fee Req'd:

Yes ☐

No ☐

CONTRACTOR:

Owner

STATE
LICENSE #

CITY
LICENSE #

ADD'L. PERMITS:

Air Cond. ☐

Elec. ☐

Plumbing ☐

Signs ☐

Paving ☐

Fence ☐

Public Walks ☐

Curb-gutters ☐

Technicians ☐

Fire Sprinkling System ☐

CONDITIONS OF THE PERMIT:

1. I agree to call the City Building Department for inspections before concrete is poured, before rough wiring, electrical, plumbing, framing is covered. Also for Air conditioning, drywall and sheathing inspection.
2. I agree that when the job is completed that I will call for final inspection before occupancy.
3. I agree to perform all construction in accordance with City Ordinances and Building Codes.
4. The Contractor's signature below denotes authority from the owner to sign in his behalf and that the owner is aware of all requirements of this application and permit. Separate permits must be taken out for work outlined above this agreement.
5. I have read and understand the contents of this application and permit; I hereby state that the information I have supplied on this application is true and correct.

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way.

SIGNED:

Contractor

BY:

Spurgeon Daniels

Agent or Owner

Clark County Health Department

Las Vegas Fire Department

PLANNING DEPT:

Date:

11-7-78

PUBLIC WORKS DEPT:

Date:

11/7/78

BUILDING DIVISION:

Date:

11/7/78

76-10-13

54-01-220

PERMIT NO.:

10730

PERMIT FEE \$

N/C

RECEIPT

Paid 11/7/78
WRT

MUST BE MACHINE VALIDATED

Theresa Reynolds 11-20-80

CITY OF LAS VEGAS,

INTER-OFFICE MEMORANDUM

Date

November 14, 1980

TO:

Richard Blue, Director
Funds Coordination

FROM:

Lee Lemmon
Lee Lemmon, Sr. Building Inspector
Building & Safety

SUBJECT:

Site
1000 "D" Street - Temporary Use

COPIES TO:

Clay Hymer, Director
Building & Safety
File

We were asked to investigate this building for a 3-day temporary use of a portion of the building for an artist exhibit. Some storage was to be removed from area and replaced into unused portion of the building. This area was to be temporarily blocked off from use.

Temporary portable restrooms were to be provided for use of the public, etc. The wiring was to be checked for any open circuits, and to be made safe for use before activating electric service.

LL/lm

OWNER <u>City of Las Vegas</u> ADDRESS <u>1000 N. D. St.</u>	
DATE <u>11-7-78</u>	GEN. CONT. <u>Owner</u>
Close in some windows	
TYPE OF STRUCTURE	PERMIT NO. <u>1073</u> FINAL INSPECTION
LEGAL DESCRIPTION <u>B-14</u>	LOG # <u>Valley View Add.</u> AREA #
APPROVED FOR OCCUPANCY & METER	
BUILDING	MECHANICAL
Investigation	Plumbing Cont.
Location & Footing	Permit No. Date
Concrete Slab Floor	Heat & Vent. A/C Cont.
Vert. Steel Reinf. <u>EC 11-29-78</u>	Permit No. Date
Horiz. Steel Reinf.	Sewer Cont.
Plumbing	Permit No. Date
Ext. Lath	Rough Soil
Ext. Brown	Rough Water
Final Building <u>PC 7-15-78</u>	Top-Out
Appr. for Occu.	Rough Gas
	A/C Rough Duct
	Final Plumbing
	Final Gas
	Final Air Cond.
	Final Sewer
Temp. pole cont.	<u>not done as of 1-17-79 C. Clark</u>
Permit No. Date	
Inspection Date	
Electrical Cont. Date	
Permit No. Date	
Rough	PLEASE NOTE REMARKS ON REVERSE SIDE
Final Rough	DIV. OF BLDG. & SAFETY CITY OF LAS VEGAS REV. 10-78
Final Electrical	2-1-32
Temporary Service	E & WAY SYSTEMS NEWARK OH 43055 LITHO IN U.S.A.

CITY OF LAS VEGAS, NEVADA

LOG NO. & AREA

DEPARTMENT OF BUILDING AND SAFETY

CONST. VAL \$ 1000

APPLICATION & BUILDING PERMIT - for:

Commercial or Public Structures:

ADDRESS OF CONSTRUCTION

1000 S. 10th St

OWNER

City of Las Vegas

LOT

BLOCK

14

SUBDIVISION

Jefferson Center

ZONE

010-536 000

Existing structure on lot:

Dwelling ☐

Accessory Bldgs. ☐

Vacant Lot ☐

Commercial Bldg. ☐

Other ☒

PROPOSED CONSTRUCTION

Interior Partitions

separate arch use into driveway

MATERIALS OF CONSTRUCTION:

Wood Frame ☐

Concrete Block ☐

Reinforced Concrete ☐

Steel Frame ☐

SQUARE FEET OF FLOOR AREAS:

1st

2nd

3rd

Other

TOTAL SQ. FT.

FIRE ZONE:

Occupancy Group

CONST. TYPE:

ARCHITECT:

ENGINEER:

NO. of UNITS

NO. of STORIES

Plans Submitted:

Yes ☐

No ☐

Calculations Submitted:

Yes ☐

No ☐

Sewer Fee Req'd:

Yes ☐

No ☐

CONTRACTOR:

Marion Bennett Organizational Center

STATE LICENSE #

CITY

LICENSE #

ADD'L. PERMITS REQ'D:

Air Cond. ☐

Elec. ☐

Plumbing ☐

Signs ☐

Paving ☐

Fence ☐

Public Walks ☐

Curb-gutters ☐

Incinerators ☐

Fire Sprinkling System ☐

CONDITIONS OF THE PERMIT:

- I agree to call the City Building Department for inspections before concrete is poured, before rough wiring, electrical, plumbing, framing is covered. Also for Air conditioning, drywall and sheathing inspection.
- I agree that when the job is completed that I will call for final inspection before occupancy.
- I agree to perform all construction in accordance with City Ordinances and Building Codes.
- The Contractor's signature below denotes authority from the owner to sign in his behalf and that the owner is aware of all requirements of this application and permit. Separate permits must be taken out for work outlined above this agreement.
- I have read and understand the contents of this application and permit. I hereby state that the information I have supplied on this application is true and correct.

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way.

SIGNED:

Richard D. Bell

Contractor

BY:

1101A

\$

00

Agent or Owner

STL \$ 00

TOTL \$ 00

CHEK \$ 00

Clark County Health Department

Las Vegas Fire Department

FW5232 BR#001/01

CITY - LAS VEGAS

BLDG. & SAFETY

11/03/81

PLANNING DEPT:

Date:

10-29-81

PUBLIC WORKS DEPT:

Date:

10-29-81

BUILDING DIVISION:

Date:

10-29-81

76-10-13

PERMIT NO.:


5232

PERMIT FEES

No Fees

MUST BE MACHINE VALIDATED

J. Jones 11/4/81



Yolanda Allen 6/16/82

OWNER CITY LAS VEGAS		ADDRESS 1000 N. 7TH ST	
DATE 11/2/81		GEN. CONTRACTOR BENETT	
INTERIOR PARTITION		PERMIT NO. 5232 FINAL INSPECTION	
TYPE OF STRUCTURE		LOG #	
LEGAL DESCRIPTION		AREA #	
APPROVED FOR OCCUPANCY & METER <i>See attached</i>			
BUILDING		MECHANICAL	
Investigation		Plumbing Cont.	
Location & Footing		Permit No.	Date
Concrete Slab Floor		Heat & Vent/A/C Cont.	
Vert. Steel Reinf.		Permit No.	Date
Horiz. Steel Reinf.		Super Cont.	
Framing		Permit No.	Date
Ext. Lath		Rough Elec.	
Ext. Brown		Rough Water	
Final Building		Top-Out	
Angr. for Occu.		Rough Gas	
		A/C Rough Duct	
		Final Plumbing	
		Final Gas	
ELECTRICAL		Final Air Cond.	
Temp. pole con.		Final Sewer	
Permit No.	Date		
Inspection	Date		
Electrical Cont.	Date		
Permit No.	Date	PLEASE NOTE REMARKS ON REVERSE SIDE	
Rough		DIV OF BLDG. & SAFETY	
Final Rough		CITY OF LAS VEGAS	
Final Electrical		REV 10-71	
Temporary Service		79-3-12	

Debbie Ingraham 7-21-87

BUILDING DEPARTMENT
CITY OF LAS VEGAS

#2
CORRECTION NOTICE

Job Located at 1000 "D" ST.

I have this day inspected this structure and these premises and have found the following violations of City and/or State laws governing same:

#1 CONDUIT ON REAR OF BLDE
SHOULD BE SUPPORTED OR REMOVED:

You are hereby notified to correct above violation and call for re-inspection.

Date 17 MAR 87

Inspector

23.03 Do not remove this tag!

BUILDING DEPARTMENT
CITY OF LAS VEGAS

#1 FILE -
CORRECTION NOTICE

Job Located at 1000 "D" ST.

I have this day inspected this structure and these premises and have found the following violations of City and/or State laws governing same:

#1 INFO - NO ACTION -
#1 GUTTER COVER MISSING AT SUB.

#2 MISC. SW. & BOX COVERS MISSING

#3 DISCONNECT REQ. ON SPACE HTRS.

#4 PANELS REQ. TO HAVE CIRCUITS
LABELED.

#5 UNUSED WIRE & PIPE IN RESTROOM
TO BE REMOVED

#6 END PLATES ON FIXTURES TO BE
REPLACED

#7 REMOVE ALL UNUSED WIRING

You are hereby notified to correct above violation and call for re-inspection.

Date 17 MAR 87

Inspector

23.03 Do not remove this tag!