

A. *2821 Cotton Cloud

B. *2825 Cotton Cloud

C. *2829 Cotton Cloud

D. *2833 Cotton Cloud

E. *2837 Cotton Cloud

*Perimeter wall/see

2916 Mellow Breeze

Debbie Ingraham 5-16-90

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 2821 Cotton Road		PERMIT NO. 010636	
LOT NO.	MAP NO.	INSPECTOR 67	DATE 3-1-89
SUBDIVISION NAME		PHONE	
INSPECTOR SIGNATURE #67 J. Schell		INSPECTION DATE 3-1-89	
Correction notice			
Block Wall And Column			
in sight triangle -			
nothing over 30" -			
in height allowed.			
☐ PARTIAL INSPECTION - DESCRIPTION:			
☐ APPROVED		☐ PERMIT REQUIRED	
☐ STOP WORK		☒ REJECTED (CORRECTION NOTICE) REINSPECTION REQUIRED CALL 799-2071	
INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS WASTE
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING
☐ B-8	EXTERIOR LATH/STUCCO	☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL	☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT. OF OCC.	☐ E-6	TEMP POWER
☐ X-1	KICKER / FLUSH		
☐ X-2	UNDERGROUND HYDRO		
☐ X-3	UNDERGROUND FINAL/FLOW		
☐ X-4	SPRINKLER SYSTEM HYDRO		
☐ X-5	FIRE ALARM		
☐ X-6	OTHER:		
☐ X-7	FINAL FIRE		
☐ FINAL INSPECTION		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)	

FOR TECHNICAL ASSISTANCE - CALL: 799-6916