

**CITY OF LAS VEGAS
DIVISION OF FIRE SERVICES**

12:30

JOB ADDRESS 3898 Meadows Ln Ste C.			PERMIT NO. 74073
LOT NO.	MAP NO. 16-1151A	INSPECTOR	DATE 10-5-90
PROJECT NAME Tenant Improvement			PHONE 877-0908
INSPECTOR'S SIGNATURE <i>[Signature]</i>			INSPECTION DATE 10/8/90

- ① Extinguisher hung so top no more than 5' off floor - expiration 9/28/91
- ② This door signs - o.k.
- ③ Emergency lighting - o.k.
- ④ Sprinklers installed as per approved plans
- ⑤ Did overhead inspection of sprinkler system - bracing and piping appears to be correct.
- ⑥ Street address posted

☐ PARTIAL APPROVAL	☐ REJECTED-REINSPECTION REQUIRED	☒ FINAL APPROVAL
☐ TEMPORARY APPROVAL		☐ STOP ORDER
☐ X-1 UNDER/ABOVEGROUND TANK	☐ X-5 FIRE ALARM SYSTEM	☐ X-8 EXTINGUISHING SYSTEM
☐ X-2 HOOD SYSTEM	☐ X-6 OTHER	☐ X-9 MEDICAL GAS
☐ X-3 UNDERGROUND FINAL/FLOW	☒ X-7 FINAL FIRE	☐ X-10 LPG
☒ X-4 SPRINKLER SYSTEM/OVERHEAD HYDRO		☐ X-11 SUPERVISION/MONITORING

FOR INSPECTIONS CALL: 799-2071 FOR FURTHER INFORMATION CALL: 383-2888