

CITY OF LAS VEGAS, NEVADA

DEPARTMENT OF BUILDING AND SAFETY
PHONE 229 6251

PERMIT NO

93-176567



071

BUILDING PERMIT

FOR Single Family Dwelling Remodel
Additions Misc Residential ConstructionPLAN CHECK NO P308 DATE January 27, 1993 CONST VAL \$ 73,200 00ADDRESS OF CONSTRUCTION 3105 St Tropez OWNER US Home Corporation PHONE 451-6222LOT(s) 117 BLOCK 5 SUBDIVISION Villa Finestra 2A ZONEPROPOSED CONSTRUCTION SFD 2373 USETHIS PERMIT FOR BLDG ☒ A/C ☒ ELEC ☒ PLBG ☒ OTHER PERMITS REQD FENCE ☐ OFF SITE ☐ SWIM POOL ☐FLOOR AREA BSMT 1ST 654 2ND 1884 GARAGE 600 PORCH 21 TOTAL 3159CONTRACTOR US Home Corporation STATE LICENSE NO 14506 CITY LICENSE NO 17512ARCHITECT Rourke, Burke and Assoc ENGINEERMASTER PLUMBER/
CONTRACTOR MASTER ELECTRICIAN/
CONTRACTOR

OTHER INSPECTIONS AND FEES

- 1 Inspections outside of normal business hours = \$40 00 per hour (minimum charge three hours)
- 2 Re inspection fee during normal business hours assessed under provisions of TABLE 3 A of the Uniform Building Code = \$40 00 per hour
- 3 Inspections during normal business hours for which no fee is specifically indicated = \$40 00 per hour (minimum charge one hour)
- 4 Additional plan review required by changes add tions or revisions to approved plans = \$40 00 per hour (minimum charge two hours)

CONDITIONS OF THE PERMIT

- 1 I agree to call the City Building Department for inspections before concrete is poured before rough wiring electrical plumbing framing is covered Also for air conditioning drywall and sheathing inspection
- 2 I agree that when the job is completed that I will call for final inspection before occupancy
- 3 I agree to perform all construction in accordance with City Ordinances and Building Codes
- 4 The Contractor's signature below denotes authority from the owner to sign in his behalf and that the owner is aware of all requirements of this application and permit Separate permits must be taken out for work outlined above this agreement
- 5 I have read and understand the contents of this application and permit I hereby state that the information I have supplied on this application is true and correct
- 6 Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way
- 7 24 HOUR MINIMUM NOTICE REQUIRED FOR INSPECTIONS

SPECIAL CONDITIONS

SEE APPROVED PLAT MAT

By US Home Corporation

I HEREBY DECLARE THAT I AM THE LEGAL OWNER OF THE ABOVE PROPERTY OWNER

By Bruce Scasta AGENT

BRUCE SCASTA, Vice President/Construction, US Home Corp
I hereby certify that I have reviewed this application and the proposed plans and have found that the proposed development meets the requirements of the City of Las Vegas Flood Hazard Reduction Ordinance for the issuance of this Development Permit.

LAND DEVELOPMENT AND FLOOD CONTROL ENGINEER

DATE

ELECTRICAL

FEE

PLANNING DEPT

DATE

BUILDING DEPT

DATE

PLUMBING		FEE
WATER DISTRIBUTION	6 70	
SEWER SYSTEM NEW OR MODIFICATION	11 05	
FIXTURES WATER SOFTENER H/W HEATER	2 25	
GARBAGE DISPOSAL WASHER	2 25	
FUEL PIPING	6 70	
IRRIGATION SYSTEM	8 90	
MISC		
2310 2433	TOTAL	\$94.00
AIR CONDITIONING		FEE
NEW UNIT 3 TON = 10 00 OVER = 18 20		
FURNACE TO 100 000/10 00 OVER/12 20		
VAPORATIVE COOLER	7 20	
VENTILATION FAN	2 65	
2310 2435	TOTAL	\$70 00

ELECTRICAL		FEE
RECEPTACLE	SWITCH	50
EACH LIGHT FIXTURE OR SOCKET		40
SPECIAL OUTLET APPLIANCE ETC		80
SERVICE/PANEL SUB/3 40 200A/6 70 400A/13 85		
A/C UNIT OR MOTORS		3 40
MISC		
2310 2432	TOTAL	\$94.00
1113 2437 ZONING		23 00
2310 2431 PLAN REVIEW		10 00
2310 2401 BLDG PERMIT		468 00
7143 2973 SEWER CONNECTION		1,100 00
6122 3352 TORTOISE		
2897 PIF		
88100 1232 TRANSPORT		500 00
TOTAL FEES		\$2,359 00

RECEIPT

MUST BE MACHINE VALIDATED

PERMIT NO

Permit Expires 180 Days After Abandonment of Work

E 66 24'
 VILLA FINESTRA UNIT 2A
 LOT 117 BLOCK 5
 3105 ST TROPEZ STREET
 28.75'
 8'
 117.4'
 PLAN L 2530 3A
 61.25'
 11.74'
 20.0'
 8'
 E 110 00'
 APP
 By: 
 COMMUNITY PLAN
 City of Los Angeles
 11/10/00

POST TENSION SERVICES
PLACING CONTRACTOR
VALUE ENGINEERING
LIC # 32861

J M BLAKE, INC
1912 PEYTON DRIVE
LAS VEGAS, NEVADA 89104

CERTIFICATE OF STRESSING

OWNER U S Homes
ADDRESS 3105 St Tropez Street
PROJECT Coral Bay
ENGINEER Nelson
LOT/BLOCK 117/5
PLAN # 2530
DATE STRESSED 4-19-93
EXCEPTIONS NONE XX SEE BELOW

This is to certify, that this foundation was installed and stressed to the engineers specifications

CERTIFICATE ISSUED BY



Joel M Blake

CITY OF LAS VEGAS, NEVADA

PERMIT NO

93 176557

DEPARTMENT OF BUILDING AND SAFETY
PHONE 229 6251

FOR INSPECTIONS CALL 229 2071

BUILDING PERMIT

FOR Single Family Dwelling Remodel
Additions Misc Residential ConstructionPLAN CHECK NO P308 DATE January 27, 1993 CONST VAL \$ 73,200 00ADDRESS OF CONSTRUCTION 3105 St Tropez OWNER US Home Corporation PHONE 451-6222LOT(s) 117 BLOCK 5 SUBDIVISION Villa Finestra 2A ZONEPROPOSED CONSTRUCTION SFD 2373 USETHIS PERMIT FOR BLDG ☒ A/C ☒ ELEC ☒ PLBG ☒ OTHER PERMITS REQD FENCE ☐ OFF SITE ☐ SWIM POOL ☐FLOOR AREA BSMT 654 1ST 1884 2ND 600 GARAGE 21 PORCH 3159 TOTALCONTRACTOR US Home Corporation STATE LICENSE NO 14506 CITY LICENSE NO 17512ARCHITECT Rourke, Burke and Assoc. ENGINEERMASTER PLUMBER/
CONTRACTOR MASTER ELECTRICIAN/
CONTRACTOR

OTHER INSPECTIONS AND FEES

- 1 Inspections outside of normal business hours = \$40 00 per hour (minimum charge three hours)
- 2 Re spect o fee du g o mal business ho rs assessed nder pro sons of TABLE 3 A of the Un form B lding Code = \$40 00 per hour
- 3 Inspections during normal business hours for which no fee is specifically indicated = \$40 00 per hour (minimum charge one hour)
- 4 Additional plan review required by changes additions or revisions to approved plans = \$40 00 per hour (minimum charge two ho rs)

CONDITIONS OF THE PERMIT

- 1 I agree to call the City Building Department for inspections before concrete is poured before rough wiring electrical plumbing framing is covered Also for air conditioning drywall and sheathing inspection
- 2 I agree that when the job is completed that I will call for final inspection before occupancy
- 3 I agree to perform all construction in accordance with City Ordinances and Building Codes
- 4 The Contractor's signature below denotes authority from the owner to sign in his behalf and that the owner is aware of all requirements of this application and permit Separate permits must be taken out for work outlined above this agreement
- 5 I have read and understand the contents of this application and permit I hereby state that the information I have supplied on this application is true and correct
- 6 Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way
- 7 24 HOUR MINIMUM NOTICE REQUIRED FOR INSPECTIONS

SPECIAL CONDITIONS

SEE APPROVED FLAT MAT

BY US Home Corporation OWNER

I HEREBY DECLARE THAT I AM THE LEGAL OWNER OF THE ABOVE PROPERTY

BY Bruce Scasta AGENT

BRUCE SCASTA, Vice President/Construction, US Home Corp
I hereby certify that I have reviewed this application and the proposed plans and have found that the proposed development meets the requirements of the City of Las Vegas Flood Hazard Reduction Ordinance for the issuance of this Development Permit

LAND DEVELOPMENT AND FLOOD CONTROL ENGINEER

PLANNING DEPT

BUILDING DEPT

PLUMBING		FEE
WATER DISTRIBUTION	6 70	
SEWER SYSTEM NEW OR MODIFICATION	11 05	
FIXTURES WATER SOFTENER H W HEATER	2 25	
GARBAGE DISPOSAL WASHER	2 25	
FUEL PIPING	6 70	
IRRIGATION SYSTEM	8 90	
MISC		
2310 2433	TOTAL	\$94.00
AIR CONDITIONING		FEE
NEW UNIT 3 TON = 10 00 OVER = 18 20		
FURNACE TO 100 000/10 00 OVER/12 20		
VAPORATIVE COOLER	7 20	
VENTILATION FAN	2 65	
2310 2435	TOTAL	\$70.00

ELECTRICAL

FEE

RECEPTACLE	SWITCH	50
EACH LIGHT FIXTURE OR SOCKET		40
SPECIAL OUTLET APPLIANCE ETC		80
SERVICE/PANEL SUB/3 40 200A/6 70 400A/13 85		
A C UNIT OR MOTORS	3 40	
MISC		
2310 2432	TOTAL	\$94.00

1113 2437 ZONING	23.00
2310 2431 PLAN REVIEW	10.00
2310 2401 BLDG PERMIT	468.00
7143 2973 SEWER CONNECTION	1,100.00
6122 3352 TORTOISE	
2897 PIF	
88100 1232 TRANSPORT	500.00
TOTAL FEES	\$2,359.00

RECEIPT

MUST BE MACHINE VALIDATED

PERMIT NO

Permit Expires 180 Days After Abandonment of Work

CERTIFICATION OF INSULATION

PART I GENERAL	ADDRESS OR TRACT		SACRAMENTO INSULATION CONTRACTORS					
	U S HOME CORAL BAY 3105 St Tropez		LOT # 117/5		☐ P O BOX 854 WEST SACRAMENTO CA 95691 LIC #202026 ☐ P O BOX 4146 STOCKTON CA 95204 LIC #202026 ☐ P O BOX 1631 RENO NV 89505 LIC #10675 ☐ P O BOX 9651 FRESNO CA 93793 9651 LIC #202026 ☒ 6470 B SOUTH PROCYON AVE LAS VEGAS NV 89118 LIC #10675			
		DATE INSULATION COMPLETED May 1993						

WALLS		CEILINGS			FLOORS	
(SQUARE FEET)		(SQUARE FEET)			(SQUARE FEET)	
TYPE OF INSULATION		TYPE OF INSULATION			TYPE OF INSULATION	
MATERIAL FIBERGLASS		MATERIAL FIBERGLASS			MATERIAL FIBERGLASS	
FORM BATTS		FORM BATTS & BLOW			FORM BATTS	
MANUFACTURER'S PRODUCT I D		MANUFACTURER'S PRODUCT I D			MANUFACTURER'S PRODUCT I D	
MANUFACTURER		MANUFACTURER			MANUFACTURER	
OCF		OCF			OCF	
R VALUE INSTALLED		R VALUE INSTALLED			R VALUE INSTALLED	
APPLIED THICKNESS		APPLIED THICKNESS			APPLIED THICKNESS	
R-13		R-30				
KNEE WALLS IF R VALUE IS OTHER THAN WALLS ABOVE						
MATERIAL FIBERGLASS		FORM BATTS		R VALUE R-19		MANUFACTURER OCF
AIR INFILTRATION SEALANT						
MATERIAL				MANUFACTURER W R GRACE		

THIS IS TO CERTIFY THAT INSULATION AND/OR SEALANT HAS BEEN INSTALLED IN CONFORMANCE WITH APPLICABLE CODES MATERIAL STANDARDS AND REGULATIONS

SIGNATURE - INSULATION CONTRACTOR 	TITLE MANAGER	DATE 6/18/93
SIGNATURE - GENERAL CONTRACTOR	TITLE	DATE

REMARKS

UltraKote, Inc.

FIBER - REINFORCED STUCCO

2865 N W Grand Avenue Phoenix AZ 85017 (602) 484-0320

Job Address

117/5

INSTALLATION CARD

ICBO Report No 4658

3105 ST TROPEZ

Date of Job Completion 4/9/93

Plastering Contractor


Name CEDCO, INC

Address 9555 So Las Vegas Blvd Las Vegas NV 89123

Telephone No (702) 361-6550

Above contractor is approved by UltraKote Inc

This is to certify that the exterior coating system on the building exterior at the above address has been installed in accordance with the evaluation report specified above and the manufacturer's instructions



Signature of authorized representative
of plastering contractor

4/9/93
Date

This installation card must be presented to the building inspector after completion of work and before final inspection

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	15
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO		BLOCK NO	SUBDIVISION NAME	
117		5	VILLA FINESTRA UNIT 2A	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	04/07/93	14:44	04/08/93
INSPECTOR NO		INSPECTOR NAME		
84		BOB WARD		
INSPECTION REQUESTED				
ROUGH ELECTRICAL (220)				
CORAL BAY ① Block All light boxes where a fan can be hung - 90-4 NEC				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) -- UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		
INSPECTOR SIGNATURE <i>Bluel</i>			INSPECTION DATE	
			4-8-93	
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call *229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER	93-176567	☒ INSPECTION NUMBER	18
JOB ADDRESS		113189	
3105 ST TROPEZ ST			
LOT NO	BLOCK NO	SUBDIVISION NAME	
117	5	VILLA FINESTRA UNIT 2A	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME
2117-17	255-4662	04/07/93	14:45
SCHEDULE DATE			
04/08/93			
INSPECTOR NO	INSPECTOR NAME		
84	BOB WARD		

☒ INSPECTION REQUESTED	TOP OUT-WATER, GAS, WASTE (420)
--	---------------------------------

CORAL BAY

① Water heater vent not acceptable
No more than 160 off set


~~② Heat vent on water heater pipe~~
~~To be 18" minimum~~ OK Per Manufacturer

② Insulate piping at Attic - protect from
Freezing - 315 UPC - All houses

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			


INSPECTOR SIGNATURE	INSPECTION DATE
B.W.	4-8-93
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT	
229-6765	

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	3
JOB ADDRESS		3105 ST TROPEZ ST 113189		
LOT NO 117	BLOCK NO 5	SUBDIVISION NAME VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO 2117-17	JOB PHONE 055-4662	CALL IN DATE 04/12/93	CALL IN TIME 14:09	SCHEDULE DATE 04/13/93
INSPECTOR NO 84	INSPECTOR NAME BOB WARD			
INSPECTION REQUESTED	EXTERIOR LATH/STUCCO (129)			
CORAL BAY				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED	
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE 		INSPECTION DATE 4-13-93		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER 3-176567		☒ INSPECTION NUMBER 13	
JOB ADDRESS 3125 ST TROPEZ ST 113199			
LOT NO 117	BLOCK NO F	SUBDIVISION NAME VILLA FINESTRA UNIT 21	
FIRE DEPT MAP NO 2117-17	JOB PHONE 451-6222	CALL IN DATE 04/14/93	CALL IN TIME 14.14
SCHEDULE DATE 04/15/93			
INSPECTOR NO 8/70	INSPECTOR NAME BOE LINDO DDM		
☒ INSPECTION REQUESTED ROUGH ELECTRICAL (221)			
CORAL BLY - DO NOT PUT WIRES UNDER LARGE SCREW NEXT TO VTER IN MAIN - MIN 1/4" INSULATION PAST BUSHING IN MAIN - IS BAR SINK ϕ IN DEN OF 1? - ADD ϕ TO ONE OF STAIR LANDINGS - UP BED RM'S 6 + 12 / FIX BOX ON WALL - BLOCK CEILING BOXES FOR FANS JEFF STAFFORD / REPUBLIC I WILL CORRECT ABOVE  WILL APPEAR BLOCKING CEILING BOXES			
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION	
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL
		☐ HOLD (H)	
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		
INSPECTOR SIGNATURE 	INSPECTION DATE 4-15-93		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C OF O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT			229-6745

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER	93-176567	☒ INSPECTION NUMBER	20
JOB ADDRESS		3105 ST TROPEZ ST 113189	
LOT NO	BLOCK NO	SUBDIVISION NAME	
117	5	VILLA FINESTRA UNIT 2A	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME
2117-17	451-6222	04/14/93	14:18
SCHEDULE DATE	04/15/93		
INSPECTOR NO	INSPECTOR NAME		
84	BOB WARD		
INSPECTION REQUESTED		SHEAR (109)	

CORAL BAY

- ① CK all details - trusses and shear walls transfer, blocking ect
- ② D/b G-2 shear wall at make above entry cannot be built - revision req
- ③ Full decking - truss cut above landing at stair - above return plenum

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION	
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL
☒ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071		☐ HOLD (H)
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE <i>BLW</i>		INSPECTION DATE 4-15-93	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 AM 7 15 AM OR 2 45 PM 3 00 PM AT			229-6765

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER 93-176567	INSPECTION NUMBER 15			
JOB ADDRESS 3105 ST TROPEZ ST 113189				
LOT NO 117	BLOCK NO 5	SUBDIVISION NAME VILLA FINESTRA UNIT 21		
FIRE DEPT MAP NO 2117-17	JOB PHONE 151-6222	CALL IN DATE 04/14/93	CALL IN TIME 14:16	SCHEDULE DATE 04/15/93
INSPECTOR NO 86	INSPECTOR NAME BOB WARD			

INSPECTION REQUESTED TOP OUT-WATER, GAS, WASTE (420)

CORAL DAY

Complete water recall

☒ PARTIAL INSPECTION	☒ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION <i>DBL Fast OK</i>		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			

INSPECTOR SIGNATURE <i>Bob Ward</i>	INSPECTION DATE 4-15-93
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)

IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 AM 7 15 AM OR 2 45 PM 3 00 PM AT **229-6765**

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	14
JOB ADDRESS 3175 ST TROPEZ ST 113189				
LOT NO 117		BLOCK NO 5	SUBDIVISION NAME VILLA FINESTRA UNIT 2A	
FIRE DEPT MAP NO 2117-17		JOB PHONE 451-6222	CALL IN DATE 04/14/93	CALL IN TIME 14:16
SCHEDULE DATE 04/15/93				
INSPECTOR NO 84		INSPECTOR NAME BOB WARD		
INSPECTION REQUESTED		ROUGH MECHANICAL (329)		

CORAL PAY
 ① **FAIL** / water heater flue not acceptable
 no more than 1 60° offset
 2 Return plenum at garage - wall must
 be insulated & sealed - No open
 faced Insul at plenum

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE B.W.		INSPECTION DATE 4-15-93		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call *229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER 02-176567		☒ INSPECTION NUMBER 12	
JOB ADDRESS 3105 ST TROPIC ST 113189			
LOT NO 117	BLOCK NO 5	SUBDIVISION NAME VILLA FINESTRA UNIT 2A	
FIRE DEPT MAP NO 2117-17	JOB PHONE 451-6222	CALL IN DATE 04/14/93	CALL IN TIME 14.13
SCHEDULE DATE 04/15/93			
INSPECTOR NO 84		INSPECTOR NAME ROB WARD	
☒ INSPECTION REQUESTED		FRAMING (12F)	


CORAL BAY

- ① Boundary nailing at upstairs truss to truss wall no connect - ABS not nailed
- ② Trusses downstairs not bearing properly at hull
- ③ Break at roof sheathing at item ① Block - G-3 wall at Above
- ④ All 2x4 material to be stud grade not STANDARD or better

Go back ck house & Details ect
RECALL

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE BLUQ		INSPECTION DATE 4-15-93		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 AM 7 15 AM OR 2 45 PM 3 00 PM AT				229-6765

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER 93-176567		☒ INSPECTION NUMBER 26	
JOB ADDRESS 3105 ST TROPEZ ST 113189			
LOT NO 117	BLOCK NO 5	SUBDIVISION NAME VILLA FINESTRA UNIT 2A	
FIRE DEPT MAP NO 2117-17	JOB PHONE 255-4662	CALL IN DATE 04/16/93	CALL IN TIME 13:53
INSPECTOR NO 84		INSPECTOR NAME BOB HARB 73	
☒ INSPECTION REQUESTED		ROUGH MECHANICAL (320)	
CORAL BAY CANCEL			
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION	
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071	
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET	
☐ PERMIT REQUIRED			
INSPECTOR SIGNATURE 		INSPECTION DATE 4/19/93	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 AM 7 15 AM OR 2 45 PM 3 00 PM AT			229-6765


For Additional Assistance Call * 229 6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	28
JOB ADDRESS 3105 ST TROPEZ ST 113189				
LOT NO 117		BLOCK NO 5	SUBDIVISION NAME VILLA FINESTRA UNIT 2A	
FIRE DEPT MAP NO 2117-17	JOB PHONE 255-4662	CALL IN DATE 04/16/93	CALL IN TIME 13:53	SCHEDULE DATE 04/19/93
INSPECTOR NO 8485		INSPECTOR NAME BOB WARD <i>72</i>		
INSPECTION REQUESTED		TOP OUT-WATER, GAS, WASTE (420)		
CORAL BAY CANCEL				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL * 229 2071		
☐ RESEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE			INSPECTION DATE	
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 AM 7 15 AM OR 2 45 PM 3 00 PM AT				229-6765

For Additional Assistance Call * 229 6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER	176567	☒ INSPECTION NUMBER	56	
JOB ADDRESS		3105 ST TROPEZ ST		113189
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	04/16/93	14:02	04/19/93
INSPECTOR NO	INSPECTOR NAME			
84	BOB WARD			
INSPECTION REQUESTED	SHEAR (109)			
CORAL BAY <i>Cancel - Call with Frame</i>				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL * 229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE			INSPECTION DATE 4-19-93	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 AM 7 15 AM OR 2 45 PM 3 00 PM AT				229-67 65

For Additional Assistance Call * 229 6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	29
JOB ADDRESS		3105 ST TROPEZ ST 113189		
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	04/16/93	13:54	04/19/93
INSPECTOR NO	INSPECTOR NAME			
84	BOB WARD			
INSPECTION REQUESTED	FRAMING (120)			

CORAL BAY

Canceled by Supt

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE	<i>BLU</i>		INSPECTION DATE <i>4-19-93</i>	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call *229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER	93-176567	INSPECTION NUMBER	24
JOB ADDRESS		3105 ST TROPEZ ST 113189	
LOT NO 117	BLOCK NO 5	SUBDIVISION NAME VILLA FINESTRA UNIT 24	
FIRE DEPT MAP NO 2117-17	JOB PHONE 255-4662	CALL IN DATE 04/20/93	CALL IN TIME 13:49
SCHEDULE DATE 04/21/93			
INSPECTOR NO 84	INSPECTOR NAME BOB WARD		
INSPECTION REQUESTED	SHEAR (109) <i>20" STRAP</i>		
CORAL BAY ① Detail Truss to truss - sheathing overlap - ② Trusses at Above require fix from truss Co on point of bending ③ OSB wall at upstairs nake & bedroom install P-1 per letter (SHEAR/BL#2) ④ Truss fix required at Fire truss Above master bath closet - P/b cut <u>connect & recall</u> John Merchant			
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION	
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL
☒ REJECTED (R)	☐ HOLD (H)		
☐ REFEED (F)	REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE		INSPECTION DATE	
BLW		4-21-93	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C OF O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT			229-6765

For Additional Assistance Call *229-6251 See Reverse Side For Inspection Types

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	33
-------------------------------------	------------------	-----------	----------------------	----

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	35
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	04/28/93	14:45	04/29/93
INSPECTOR NO	INSPECTOR NAME			
84	BOB WARD			
INSPECTION REQUESTED	SHEAR (109)			

CORAL BAY

CK Attachment upstairs
truss to wall —

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE			INSPECTION DATE	
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	36
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO		BLOCK NO	SUBDIVISION NAME	
117		5	VILLA FINESTRA UNIT 2A	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	04/28/93	14:46	04/29/93
INSPECTOR NO		INSPECTOR NAME		
84181		BOB WARD		
INSPECTION REQUESTED		ROUGH MECHANICAL (320)		


CORAL BAY

14' Dryer vent cannot exceed
~~24'~~ max. No approved mech plus on
 jobsite

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE		INSPECTION DATE		
Bob W. [Signature]		4 21-93		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	37
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	04/28/93	14:46	04/29/93
INSPECTOR NO	INSPECTOR NAME			
84181	BOB WARD			
INSPECTION REQUESTED	TOP OUT-WATER, GAS, WASTE (420)			
CORAL BAY need to connect 2nd str waste's + water test Also need 100 lbs poly test				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE				INSPECTION DATE
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765


For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	38
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO		BLOCK NO	SUBDIVISION NAME	
117		5	VILLA FINESTRA UNIT 2A	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	04/28/93	14:47	04/29/93
INSPECTOR NO		INSPECTOR NAME		
84		BOB WARD		
INSPECTION REQUESTED		FRAMING (120)		

CORAL BAY

Not ready

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE			INSPECTION DATE	
			4-29-93	
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765


For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	29
JOB ADDRESS 3105 ST TROPEZ ST 113189				
LOT NO 117		BLOCK NO 5	SUBDIVISION NAME VILLA FINESTRA UNIT 2A	
FIRE DEPT MAP NO 2117-17	JOB PHONE 055-4662	CALL IN DATE 04/30/93	CALL IN TIME 14:25	SCHEDULE DATE 05/03/93
INSPECTOR NO 8481		INSPECTOR NAME BOB WARD		
INSPECTION REQUESTED		ROUGH MECHANICAL (320)		
CORAL BAY Need to have revised plans approved for final Need to install dryer vent to 5" above top plate 4" cannot exceed 14'				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		
INSPECTOR SIGNATURE <i>[Signature]</i>		INSPECTION DATE 5/3/93		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765


For Additional Assistance Call * 229 6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	30
JOB ADDRESS 3105 ST TROPEZ ST 113189				
LOT NO 117		BLOCK NO 5	SUBDIVISION NAME VILLA FINESTRA UNIT 2A	
FIRE DEPT MAP NO 2117-17	JOB PHONE 055-4662	CALL IN DATE 04/30/93	CALL IN TIME 14:26	SCHEDULE DATE 05/03/93
INSPECTOR NO 84		INSPECTOR NAME BOB WARD		
INSPECTION REQUESTED		FRAMING (120)		
CORAL BAY ① Repair plb - At truss fixes - re-test ② Nail drywall Above lid - gauge wall 4" OC ③ Block under main block - Return plumb ④ Dryer vent 5' From top plate out CK At Insul				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) -- UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE		INSPECTION DATE		
		5-3 93		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				 229-6765

For Additional Assistance Call *229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	28
JOB ADDRESS				
3105 ST TROPEZ ST				113189
LOT NO		BLOCK NO	SUBDIVISION NAME	
117		5	VILLA FINESTRA UNIT 2A	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	055-4662	04/30/93	14:25	05/03/93
INSPECTOR NO		INSPECTOR NAME		
84/10		BOB WARD		
INSPECTION REQUESTED				
TOP OUT-WATER, GAS, WASTE (420)				
CORAL BAY Poly dest app. Need to connect plying at 2 xed truss				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) -- UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE		INSPECTION DATE		
 BOB WARD		5/3/93		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		

IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY
CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT

229-6765

For Additional Assistance Call *229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

M	PERMIT NUMBER	93-176567	INSPECTION NUMBER	57
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO		BLOCK NO		SUBDIVISION NAME
117		5		VILLA FINESTRA UNIT 2A
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	055-4662	05/05/93	14:53	05/06/93
INSPECTOR NO		INSPECTOR NAME		
84		BOB WARD Carson 68		
INSPECTION REQUESTED		INSULATION (123)		
CORAL BAY ①. Need insulation ABOVE Blocks - 2 Locations, ②. Return air plenum - Stuff area for fire stop. ③. Bath 2 - stuff vertical penetration (water service) AT tub. ④. Check all water SERVICE penetrations, stuff where needed. ⑤. Complete any correction notices. No one at site				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☐ APPROVED (A)		☐ STOP WORK (S)	☒ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		☐ HOLD (H)
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE		INSPECTION DATE		
		John E 5693		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-5765

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER	93-176567	APPLICATION NUMBER	113189
JOB ADDRESS 3105 ST TROPEZ ST		INSPECTION NUMBER 4	
LOT/BLOCK 117 5	RECORDED SUBDIVISION NAME VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO 2117-17	JOB PHONE 255-4662	CALL IN DATE 05/14/93	CALL IN TIME 13:06
SCHEDULE DATE 05/17/93			
INSPECTOR/NAME BOB WARD - 84		MARKETING/BUSINESS NAME CORAL BAY	
INSPECTION REQUESTED	FINAL GAS TEST (423)		

28838

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T)	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED CALL 229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE <i>BW</i>		INSPECTION DATE 5-17-93		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call 229 6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	APPLICATION NUMBER	113139
JOB ADDRESS 3105 ST TROPEZ ST			INSPECTION NUMBER 39	
LOT/BLOCK 117 5		RECORDED SUBDIVISION NAME VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO 2117-17	JOB PHONE 255-4662	CALL IN DATE 05/13/93	CALL IN TIME 14:49	SCHEDULE DATE 05/14/93
INSPECTOR/NAME BOB WARD - 84		MARKETING/BUSINESS NAME CORAL BAY		
INSPECTION REQUESTED DRYWALL NAILING (125)				

- ① Missing rock closet + garage
- ② Repair all locations where nails in edge-seal at butt joints
- ③ Garage shear wall not 4" OC

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL 229 2071		☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		
INSPECTOR SIGNATURE BW		INSPECTION DATE 5-15-93		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C OF O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call * 229 6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	9
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO		BLOCK NO	SUBDIVISION NAME	
117		5	VILLA FINESTRA UNIT 2A	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	05/12/93	13:39	05/13/93
INSPECTOR NO		INSPECTOR NAME		
84		BOB WARD		
INSPECTION REQUESTED		DRYWALL NAILING (125)		

CORAL BAY

Completed retil

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE			INSPECTION DATE	
BW			5-13-93	
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C OF O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765


For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	34
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO		BLOCK NO	SUBDIVISION NAME	
117		5	VILLA FINESTRA UNIT 2A	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	451-6222	05/06/93	15:02	05/07/93
INSPECTOR NO		INSPECTOR NAME		
84		BOB WARD		
INSPECTION REQUESTED		INSULATION (123)		

CORAL BAY

Insul water line at vent

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE		INSPECTION DATE		
		5-7-93		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types


DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	8
JOB ADDRESS		3105 ST TROPEZ ST 113189		
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA <u>CORAL BAY</u> FINESTRA		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	03/29/93	13:52	03/30/93
INSPECTOR NO	INSPECTOR NAME			
59/65	BOB GATES <u>LOW BRUNSON</u> SID			
INSPECTION REQUESTED	SHEAR (109)			

PLAN -
(CHECK PRIOR LISTS)

LATE
PM

-OK

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE			INSPECTION DATE 3-30-93	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C OF O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6769

For Additional Assistance Call *229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	7
JOB ADDRESS 3105 ST TROPEZ ST 113189				
LOT NO 117		BLOCK NO 5		SUBDIVISION NAME <i>Solar Bay</i> VILLA FINESTRA
FIRE DEPT MAP NO 2117-17	JOB PHONE 255-4662	CALL IN DATE 03/29/93	CALL IN TIME 13:51	SCHEDULE DATE 03/30/93
INSPECTOR NO 59 / GS		INSPECTOR NAME BOB BATES <i>Wm BRUNSON</i> SID		
INSPECTION REQUESTED ROOF SHEATHING (107)				

LATE
PM

PLAN —

(CHECK PRIOR LISTS)

— OK, EXCEPT REMAIN REAR BOUNDARY BLOCKS, BETWEEN TRUSS ENDS

— BUK UNDER LARGE GAP, upper ^{RF/} SHEATH FRT., USE 2" X

— OK — TO "DRY-IN", ONLY

— RECALL THIS INSP.

☐ PARTIAL INSPECTION	☒ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
RECEIVED (A)		REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE <i>[Signature]</i>		INSPECTION DATE 3-30-93		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-67 69

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	14
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO 117	BLOCK NO 5	SUBDIVISION NAME VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO 2117-17	JOB PHONE 255-4662	CALL IN DATE 34/07/93	CALL IN TIME 14:43	SCHEDULE DATE 04/08/93
INSPECTOR NO 84	INSPECTOR NAME BOB WARD			

INSPECTION REQUESTED	FRAMING (12C)
-----------------------------	----------------------

CORAL BAY

- ① CB-66 missing at garage
- ② A-Bs missing at garage shear wall - 48" oc
- ③ Shear not transferred at garage
- ④ Install gable bracing per plans -
- ⑤ Trusses upstairs not bracing properly
- ⑥ Shear nailing at wall downstairs incomplete
- ⑦ Shear wall transfer at Kit - to top plate
- ⑧ Provide copy of concrete detail -
- ⑨ Complete all details per plan +
Correct other items Mech, Plb - Elect
ECT & Mech

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☒ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			

INSPECTOR SIGNATURE <i>B Ward</i>	INSPECTION DATE 4-8-93
--------------------------------------	----------------------------------

☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)
---	---

IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY
CALL THE INSPECTOR FROM 7 00 AM 7 15 AM OR 2 45 PM 3 00 PM AT

229-6765

For Additional Assistance Call * 229 6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	23-176567	INSPECTION NUMBER	16
JOB ADDRESS				
3105 ST TROPEZ ST			113180	
LOT NO 117	BLOCK NO 5	SUBDIVISION NAME VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO 2117-17	JOB PHONE 255-4662	CALL IN DATE 04/07/93	CALL IN TIME 14:44	SCHEDULE DATE 04/08/93
INSPECTOR NO 84	INSPECTOR NAME BOB WARD			
INSPECTION REQUESTED	ROUGH MECHANICAL (320)			
CORAL BAY ① Return needs to be ducted at stair way ② FAU Flue not installed properly				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL * 229 2071		☐ PERMIT REQUIRED	
☒ FEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE		INSPECTION DATE		
<i>Bob Ward</i>		4-8-93		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 AM 7 15 AM OR 2 45 PM 3 00 PM AT				229-6765

For Additional Assistance Call * 229 6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS


☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	21
JOB ADDRESS				
3105 ST TROPICZ ST			113189	
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA FINESTR [®]		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	755-4662	12/25/93	13:55	02/26/93
INSPECTOR NO	INSPECTOR NAME			
59	BOB GATES			
INSPECTION REQUESTED	STEM WALL - FORMS & REBAR (103)			

Reg
M/Rdy

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) -- UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE	B. Gates 2 26 93		INSPECTION DATE	
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6769

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	26
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO		BLOCK NO	SUBDIVISION NAME	
117		5	VILLA FINESTRA	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	02/25/93	13:54	02/26/93
INSPECTOR NO		INSPECTOR NAME		
59		BOB GATES		
INSPECTION REQUESTED		FOOTING, LAYOUT, REBAR, ZONING (101)		
PROPERTY LINE & SETBACKS VERIFIED BY: ----- Ref - N/Rdy				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE				INSPECTION DATE
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6769

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☐	PERMIT NUMBER	93-176567	INSPECTION NUMBER	28
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA FINESTRA		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	225-4662	02/26/93	14:53	03/01/93
INSPECTOR NO		INSPECTOR NAME		
59		BOB GATES		
INSPECTION REQUESTED		FOOTING, LAYOUT, REBAR, ZONING (101)		
PROPERTY LINE & SETBACKS VERIFIED BY: [Signature] Wufes				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) -- UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE		[Signature]		INSPECTION DATE
3 1 93				
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6769

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176507	INSPECTION NUMBER	33
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO		BLOCK NO	SUBDIVISION NAME	
117		5	VILLA FINESTRA	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	451-6222	03/05/93	14:40	03/08/93
INSPECTOR NO		INSPECTOR NAME		
59		BOB GATES		
INSPECTION REQUESTED		PRF-SLAB (105)		

EARLY A.M.

PROPERTY LINE & SETBACKS VERIFIED BY:

Reg
-N/Rdy

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL * 229 2071		☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		
INSPECTOR SIGNATURE		INSPECTION DATE		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6769

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	29
JOB ADDRESS				
3105 ST TROPFZ ST			113139	
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA FI IS		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	451-6222	03/08/93	14:42	03/09/93
INSPECTOR NO	INSPECTOR NAME			
59	BOB GATES			
INSPECTION REQUESTED				
PRE-SLAB (105)				
EARLY A.M. PROPERTY LINE & SETBACKS VERIFIED BY: <i>X [Signature]</i>				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE	<i>[Signature]</i> 3993		INSPECTION DATE	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6769

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	9
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA FINESTRA		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	03/24/93	14:04	03/25/93
INSPECTOR NO	INSPECTOR NAME			
59	BOB GATES			
INSPECTION REQUESTED		ROOF SHEATHING (107)		

Reg
- N/Rdy

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE		INSPECTION DATE		
		3 25 93		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6769

For Additional Assistance Call *229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	10
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO		BLOCK NO	SUBDIVISION NAME	
117		5	VILLA FINESTRA	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	03/24/93	14:04	03/25/93
INSPECTOR NO		INSPECTOR NAME		
59		BOB GATES		
INSPECTION REQUESTED		SHEAR (109)		
<i>Reg</i> <i>- N/Rdy</i>				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE		INSPECTION DATE		
 3 25 93				
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				➤ 229-6769

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	14
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA FINESTRA		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	03/25/93	14:28	03/26/93
INSPECTOR NO	INSPECTOR NAME			
59	BOB GATES			
INSPECTION REQUESTED	SHEAR (109)			

Ref
- Nail P.H.D

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE	<i>[Signature]</i> 3 26 93			INSPECTION DATE
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6769

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER	93-176567	☒ INSPECTION NUMBER	17
JOB ADDRESS 3105 ST TROPEZ ST 113189			
LOT NO 117	BLOCK NO 5	SUBDIVISION NAME VILLA FINESTRA	
FIRE DEPT MAP NO 2117-17	JOB PHONE 255-4662	CALL IN DATE 03/25/93	CALL IN TIME 14:30
INSPECTOR NO 59		INSPECTOR NAME BOB GATES	
INSPECTION REQUESTED		ROOF SHEATHING (107)	
<i>Key</i> <i>- bN @ over stacked area</i> <i>- used BN'ing @ perimeters</i>			
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION	
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL
☒ REJECTED (R)	☐ REFEE (F)	☐ HOLD (H)	☐ PERMIT REQUIRED
INSPECTOR SIGNATURE		INSPECTION DATE	
<i>B. Gates</i>		3 26 93	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT			229-6769

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	53
JOB ADDRESS		3105 ST TROPEZ ST		113189
LOT NO	117	BLOCK NO	5	SUBDIVISION NAME Coral Bay VILLA FINESTRA
FIRE DEPT MAP NO	2117-17	JOB PHONE	451-6222	CALL IN DATE 03/30/93
			CALL IN TIME 15:09	SCHEDULE DATE 03/31/93
INSPECTOR NO	59	INSPECTOR NAME BOB GATES Lou Brunson		
INSPECTION REQUESTED		ROOF SHEATHING (107)		
EARLY P.M. PLAN — — finish nailing blocking @ perimeter APV'd Subject ↑				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED	
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE		INSPECTION DATE 3-31-93		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 AM 7 15 AM OR 2 45 PM 3 00 PM AT				229-6769

For Additional Assistance Call * 229 6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	16
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO		BLOCK NO	SUBDIVISION NAME	
117		5	WILLA FINESTRA	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	04/06/93	14:12	04/07/93
INSPECTOR NO		INSPECTOR NAME		
85		BOB WARD 73		
INSPECTION REQUESTED		TOP OUT-WATER, GAS, WASTE (420)		
CORAL BAY WHERE IS 100 PSI TEST FOR Poly system				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE		73		INSPECTION DATE
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	15
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO 117	BLOCK NO 5	SUBDIVISION NAME VILLA FINESTRA		
FIRE DEPT MAP NO 2117-17	JOB PHONE 255-4662	CALL IN DATE 04/06/93	CALL IN TIME 14:11	SCHEDULE DATE 04/07/93
INSPECTOR NO 85	INSPECTOR NAME BOB WARD <i>73</i>			
INSPECTION REQUESTED	ROUGH MECHANICAL (320)			
CORAL BAY FURNACE VENT CAN HAVE NO MORE THAN 1 60° OFFSET, REMOVE DUCT TAPE FROM B VENT 7" CLEARANCE REQ ON ATTIC B VENT				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED	
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE	<i>73</i>		INSPECTION DATE 4 7 93	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	14
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO		BLOCK NO	SUBDIVISION NAME	
117		5	VILLA FINESTRA	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	04/06/93	14:11	04/07/93
INSPECTOR NO		INSPECTOR NAME		
85		BOB WARD 72		
INSPECTION REQUESTED		ROUGH ELECTRICAL (220)		
CORAL BAY BLK CEILING & BOXES WHEREVER POSSIBLE CEILING CAN CAN BE MOUNTED UFR CLAMP LOOSE BAR FHA STRAP SERVICE RIZER				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		
INSPECTOR SIGNATURE		INSPECTION DATE		
73		4793		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 AM 7 15 AM OR 2 45 PM 3 00 PM AT				229-6765

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	13
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO		BLOCK NO	SUBDIVISION NAME	
117		5	VILLA FINESTRA	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	04/06/93	14:11	04/07/93
INSPECTOR NO		INSPECTOR NAME		
84 85		BOB WARD 73		
INSPECTION REQUESTED		FRAMING (120)		
CORAL BAY 30" PLATE FORM REQ IN FRONT OF ATTIC UNIT BLKING FOR CORE UNIT IN PROPERLY INSTALLED, PB GAR NOT COMPLETELY NAILED STRAIGHTEN MONO TRUSSES, ABOVE HALLWAY, FIRE STOPPING LIVING RM COLUMNS AND FIRE DWNS PB 44 UTILITY RM? IN PROPER GIRDER FOR FLOOR TRUSSES ABOVE MASTER CLOSET STRAP TOP PLATE ACROSS 4x4 GAR, WAY				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		
INSPECTOR SIGNATURE		73		INSPECTION DATE
				4793
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C OF O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call *229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

A	PERMIT NUMBER	93-176567	APPLICATION NUMBER	113189
JOB ADDRESS			INSPECTION NUMBER	
3105 ST TROPEZ ST			3	
LOT/BLOCK		RECORDED SUBDIVISION NAME		
117 5		VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	05/14/93	13:05	05/17/93
INSPECTOR/NAME		MARKETING/BUSINESS NAME		
BOB HARD - 84		CORAL BAY		
INSPECTION REQUESTED		DRYWALL NAILING (125)		

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T)	☐ HOLD (H)
☐ REJECTED (R)		REINSPECTION REQUIRED CALL 229 2071		☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		
INSPECTOR SIGNATURE		INSPECTION DATE		
BW		5-17-93		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call 229 6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

H	PERMIT NUMBER	93-176567	APPLICATION NUMBER	113180
JOB ADDRESS			INSPECTION NUMBER	
3105 SY TROPEZ ST			6	
LOT/BLOCK		RECORDED SUBDIVISION NAME		
117 5		VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	05/14/93	13:06	05/17/93
INSPECTOR/NAME		MARKETING/BUSINESS NAME		
BOB HARD - 84		CORAL BAY		
INSPECTION REQUESTED		FINAL GAS TEST (423)		

28838

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) UNTIL	☐ HOLD (H)
☐ REJECTED (R)		REINSPECTION REQUIRED CALL 229 2071		☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		
INSPECTOR SIGNATURE			INSPECTION DATE	
			5-17-93	
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call * 229 6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER	93-176567	APPLICATION NUMBER	113139
JOB ADDRESS 3105 ST TROPEZ ST		INSPECTION NUMBER 39	
LOT/BLOCK 117 5	RECORDED SUBDIVISION NAME VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO 2117-17	JOB PHONE 255-4662	CALL IN DATE 05/13/93	CALL IN TIME 14:49
SCHEDULE DATE 05/14/93			
INSPECTOR/NAME BOB WARD - 84		MARKETING/BUSINESS NAME CORAL BAY	
INSPECTION REQUESTED	DRYWALL NAILING (125)		

- ① Missing rock closet + garage
- ② Repair all locations where nails in edge-secure at butt joints
- ③ Garage shear wall not 4" OC

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T)	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL 229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE <i>BW</i>		INSPECTION DATE 5-15-93		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call * 229 6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	9
JOB ADDRESS				
3905 ST TROPEZ ST 113189				
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4462	05/12/93	13:39	05/13/93
INSPECTOR NO	INSPECTOR NAME			
84	BOB WARD			
INSPECTION REQUESTED	DRYWALL NAILING (125)			

CORAL BAY

Completed recheck

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		
INSPECTOR SIGNATURE	BWL		INSPECTION DATE	
				5-13-93
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C OF O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	52
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO 117	BLOCK NO 5	SUBDIVISION NAME VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO 2117-17	JOB PHONE 055-4662	CALL IN DATE 05/05/93	CALL IN TIME 14:53	SCHEDULE DATE 05/06/93
INSPECTOR NO 84	INSPECTOR NAME BOB WARD Carson 68			
INSPECTION REQUESTED	INSULATION (123)			
CORAL BAY ①. feed insulation ABOVE Blocks - 2 Locations, ②. Return air plenum - Stuff area for fire stop. ③. BATH, 12" SALVAGE, vehicle penetration (water service) AT tub. ④. Check all water SERVICE penetrations & stuff where needed. ⑤. Complete any correction notices. Some of the returning water & sewage exhausts still have no one at a site.				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☒ STOP WORK (S)	☒ COMMENTS (C)	☐ TEMPORARY APPROVAL (T)	☐ UNTIL HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED	
☐ RESEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE		INSPECTION DATE		
<i>John E</i>		5693		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	34
JOB ADDRESS				
3105 ST TROPES ST 113180				
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA EQUESTRA UNIT 2A		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	651-6222	05/06/93	15:02	05/07/93
INSPECTOR NO	INSPECTOR NAME			
84	BOB WARD			
INSPECTION REQUESTED	INSULATION (123)			

CORAL BAY

Insol water line at vent

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED	
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE	B. Ward		INSPECTION DATE 5-7-93	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

PERMIT
NUMBER

85-475567

INSPECTION
NUMBER

13

JOB ADDRESS

3105 ST TROPEZ ST

113189

LOT NO

117

BLOCK NO

5

SUBDIVISION NAME

VILLA PINESTRA UNIT 2A

FIRE DEPT MAP NO

2117-17

JOB PHONE

451-6222

CALL IN DATE

04/14/93

CALL IN TIME

14:14

SCHEDULE DATE

04/15/93

INSPECTOR NO

8470

INSPECTOR NAME

BOB WARD

DRM

INSPECTION
REQUESTED

ROUGH ELECTRICAL (220)

CORAL BAY

- DO NOT PUT WIRES UNDER LARGE SCREW NEXT TO VTR IN MAIN
- MIN 1/4" INSULATION PAST BUSHING IN MAIN
- IS BAR SINK IN DEN OF 1?
- ADD TO ONE OF STAIR LANDINGS
- UP BED RM'S 6 + 12 / FIX BOX ON WALL
- BLACK CIELING BOXES FOR FANS

JEFF STAFFORD / REPUBLIC

I WILL CORRECT ABOVE

[Signature]

WILL APPEAL BLOCKING CIELING BOXES

☐ PARTIAL INSPECTION

☐ PARTIAL APPROVAL (P)

PARTIAL DESCRIPTION

☒ APPROVED (A)

☐ STOP WORK (S)

☐ COMMENTS (C)

☐ TEMPORARY APPROVAL (T) - UNTIL

☐ HOLD (H)

☐ REJECTED (R)

REINSPECTION REQUIRED CALL *229 2071

☐ REFEE (F)

REINSPECTION FEE REQUIRED - PAY AT CITY HALL

☐ PERMIT REQUIRED

INSPECTOR
SIGNATURE

[Signature]

INSPECTION DATE

4-15-93

☐ PROJECT COMPLETE

BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C OF O ISSUANCE (Commercial Only)

IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 AM 7 15 AM OR 2 45 PM 3 00 PM AT

229-6765

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

1	PERMIT NUMBER	93-176567	INSPECTION NUMBER	29
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	055-4662	04/30/93	14:25	05/03/93
INSPECTOR NO	INSPECTOR NAME			
84/81	BOB WARD			
INSPECTION REQUESTED	ROUGH MECHANICAL (320)			

CORAL BAY

Need to have revised
 plans approved for h rail
 Need to install dryer vent
 to 5" above top plate 4' cannot exceed
 14'.

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE			INSPECTION DATE	
		5/3/93		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C OF O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call *229 6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

(K)	PERMIT NUMBER	93-176567	INSPECTION NUMBER	30
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2917-17	055-4662	04/30/93	14:26	05/03/93
INSPECTOR NO		INSPECTOR NAME		
84		BOB WARD		
INSPECTION REQUESTED				
		FRAPING (120)		

CORAL BAY

- ① Repair plb - At truss fixes - re-test
- ② Nail drywall Above l.p - garage wall 4'00
- ③ Block under main block - Return plenum
- ④ Dryer vent 5" From top plate out

CK At Insul

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED CALL * 229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE		INSPECTION DATE		
B.W.L.		5-3-93		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A.M. 7 15 A.M. OR 2 45 P.M. 3 00 P.M. AT				229-6765

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

M	PERMIT NUMBER	93-176567	INSPECTION NUMBER	28
JOB ADDRESS				
3105 ST TROPEZ ST				113189
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	055-4662	04/30/93	14:25	05/03/93
INSPECTOR NO	INSPECTOR NAME			
84/100	BOB WARD			
INSPECTION REQUESTED	TOP OUT-WATER, GAS, WASTE (420)			
CORAL BAY Poly dest gpp Need to connect plbging at L xed truss				
☐ PARTIAL INSPECTION ☐ PARTIAL APPROVAL (P) PARTIAL DESCRIPTION				
☒ APPROVED (A) ☐ STOP WORK (S) ☐ COMMENTS (C) ☐ TEMPORARY APPROVAL (T) — UNTIL ☐ HOLD (H)				
☐ REJECTED (R) REINSPECTION REQUIRED CALL * 229 2071 ☐ PERMIT REQUIRED				
☐ REFEE (F) REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET				
INSPECTOR SIGNATURE				INSPECTION DATE
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call * 229 6251 See Reverse Side For Inspection Types

PERMIT NUMBER	93-176567	INSPECTION NUMBER	35
JOB ADDRESS 3105 ST TROPEZ ST 113189			
LOT NO 117	BLOCK NO 5	SUBDIVISION NAME VILLA FINESTRA UNIT 2A	
FIRE DEPT MAP NO 2117-17	JOB PHONE 255-4662	CALL IN DATE 04/28/93	CALL IN TIME 14:45
SCHEDULE DATE 04/29/93			
INSPECTOR NO 84	INSPECTOR NAME BOB WARD		
INSPECTION REQUESTED	SHEAR (109)		

CORAL GAY

CK Attachment upstairs
truss to wall —

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION	
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL
☐ HOLD (H)			
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		
INSPECTOR SIGNATURE <i>Bob Ward</i>		INSPECTION DATE 4-29-93	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT			229-6765

☐	PERMIT NUMBER	93-176567	INSPECTION NUMBER	38
JOB ADDRESS				
3905 ST TROPEZ ST 113189				
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	04/28/93	14:47	04/29/93
INSPECTOR NO	INSPECTOR NAME			
84	BOB WARD			
INSPECTION REQUESTED	FRAMING (120)			

CORAL BAY

Not ready

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☒ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE		INSPECTION DATE		
[Signature]		4-29-93		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C OF O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

☐	PERMIT NUMBER	93-176567	INSPECTION NUMBER	36
JOB ADDRESS 3105 ST TROPEZ ST 113189				
LOT NO 117	BLOCK NO 5	SUBDIVISION NAME VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO 2117-17	JOB PHONE 255-4662	CALL IN DATE 04/28/93	CALL IN TIME 14:46	SCHEDULE DATE 04/29/93
INSPECTOR NO 84181	INSPECTOR NAME BOB WARD			
INSPECTION REQUESTED	ROUGH MECHANICAL (320)			

CORAL BAY

14'
28' max
jobsite

Dryer vent cannot exceed
No approved mech plus on

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		
INSPECTOR SIGNATURE <i>Bob Ward</i>		INSPECTION DATE 4.29.93		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765


For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

PERMIT	NUMBER	93-176567	INSPECTION	NUMBER	37
JOB ADDRESS					
3105 ST TROPEZ ST 113189					
LOT NO		BLOCK NO		SUBDIVISION NAME	
117		15		VILLA FINESTRA UNIT 2A	
FIRE DEPT MAP NO		JOB PHONE		CALL IN DATE	
2117-17		255-4862		06/28/93	
CALL IN TIME		SCHEDULE DATE			
14:46		06/29/93			
INSPECTOR NO		INSPECTOR NAME			
84181		BOB WARD			
INSPECTION REQUESTED		TOP OUT-WATER, GAS, WASTE (420)			

CORAL BAY

need to connect 2nd flr
waste's + water test
Also need 100 lbs poly test.

☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION	
☐ APPROVED (A)		☐ STOP WORK (S)		☐ COMMENTS (C)	
☐ TEMPORARY APPROVAL (T)		☐ UNTIL		☐ HOLD (H)	
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071			
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
☐ PERMIT REQUIRED					
INSPECTOR SIGNATURE		INSPECTION DATE			
		4-29-93			
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT					229-6765

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER	93-176567		☒ INSPECTION NUMBER	15
JOB ADDRESS 3105 ST TROPEZ ST 113189				
LOT NO 117	BLOCK NO 5	SUBDIVISION NAME VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO 2117-17	JOB PHONE 451-6222	CALL IN DATE 04/14/93	CALL IN TIME 14:16	SCHEDULE DATE 04/15/93
INSPECTOR NO 84	INSPECTOR NAME BOB WARD			
INSPECTION REQUESTED	TOP OUT-WATER, GAS, WASTE (420)			


CORAL BAY

Complete water recall

☒ PARTIAL INSPECTION	☒ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION <i>DB Fast OK</i>		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL * 229 2071		☐ PERMIT REQUIRED	
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE <i>Bob Ward</i>		INSPECTION DATE 4-15-93		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 AM 7 15 AM OR 2 45 PM 3 00 PM AT			229-6765	

For Additional Assistance Call * 229 6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

M	PERMIT NUMBER	93-176567	INSPECTION NUMBER	14
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO		BLOCK NO		SUBDIVISION NAME
117		5		VILLA FINESTRA UNIT 2A
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	451-6222	04/14/93	14:16	04/15/93
INSPECTOR NO		INSPECTOR NAME		
84		BOB WARD		
INSPECTION REQUESTED		ROUGH MECHANICAL (320)		
CORAL BAY ① FALL/Water heater flue not acceptable No more than 1 60° offset 2 Return plenum at garage-wall must be insulated & sealed - No open faced Insul at plenum				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☐ APPROVED (A)		☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		☐ HOLD (H)
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE			INSPECTION DATE	
			4-15-93	
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call *229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

M	PERMIT NUMBER	93-176567	INSPECTION NUMBER	12
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO		BLOCK NO	SUBDIVISION NAME	
117		5	VILLA FINESTRA UNIT 2A	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	651-6222	04/14/93	14:13	04/15/93
INSPECTOR NO		INSPECTOR NAME		
84		BOB WARD		
INSPECTION REQUESTED		FRAMING (120)		

CORAL BAY

- ① Boundary nailing at upstairs truss to truss wall no connect - A35 not nailed
- ② Trusses downstairs not bearing properly at hull
- ③ Break at roof sheathing at item ① Block - G-3 wall at Above
- ④ All 2x4 material to be stud grade not standard or better

Go back ck house & Details ect
recall

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		☐ PERMIT REQUIRED

INSPECTOR SIGNATURE	INSPECTION DATE
BWQ	4-15-93

☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)
--	--

IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT

229-6765

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	20
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO		BLOCK NO	SUBDIVISION NAME	
117		5	VILLA FINESTRA UNIT 2A	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	451-6222	04/14/93	14:18	04/15/93
INSPECTOR NO		INSPECTOR NAME		
84		BOB WARD		
INSPECTION REQUESTED		SHEAR (109)		

CORAL BAY


① CK all details - trusses and shear walls transfer, blocking out

② D/b G-2 shear wall at rake above entry cannot be built - revision req

③ Full bearing - truss cot above landing at stair - above return plenum

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		
INSPECTOR SIGNATURE		INSPECTION DATE		
B.W.		4-15-93		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF, TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 AM 7 15 AM OR 2 45 PM 3 00 PM AT				229-6765

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

1	PERMIT NUMBER	93-176567	INSPECTION NUMBER	3
JOB ADDRESS 3105 ST TROPEZ ST 113189				
LOT NO 117		BLOCK NO 5		SUBDIVISION NAME VILLA FINESTRA UNIT 2A
FIRE DEPT MAP NO 2117-17	JOB PHONE 055-4662	CALL IN DATE 04/12/93	CALL IN TIME 14:09	SCHEDULE DATE 04/13/93
INSPECTOR NO 84		INSPECTOR NAME BOB WARD		
INSPECTION REQUESTED		EXTERIOR LATH/STUCCO (129)		
CORAL BAY				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED	
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE 			INSPECTION DATE 4-13-93	
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 AM 7 15 AM OR 2 45 PM 3 00 PM AT				229-6765

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

1	PERMIT NUMBER 93-176567	INSPECTION NUMBER 18		
JOB ADDRESS 3105 ST TROPEZ ST 113189				
LOT NO 117	BLOCK NO 5 th	SUBDIVISION NAME VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO 2117-17	JOB PHONE 255-4662	CALL IN DATE 04/07/93	CALL IN TIME 14:45	SCHEDULE DATE 04/08/93
INSPECTOR NO 84	INSPECTOR NAME BOB HARD			
INSPECTION REQUESTED	TOP OUT-WATER, GAS, WASTE (420)			
CORAL BAY ① Water heater vent not acceptable No more than 160 offset ② Heat exchanger water heater to be replaced OK Per Manufacturer ② Insulate piping at Attic - protect from Freezing Sec-315 UPC - All <u>homes</u>				
☐ PARTIAL INSPECTION ☐ PARTIAL APPROVAL (P) PARTIAL DESCRIPTION				
☐ APPROVED (A) ☐ STOP WORK (S) ☐ COMMENTS (C) ☐ TEMPORARY APPROVAL (T) - UNTIL ☐ HOLD (H)				
☒ REJECTED (R) REINSPECTION REQUIRED CALL *229 2071 ☐ PERMIT REQUIRED				
☐ REFEE (F) REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET				
INSPECTOR SIGNATURE B. Hard			INSPECTION DATE 4-8-93	
☐ PROJECT COMPLETE			BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)	
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call *229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

A	PERMIT NUMBER ➤	93-176567	INSPECTION NUMBER ➤	14
JOB ADDRESS 3105 ST TROPEZ ST 113189				
LOT NO 117	BLOCK NO 5	SUBDIVISION NAME VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO 2117-17	JOB PHONE 255-4662	CALL IN DATE 04/07/93	CALL IN TIME 14:43	SCHEDULE DATE 04/08/93
INSPECTOR NO 84	INSPECTOR NAME BOB WARD			
INSPECTION REQUESTED ➤	FRAMING (120)			
CORAL BAY ① CB-66 missing at garage ② A-Bs missing at garage shear wall - 48" oc ③ Shear not transferred at garage ④ Install gable bracing per plan - ⑤ Trusses upstairs not bearing properly ⑥ Shear nailing at wall downstairs incomplete ⑦ Shear wall transfer at kit - to top plate ⑧ Provide copy of concrete detail - ⑨ Complete all details per plan + Correct other items Mech, Plb - Elect ECT & Mech				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED
☒ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		
INSPECTOR SIGNATURE <i>Bob Ward</i>		INSPECTION DATE 4-8-93		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				➤ 229-6765

For Additional Assistance Call *229 6251 See Reverse Side For Inspection Types ,

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

X	PERMIT NUMBER 93-176567	INSPECTION NUMBER 15
JOB ADDRESS 3105 ST TROPEZ ST 113189		
LOT NO 117	BLOCK NO 5	SUBDIVISION NAME VILLA FINESTHO UNIT 2A
FIRE DEPT MAP NO 2117-17	JOB PHONE 255-4662	CALL IN DATE 04/07/93
		CALL IN TIME 14:44
SCHEDULE DATE 04/08/93		
INSPECTOR NO 84	INSPECTOR NAME BOB WARD	
INSPECTION REQUESTED	ROUGH ELECTRICAL (220)	

CORAL BAY

① Block All light boxes where a fan can be hung - 90-4 NEC

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE 		INSPECTION DATE 4-8-93		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call *229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

H	PERMIT NUMBER	93-176567	INSPECTION NUMBER	16
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA FINESTRA UNIT 2A		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	04/07/93	14:44	04/08/93
INSPECTOR NO	INSPECTOR NAME			
84	BOB WARD			
INSPECTION REQUESTED	ROUGH MECHANICAL (320)			
CORAL BAY ① Return needs to be ducted at stairway ② FAU Flue not installed properly				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED	
☒ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE	<i>Bob Ward</i>		INSPECTION DATE	
		4-8-93		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 AM 7 15 AM OR 2 45 PM 3 00 PM AT				229-6765

For Additional Assistance Call * 229 6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER		15
JOB ADDRESS					
3105 ST TROPEZ ST					113189
LOT NO		BLOCK NO		SUBDIVISION NAME	
117		5		VILLA FINESTRA	
FIRE DEPT MAP NO		JOB PHONE		CALL IN DATE	CALL IN TIME
2917-17		255-4662		04/06/93	14:11
INSPECTOR NO		INSPECTOR NAME			
85		BOB HART 73			
INSPECTION REQUESTED		ROUGH MECHANICAL (320)			
CORAL BAY FURNACE VENT CAN HAVE NO MORE THAN 1-60° OFFSET, REMOVE DUCT TAPE FROM B VENT 1" CLEARANCE REASON ATTIC B VENT FILE 229-6251					
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION	
☐ APPROVED (A)		☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE		73		INSPECTION DATE	
				4/7/93	
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT					229-6765

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

1	PERMIT NUMBER	93-176567	INSPECTION NUMBER	14
JOB ADDRESS				
3105 SY TROPEZ ST			113189	
LOT NO		BLOCK NO		SUBDIVISION NAME
117		5		VILLA FINESTRA
FIRE DEPT MAP NO		JOB PHONE		CALL IN DATE
2117-17		255-4662		04/06/93
CALL IN TIME		SCHEDULE DATE		
14:11		04/07/93		
INSPECTOR NO		INSPECTOR NAME		
85		BOB BARD 73		
INSPECTION REQUESTED		ROUGH ELECTRICAL (220)		
CORAL BAY BLK. CEILING & P. BOXES. WHEREVER POSSIBLE CEILING CAN BE MOUNTED UNDER CLAMP LOOSE BAR FHA STRAP SERVICE RIZER				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☐ APPROVED (A)		☐ STOP WORK (S)		☐ COMMENTS (C)
☐ REJECTED (R)		☐ TEMPORARY APPROVAL (T)		☐ HOLD (H)
☐ REFEE (F)		☐ UNTIL		☐ PERMIT REQUIRED
REINSPECTION REQUIRED		CALL * 229 2071		
REINSPECTION FEE REQUIRED		PAY AT CITY HALL		
3RD FLOOR 400 E STEWART STREET				
INSPECTOR SIGNATURE		INSPECTION DATE		
73		4793		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				➤
				229-6765

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

A	PERMIT NUMBER	93-176567	INSPECTION NUMBER	13
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO		BLOCK NO		SUBDIVISION NAME
117		5		VILLA FINESTRA
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	04/06/93	14:11	04/07/93
INSPECTOR NO		INSPECTOR NAME		
85		BOB WARD <i>[Signature]</i>		
INSPECTION REQUESTED		FRAMING (120)		
CORAL BAY 30" PLATE FORM REQ IN FRONT OF AIR-CON UNIT BLKING FOR CORE UNIT IN PROPERLY INSTALLED; PB GAR NOT COMPLETELY NAILED STRAIGHTEN MONO TRUSSES ABOVE HALLWAY; FIRE STOPPING LIVING RM COLUMNS AND FIRE DWNS PB 44 UTILITY RM? IN PROPER BORDER FOR FLOOR TRUSSES ABOVE MASTER CLOSET STRAP TOP PLATE ACROSS 4x4 GARWAY				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) -- UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		
INSPECTOR SIGNATURE		<i>[Signature]</i>		INSPECTION DATE
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call * 229 6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

W	PERMIT NUMBER	93-176567	INSPECTION NUMBER	16
JOB ADDRESS				
3905 ST TROPEZ ST			113189	
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA FINESTRA		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	04/06/93	14:12	04/07/93
INSPECTOR NO		INSPECTOR NAME		
8/85		BOB WOOD FS		
INSPECTION REQUESTED		TOP OUT-WATER, GAS, WASTE (420)		
CORAL BAY WHERE IS 100 PSI TEST FOR POLY. SYSTEM				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		
INSPECTOR SIGNATURE		FS		INSPECTION DATE
☐ PROJECT COMPLETE		4/7/93		
BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)				
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6765

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS					
☒	PERMIT NUMBER	93-176567		INSPECTION NUMBER	7
JOB ADDRESS		3105 ST TROPEZ ST		113189	
LOT NO	BLOCK NO	SUBDIVISION NAME			
117	5	CORN BAY VILLA PINESTRA			
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE	
2117-17	255-4662	03/29/93	13:51	03/30/93	
INSPECTOR NO	INSPECTOR NAME				
59/68	BOB BATES Lou Bernison SID				
INSPECTION REQUESTED	ROOF SHEATHING (107)				

PLAN —

(CHECK PRIOR LISTS) OK

OK, EXCEPT REINFORCING BOUNDARY BLOCKS BETWEEN TRUSS ENDS

BUT UNDER LARGE GAP, UPPER FRT., USE 2" X

OK — TO DRY-IN, ONLY

RECALL THIS INSP.

☐ PARTIAL INSPECTION	☒ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION			
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T)	— UNTIL	☐ HOLD (H)
☒ REINSPECTION REQUIRED (R)		REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED	
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE		INSPECTION DATE			
[Signature]		3-30-93			
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C OF O ISSUANCE (Commercial Only)				

IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT

229-6769

For Additional Assistance Call * 229 6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY						CITY OF LAS VEGAS	
☐	PERMIT NUMBER	93-176567		INSPECTION NUMBER	8		
JOB ADDRESS 3105 ST TROPEZ ST 113189							
LOT NO 117		BLOCK NO 5		SUBDIVISION NAME CORAL BAY VILLA FINESTRA			
FIRE DEPT MAP NO 2117-17		JOB PHONE (255-4662		CALL IN DATE 03/29/93		CALL IN TIME 13:52	
SCHEDULE DATE 03/30/93							
INSPECTOR NO 59/65		INSPECTOR NAME BOB GATES Lou Brownson SID					
INSPECTION REQUESTED		SHEAR (109)					

PLAN -

(CHECK PRIOR LIST)

LATE
PM

OK

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION					
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T)	- UNTIL		☐ HOLD (H)	
☒ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED			
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET						
INSPECTOR SIGNATURE		INSPECTION DATE 3-30-93					
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)					
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 AM 7 15 AM OR 2 45 PM 3 00 PM AT							229-6769

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

1	PERMIT NUMBER 93-176567	INSPECTION NUMBER 53	
JOB ADDRESS 3105 ST TROPEZ ST 113189			
LOT NO 917	BLOCK NO 5	SUBDIVISION NAME CORAL BAY VILLA PINESTRA	
FIRE DEPT MAP NO 2117-17	JOB PHONE 451-6222	CALL IN DATE 03/30/93	CALL IN TIME 15:09
SCHEDULE DATE 03/31/93			
INSPECTOR NO 59	INSPECTOR NAME BOB GAYES <i>Jan Brunson</i>		
INSPECTION REQUESTED	ROOF SHEATHING (107)		
EARLY P.M. PLAN — — finish nail; b/lk 5 @ terminator App'd Subject ↑			
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION	
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL
			☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		
INSPECTOR SIGNATURE	INSPECTION DATE 3 31-93		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C OF O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 AM 7 15 AM OR 2 45 PM 3 00 PM AT			229-6769

For Additional Assistance Call * 229 6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

PERMIT NUMBER	93-176567	INSPECTION NUMBER	17
JOB ADDRESS			
3105 ST TROPEZ ST		113189	
LOT NO	BLOCK NO	SUBDIVISION NAME	
117	5	VILLA FINESTRA	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME
2117-17	255-4662	03/25/93	14:30
SCHEDULE DATE		03/26/93	
INSPECTOR NO	INSPECTOR NAME		
59	BOB GATES		
INSPECTION REQUESTED	ROOF SHEATHING (107)		

Ref
 - bN @ overstacked area
 - used BN'ing @ perimeters

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION	
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL
☐ REFEE (F)	☐ HOLD (H)	☐ PERMIT REQUIRED	
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071	
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET	
INSPECTOR SIGNATURE	<i>Bob Gates</i>		INSPECTION DATE
3 26 93			
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 AM 7 15 AM OR 2 45 PM 3 00 PM AT			229-6769

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

1	PERMIT NUMBER	93-176567	INSPECTION NUMBER	14
JOB ADDRESS				
3195 ST TROPEZ ST		113189		
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA FINESTRA		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	03/25/93	14:28	03/26/93
INSPECTOR NO	INSPECTOR NAME			
59	BOB GATES			
INSPECTION REQUESTED	SHEAR (109)			

Rej

- Nail P.H.D.

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED
☒ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		
INSPECTOR SIGNATURE		INSPECTION DATE		
 3 26 93				
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 AM 7 15 AM OR 2 45 PM 3 00 PM AT				229-6769

For Additional Assistance Call * 229 6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

X	PERMIT NUMBER	93-176567	INSPECTION NUMBER	29
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO		BLOCK NO	SUBDIVISION NAME	
117		5	VILLA FINESTRA	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	451-6222	03/08/93	14:42	03/09/93
INSPECTOR NO		INSPECTOR NAME		
59		BOB GATES		
INSPECTION REQUESTED		PRE-SLAB (105)		

EARLY A.M.

PROPERTY LINE & SETBACKS VERIFIED BY:

[Signature]

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE		<i>[Signature]</i> 3 9 93		INSPECTION DATE
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6769

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

☒ H	PERMIT NUMBER	93-176567	INSPECTION NUMBER	33
JOB ADDRESS 3105 ST TROPEZ ST 113189				
LOT NO 117		BLOCK NO 5	SUBDIVISION NAME VILLA FINESTRA	
FIRE DEPT MAP NO 2117-17	JOB PHONE 451-6222	CALL IN DATE 03/05/93	CALL IN TIME 14:40	SCHEDULE DATE 03/08/93
INSPECTOR NO 59		INSPECTOR NAME BOB GATES		
INSPECTION REQUESTED		PRE-SLAB (105)		

EARLY A.M.

PROPERTY LINE & SETBACKS VERIFIED BY:

Reg
N/Rdy

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		
INSPECTOR SIGNATURE <i>Bob Gates</i>		INSPECTION DATE 3-8-93		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6769

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

K	PERMIT NUMBER	93-176567	INSPECTION NUMBER	20
JOB ADDRESS				
3105 ST TROPEZ ST			113189	
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA FINESTRA		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2917-17	255-4662	03/04/93	14:42	03/05/93
INSPECTOR NO	INSPECTOR NAME			
59	BOB GATES			
INSPECTION REQUESTED				
UNDERSLAB PLUMBING (407)				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T)	☐ HOLD (H)
☐ REJECTED (R)		REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		
INSPECTOR SIGNATURE	<i>B. Gates</i> 3593		INSPECTION DATE	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6769

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	93-176567	INSPECTION NUMBER	19
JOB ADDRESS				
3105 ST TROPEZ ST			1131 89	
LOT NO		BLOCK NO	SUBDIVISION NAME	
117		5	VILLA FINESTRA	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	255-4662	03/04/93	14:42	03/05/93
INSPECTOR NO		INSPECTOR NAME		
59		BOB GATES		
INSPECTION REQUESTED		BUILDING SEWER (YARD LINE S) (405)		
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T)	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE		<i>[Signature]</i> 3593		INSPECTION DATE
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6769

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

1	PERMIT NUMBER	93-176567	INSPECTION NUMBER	28
JOB ADDRESS				
3905 ST TROPEZ ST			113189	
LOT NO	BLOCK NO	SUBDIVISION NAME		
117	5	VILLA FINESTRA		
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2117-17	225-4662	02/26/93	14:53	03/01/93
INSPECTOR NO	INSPECTOR NAME			
59	BOB GATES			
INSPECTION REQUESTED		FOOTING, LAYOUT, REBAR, ZONING (101)		

PROPERTY LINE & SETBACKS VERIFIED BY:

Bob Smith

W. J. F. N.

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE	<i>Bob Gates 3.1.93</i>			INSPECTION DATE
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6769

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types