

CITY OF LAS VEGAS, NEVADA

PERMIT NO 92-142965

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386 6251FO
44

78563

DEVELOPMENT PERMIT
FOR Swimming Pool or SpaLOG NO & AREA M-2641-R DATE 9-21-92 CONST VAL \$ 5300ADDRESS OF CONSTRUCTION 3005 STERN DR. OWNER MARK MILLER PHONE 2540260CONTRACTOR BLUE BIRD POOLS, INC STATE LICENSE NO 0027119 CITY LICENSE NO 036181LOT(s) 63 BLOCK 3 SUBDIVISION Blue Bird 11C ZONE _____PLUMBING CONTRACTOR BLUE BIRD POOLS, INC ELECTRICAL CONTRACTOR HUDDLESTON ELECTRICCIRCLE TYPE OF POOL THAT APPLIES PRIVATE SEMI PUBLIC PUBLIC SPAMATERIALS OF CONSTRUCTION REINFORCED GUNITE REINFORCED CONCRETE OTHER _____SQUARE FEET OF SURFACE POOL 400 SPA 30 VOLUME IN GALLONS 13300

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way

I state that I am familiar with the effective ordinances of the City of Las Vegas Nevada and the effective Statutes of the State of Nevada covering construction and use of the above type I agree to perform said construction in conformity therewith I further agree that issuance of a permit on the above application will not excuse me from conforming with the said Ordinances and Statutes despite any errors on the part of the building inspector or engineer in checking plans and application herewith

All swimming pools must be fenced before the pool is filled with water No electrical lines shall cross over a pool Applicants must have separate plot plans showing location of power pole proposed or existing fencing and location of swimming pool I agree to repair any utility line if damaged during excavation work I have read and understand the contents of above application I hereby state that the same are true and correct

BLUE BIRD POOLS, INC

SIGNED _____ CONTRACTOR

BY HB Spencer Pres. AGENT/OWNERPLANNING DEPT 4/20-92 DATE

BUILDING DEPT _____ DATE

- 1 Inspections outside of normal business hours = \$30 00 per hour (minimum charge three hours)
- 2 Re Inspection fee during normal business hours assessed under provisions of TABLE 3 A of the Uniform Building Code = \$30 00 each
- 3 Inspections during normal business hours for which no fee is specifically indicated = \$30 00 per hour (minimum charge one half hour)
- 4 Additional plan review required by changes additions or revisions to approved plans = \$30 00 per hour (minimum charge two hour)

DESCRIPTION			FEE	TOTAL
ISSUANCE FEE			10 00	11
SEWER CONNECTION FEE (to 30 000 GALLONS)			60 00	110
BUILDING PERMIT POOL & OR SPA				73
PLUMBING PERMIT	PRIVATE POOL OR SPA	PREFORMED SPA	10 00	
		OTHERWISE	20 00	21
	PUBLIC OR SEMI PUBLIC POOL OR SPA	PREFORMED SPA	20 00	
		OTHERWISE	30 00	04/2
	FUEL PIPING FOR POOL HEATER		6 00	6
ELECTRICAL PERMIT	SPA		8 00	9
	SWIMMING POOL	RESIDENTIAL	20 00	21
		PUBLIC SEMI PUBLIC	30 00	
	ELECTRICAL SERVICE CHANGE		6 00	
MISC				
TOTAL FEES				253.00

RECEIPT

0002

POOL 86 00

SEWR 110 00

FLBG 27 00

ELEC 30 00

CHEK 253 00

4115A000 14 55

04/20/92

MUST BE MACHINE VALIDATED

Permit Expires 180 Days After Abandonment of Work

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386 6251

FOR INSPECTIONS CALL 799 2071

DEVELOPMENT PERMIT
FOR Swimming Pool or Spa

75

LOG NO & AREA M-2641-R DATE 4-21-92 CONST VAL \$ 5300ADDRESS OF CONSTRUCTION 3005 STERN DR. OWNER MARK MILLER PHONE 254-260CONTRACTOR BLUE BIRD POOLS, INC STATE LICENSE NO 0027119 CITY LICENSE NO 036181LOT(s) 63 BLOCK 3 SUBDIVISION Blue Bird 11C ZONEPLUMBING CONTRACTOR BLUE BIRD POOLS, INC ELECTRICAL CONTRACTOR HUDDLESTON ELECTRICCIRCLE TYPE OF POOL THAT APPLIES PRIVATE SEMI PUBLIC PUBLIC SPAMATERIALS OF CONSTRUCTION REINFORCED GUNITE REINFORCED CONCRETE OTHERSQUARE FEET OF SURFACE POOL 400 SPA 30 VOLUME IN GALLONS 13300

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way

I state that I am familiar with the effective ordinances of the City of Las Vegas Nevada and the effective Statutes of the State of Nevada covering construction and use of the above type I agree to perform said construction in conformity therewith I further agree that issuance of a permit on the above application will not excuse me from conforming with the said Ordinances and Statutes despite any errors on the part of the building inspector or engineer in checking plans and application herewith

All swimming pools must be fenced before the pool is filled with water No electrical lines shall cross over a pool Applicants must have separate plot plans showing location of power pole proposed or existing fencing and location of swimming pool I agree to repair any utility line if damaged during excavation work I have read and understand the contents of above application I hereby state that the same are true and correct

SIGNED BLUE BIRD POOLS, INC. CONTRACTOR
BY [Signature] AGENT/OWNER
PLANNING DEPT [Signature] DATE 4/17/92
BUILDING DEPT [Signature] DATE 4-20-92

- 1 Inspections outside of normal business hours = \$30.00 per hour (minimum charge three hours)
- 2 Re Inspection fee during normal business hours assessed under provisions of TABLE 3 A of the Uniform Building Code = \$30.00 each
- 3 Inspections during normal business hours for which no fee is specifically indicated = \$30.00 per hour (minimum charge one half hour)
- 4 Additional plan review required by changes additions or revisions to approved plans = \$30.00 per hour (minimum charge two hours)

DESCRIPTION			FEE	TOTAL
ISSUANCE FEE			10 00	11
SEWER CONNECTION FEE (to 30 000 GALLONS)			60 00	110
BUILDING PERMIT POOL & OR SPA				75
PLUMBING PERMIT	PRIVATE POOL OR SPA	PREFORMED SPA	10 00	
		OTHERWISE	20 00	21
	PUBLIC OR SEMI PUBLIC POOL OR SPA	PREFORMED SPA	20 00	
		OTHERWISE	30 00	04/20/92
	FUEL PIPING FOR POOL HEATER		6 00	6
ELECTRICAL PERMIT	SPA		8 00	797
	SWIMMING POOL	RESIDENTIAL	20 00	21
		PUBLIC SEMI PUBLIC	30 00	
	ELECTRICAL SERVICE CHANGE		6 00	
MISC				
TOTAL FEES				253.00

RECEIPT

000000
FOOL 00 00
SEWER 110 00
PLBG 27 00
ELEC 70 00
CHECK 253 00
4115A000 14 55

MUST BE MACHINE VALIDATED

CITY OF LAS VEGAS, NEVADA

PERMIT NO 90

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386 6251

FOR INSPECTIONS CALL 799 2071

DEVELOPMENT PERMIT

FOR Fence Wall Retaining Wall

LOG NO & AREA

940-012-019
M-3600

DATE

Aug 16 1990

CONST VAL \$

ADDRESS OF
CONSTRUCTION

3005 STERN

OWNER

PAUL ZUGELDEE

PHONE

255-7172

CONTRACTOR

STM CONST

STATE
LICENSE NO

021407

CITY
LICENSE NO

25888

LOT(s)

63

BLOCK

3

SUBDIVISION

BLUES UNIT^H 11-C

ZONE

R-PD6

☐ CONSTRUCTION PLANS SUBMITTED BY OWNER/CONTRACTOR☒ CONSTRUCTION DESIGN BY CITY DESIGN SHEET

ENGINEER

Approval for the work under this permit will be given only after refuse
and debris have been removed from job site and public right of way

	DESCRIPTION	TOTAL LIN FT	TOTAL SQ FT
	CHAIN LINK OR WIRE MESH		
	ORNAMENTAL IRON		
	WOOD		
X	MASONRY 43x6 FT	43	258
Y	RETAINING 43x3 FT + 31	74	222


OTHER INSPECTIONS AND FEES

- 1 Inspections outside of normal business hours = \$30.00 per hour (minimum charge three hours)
- 2 Re inspection fee during normal business hours assessed under provisions of TABLE 3 A of the Uniform Building Code = \$30.00 each
- 3 Inspections during normal business hours for which no fee is specifically indicated = \$30.00 per hour (minimum charge one half hour)
- 4 Additional plan review required by changes additions or revisions at approved plans = \$30.00 per hour (minimum charge two hours)

CONDITIONS OF THE PERMIT

- 1 Any type of retaining wall must be engineered by a Civil or Structural Engineer
- 2 If a home owner takes out the Building Permit and if the owner sublets the work to a Contractor then the Contractor must take out the permit and pay for it
- 3 No fence or wall can be built on City property or rights of way but this is not intended to preclude construction within utility easements if utilities will not be damaged or made inaccessible
- 4 The fence or wall shall not enclose any water meter light standard or fire alarm box and shall not come closer than 24' from the nearest fire hydrant outlet
- 5 Department Inspectors must approve footings before concrete is poured and block wall reinforcing before grouting is done
- 6 Maximum height of any wall or fence is 6' side and rear yards 4' maximum in front yard with the vertical surface above the height of 2' - 50% open
- 7 I must not obstruct required onsite parking space (2 spaces for each dwelling unit) by the erection of this fence or wall
- 8 By the signing of this application I herewith agree to the requirements outlined above

FOR INSPECTIONS CALL 799 2071



RECEIPT

0006

WALL 30 10

CASH 30 10

9987A000 11 02

08/16/90

SIGNED

CONTRACTOR AGENT OWNER

PLANNING DEPT

DATE

I hereby certify that I have reviewed this application and the proposed plans and have found that the proposed development meets the requirements of the City of Las Vegas Flood Hazard Reduction Ordinance for the issuance of this Development Permit

PLAN
REVIEW
FEEPERMIT
FEE 2310 2401TOTAL
FEES

LAND DEVELOPMENT AND FLOOD CONTROL ENGINEER

DATE

BUILDING DEPT

DATE

MUST BE MACHINE VALIDATED

PERMIT EXPIRES 180 DAYS AFTER ABANDONMENT OF WORK

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER	07-142965	INSPECTION NUMBER	9
JOB ADDRESS 3005 STERN DR			
LOT NO	BLOCK NO	SUBDIVISION NAME	
FIRE DEPT MAP NO -	JOB PHONE	CALL IN DATE 04/20/92	CALL IN TIME 16:16
INSPECTOR NO 75		INSPECTOR NAME RON PATTERSON	
INSPECTION REQUESTED	POOL PRE-GUNITE (9P1)		

(Recall for V.G. Electrical when finished)

☒ PARTIAL INSPECTION	☒ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION STEEL & 420 only	
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) UNTIL
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071		☐ HOLD (H)
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE	R. Patterson		INSPECTION DATE 4-21-92
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT			229-67 69

For Additional Assistance Call *229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 3005 Alvin		PERMIT NO. 79124	
LOT NO.	MAP NO. 5-1288p	INSPECTOR 59	DATE 8-29-90
SUBDIVISION NAME			PHONE
INSPECTOR SIGNATURE [Signature]			INSPECTION DATE 8/30/90

Reg

Steel not placed per city design for 3' Retaining

☐ PARTIAL INSPECTION DESCRIPTION

☐ APPROVED

☐ PERMIT REQUIRED

☐ STOP WORK

☒ REJECTED CORRECTION NOTICE REINSPECTION REQUIRED CALL 799 2071

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☒ B 1	FOOTING LAYOUT REBAR ZONING	☐ P 1	ON SITE SEWER	☐ X 2	UNDERGROUND HYDRO
☐ B 2	STEM WALL — FORMS & REBAR	☐ P 2	ON SITE WATER	☐ X 3	UNDERGROUND FINAL/FLOW
☐ B 3	PRE SLAB	☐ P 3	BUILDING SEWER (YARD LINES)	☐ X 4	SPRINKLER SYSTEM HYDRO
☐ B 4	ROOF SHEATHING	☐ P 4	UNDERSLAB PLUMBING	☐ X 5	FIRE ALARM
☐ B 5	FRAMING	☐ P 5	TOP OUT WATER GAS WASTE	☐ X 6	OTHER
☐ B 6	INSULATION	☐ P 6	FINAL GAS TEST	☐ X 7	FINAL FIRE
☐ B 7	DRYWALL NAILING	☐ P 7	FINAL PLUMBING		
☐ B 8	EXTERIOR LATH/STUCCO			☐ E 1	UNDERGROUND ELECTRICAL
☐ B 9	WALL GROUT & STEEL	☐ M 1	ROUGH VENT	☐ E 2	ROUGH ELECTRICAL
☐ B 10	☒ PRE GUNITE	☐ M 2	HOOD	☐ E 3	LOW VOLTAGE ELECTRICAL
☐ B 11	☒ PRE PLASTER / FINAL	☐ M 3	FINAL MECHANICAL	☐ E 4	SIGN INSPECTION
☐ B 12	BUILDING FINAL			☐ E 5	FINAL ELECTRICAL
☐ B 13	CERT OF OCC	☐ X 1	KICKER / FLUSH	☐ E 6	TEMP POWER

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)

FOR ASSISTANCE CALL 386 6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

[illegible]

FOR ASSISTANCE CALL 386-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS <i>5005 Alamo</i>		PERMIT NO <i>19124</i>	
LOT NO <i>9-33</i>	INSPECTOR <i>59</i>	DATE <i>8-31-90</i>	
SUBDIVISION NAME <i>Crystal Bay</i>		PHONE	
INSPECTOR SIGNATURE <i>[Signature]</i>		INSPECTION DATE <i>8/4/0</i>	

☐ PARTIAL INSPECTION DESCRIPTION

☒ **APPROVED**

☐ **PERMIT REQUIRED**

☐ **STOP WORK**

☒ **REJECTED CORRECTION NOTICE REINSPECTION REQUIRED CALL 799 2071**

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B 1	FOOTING LAYOUT REBAR ZONING	☐ P 1	ON SITE SEWER	☐ X 2	UNDERGROUND HYDRO
☐ B 2	STEM WALL - FORMS & REBAR	☐ P 2	ON SITE WATER	☐ X 3	UNDERGROUND FINAL/FLOW
☐ B 3	PRE SLAB	☐ P 3	BUILDING SEWER (YARD LINES)	☐ X 4	SPRINKLER SYSTEM HYDRO
☐ B 4	ROOF SHEATHING	☐ P 4	UNDERSLAB PLUMBING	☐ X 5	FIRE ALARM
☐ B 5	FRAMING	☐ P 5	TOP OUT WATER GAS WASTE	☐ X 6	OTHER
☐ B 6	INSULATION	☐ P 6	FINAL GAS TEST	☐ X 7	FINAL FIRE
☐ B 7	DRYWALL NAILING	☐ P 7	FINAL PLUMBING		
☐ B 8	EXTERIOR LATH/STUCCO			☐ E 1	UNDERGROUND ELECTRICAL
☒ B 9	WALL GROUT & STEEL	☐ M 1	ROUGH VENT	☐ E 2	ROUGH ELECTRICAL
☐ B 10	<u>POOL</u> PRE GUNITE	☐ M 2	HOOD	☐ E 3	LOW VOLTAGE ELECTRICAL
☐ B 11	<u>POOL</u> PRE PLASTER / FINAL	☐ M 3	FINAL MECHANICAL	☐ E 4	SIGN INSPECTION
☐ B 12	BUILDING FINAL			☐ E 5	FINAL ELECTRICAL
☐ B 13	CERT OF OCC	☐ X 1	KICKER / FLUSH	☐ E 6	TEMP POWER

☐ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)

FOR ASSISTANCE CALL 388-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS <i>5005 Keen</i>			PERMIT NO <i>79124</i>
LOT NO	MAP NO <i>10-157p</i>	INSPECTOR <i>59</i>	DATE <i>9-5-90</i>
SUBDIVISION NAME			PHONE
INSPECTOR SIGNATURE <i>B. H. [Signature]</i>			INSPECTION DATE <i>9/6/90</i>

Final grout Apu

☐ PARTIAL INSPECTION DESCRIPTION

☒ **APPROVED**
☐ **PERMIT REQUIRED**
☐ **STOP WORK**

☐ **REJECTED CORRECTION NOTICE REINSPECTION REQUIRED CALL 799 2071**

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B 1	FOOTING LAYOUT REBAR ZONING	☐ P 1	ON SITE SEWER	☐ X 2	UNDERGROUND HYDRO
☐ B 2	STEM WALL - FORMS & REBAR	☐ P 2	ON SITE WATER	☐ X 3	UNDERGROUND FINAL/FLOW
☐ B 3	PRE SLAB	☐ P 3	BUILDING SEWER (YARD LINES)	☐ X 4	SPRINKLER SYSTEM HYDRO
☐ B 4	ROOF SHEATHING	☐ P 4	UNDERSLAB PLUMBING	☐ X 5	FIRE ALARM
☐ B 5	FRAMING	☐ P 5	TOP OUT WATER GAS WASTE	☐ X 6	OTHER
☐ B 6	INSULATION	☐ P 6	FINAL GAS TEST	☐ X 7	FINAL FIRE
☐ B 7	DRYWALL NAILING	☐ P 7	FINAL PLUMBING		
☐ B 8	EXTERIOR LATH/STUCCO			☐ E 1	UNDERGROUND ELETRICAL
☒ B 9	WALL GROUT & STEEL	☐ M 1	ROUGH VENT	☐ E 2	ROUGH ELECTRICAL
☐ B 10	FOOL PRE GUNITE	☐ M 2	HOOD	☐ E 3	LOW VOLTAGE ELECTRICAL
☐ B 11	FOOL PRE PLASTER / FINAL	☐ M 3	FINAL MECHANICAL	☐ E 4	SIGN INSPECTION
☒ B 12	BUILDING FINAL <i>wall</i>			☐ E 5	FINAL ELECTRICAL
☐ B 13	CERT OF OCC	☐ X 1	KICKER / FLUSH	☐ E 6	TEMP POWER

☒ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C O ISSUANCE (Commercial Only)

FOR ASSISTANCE CALL 386 6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	02-142,65	INSPECTION NUMBER	3
JOB ADDRESS 3705 STEPH DR				
LOT NO 63		BLOCK NO 7	SUBDIVISION NAME BLUFFS 11C	
FIRE DEPT MAP NO 2615-68	JOB PHONE 254-0260	CALL IN DATE 05/04/92	CALL IN TIME 11:35	SCHEDULE DATE 05/05/92
INSPECTOR NO 75		INSPECTOR NAME RON PATTERSON		
INSPECTION REQUESTED		POOL PRE-PLASTER/FINAL (917)		

1- No power for lights

2- Ground bus required to have one more ground connection than number of ground conductors

NOTE (OK TO Plaster Pool)

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE		INSPECTION DATE		
R. Patterson		5-5-92		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6769

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	77-142965	INSPECTION NUMBER	2
JOB ADDRESS				
3005 STERN DR				
LOT NO		BLOCK NO	SUBDIVISION NAME	
63		3	BLUFFS 11C	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2615-68	254-0260	05/15/92	10:23	05/18/92
INSPECTOR NO		INSPECTOR NAME		
75		RON PATTERSON		
INSPECTION REQUESTED		POOL PRE-PLASTER/FINAL (910)		
GAS LINE ALSO				
<i>2. tag - 21877</i>				
☐	PARTIAL INSPECTION	☐	PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION
☒	APPROVED (A)	☐	STOP WORK (S)	☐
☐	REJECTED (R)	☐	COMMENTS (C)	☐
☐	REFEE (F)	☐	TEMPORARY APPROVAL (T) - UNTIL	☐
☐	REINSPECTION REQUIRED CALL * 229 2071	☐	HOLD (H)	
☐	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET	☐	PERMIT REQUIRED	
INSPECTOR SIGNATURE		INSPECTION DATE		
<i>R. Patterson</i>		5-18-92		
☐	PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6769

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	92-1429651	INSPECTION NUMBER	2
JOB ADDRESS				
3005 STEPHEN RD				
LOT NO		BLOCK NO	SUBDIVISION NAME	
63		3	BLUES 114	
FIRE DEPT MAP NO	JOB PHONE	CALL IN DATE	CALL IN TIME	SCHEDULE DATE
2445-68	254-0260	05/15/92	10:23	05/18/92
INSPECTOR NO		INSPECTOR NAME		
475		RON PATTERSON		
INSPECTION REQUESTED		POOL PRE-PLASTER/FINAL (910)		
GAS LINE ALSO				
<i>2. top - 21877</i>				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED	
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE	<i>R. Patterson</i>		INSPECTION DATE 5-18-92	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6769

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

☒	PERMIT NUMBER	92-142965	INSPECTION NUMBER	9
JOB ADDRESS 3005 STERN DR				
LOT NO 63		BLOCK NO 3	SUBDIVISION NAME BLUFFS 11C	
FIRE DEPT MAP NO 2615-68	JOB PHONE 254-0260	CALL IN DATE 05/11/92	CALL IN TIME 13:13	SCHEDULE DATE 05/12/92
INSPECTOR NO 75		INSPECTOR NAME RON PATTERSON		
INSPECTION REQUESTED		POOL PRE-PLASTER/FINAL (910)		

WITH GAS INSPECTION

② Secure conduit within 12' of box
Gas line not pumped up

③ Ground buss in junction box must
have one more terminal screw than
number of ground conductors

(1 Conductor per screw)

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE <i>R. Patterson</i>		INSPECTION DATE <i>5-12-92</i>		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C OF O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6769

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER	02-142965	INSPECTION NUMBER	3
JOB ADDRESS 3005 STERN DR			
LOT NO 63	BLOCK NO 3	SUBDIVISION NAME BLUFFS 11C	
FIRE DEPT MAP NO 2615-68	JOB PHONE 254-0260	CALL IN DATE 05/04/92	CALL IN TIME 11:35
INSPECTOR NO 75		INSPECTOR NAME RON PATTERSON	
INSPECTION REQUESTED POOL PRE-PLASTER/FINAL (910)			

1. No power for lights
2. Ground bars required to have one more ground connection
This number of ground conductors

NOTE (OK TO Plaster Pool)

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE R. Patterson		INSPECTION DATE 5-5-92		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-6769

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

1	PERMIT NUMBER	02-142965	INSPECTION NUMBER	9
JOB ADDRESS 3005 STERN DR				
LOT NO		BLOCK NO	SUBDIVISION NAME	
FIRE DEPT MAP NO -	JOB PHONE	CALL IN DATE 04/20/92	CALL IN TIME 16:16	SCHEDULE DATE 04/21/92
INSPECTOR NO 75		INSPECTOR NAME RON PATTERSON		
INSPECTION REQUESTED		POOL PRE-GUNITES (901)		

(Recall for U.G. Electrical when finished)

☒ PARTIAL INSPECTION	☒ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION STEEL P 420 only		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T)	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE		INSPECTION DATE		
<i>R. Patterson</i>		4-21-92		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-67 69

For Additional Assistance Call * 229-6251 See Reverse Side For Inspection Types

☒	PERMIT NUMBER	92-142965	INSPECTION NUMBER	9
JOB ADDRESS 3005 STERN DR				
LOT NO 63		BLOCK NO 3	SUBDIVISION NAME BLUFFS 11C	
FIRE DEPT MAP NO 2615-68	JOB PHONE 254-0260	CALL IN DATE 05/11/92	CALL IN TIME 13:13	SCHEDULE DATE 05/12/92
INSPECTOR NO 75		INSPECTOR NAME RON PATTERSON		
INSPECTION REQUESTED		POOL PRE-PLASTER/FINAL (910)		

WITH GAS INSPECTION

② Secure conduit within 12" of box
Gas line not pumped up.

③ Ground buss in junction box must
have one more terminal screw than
number of ground conductors

(1-Conductor per screw)

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED CALL *229 2071		☐ PERMIT REQUIRED	
☐ REFEE (F)	REINSPECTION FEE REQUIRED PAY AT CITY HALL 3RD FLOOR 400 E STEWART STREET			
INSPECTOR SIGNATURE <i>R. Patterson</i>		INSPECTION DATE <i>5-12-92</i>		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION YOU MAY CALL THE INSPECTOR FROM 7 00 A M 7 15 A M OR 2 45 P M 3 00 P M AT				229-5769