

**CITY OF LAS VEGAS
DIVISION OF FIRE SERVICES**

213619-4

1:00^{pm} main entrance new tower

JOB ADDRESS <i>2411 W. Sahara</i>		PERMIT NO. <i>90-A 2541</i>
LOT NO.	MAP NO. <i>13-201P</i>	INSPECTOR
PROJECT NAME <i>Palace Station</i>		DATE <i>11-20-90</i>
INSPECTOR'S SIGNATURE <i>Joe Forwards</i>		PHONE <i>737-1055</i>
		INSPECTION DATE <i>11/21/90</i>

porta cachere (Overhang by Main Entrance)

Did overhead inspection of overhang and hydrostatic test. Hydrostatic test pressure 225 psi.

Hangers, spacing and piping appears to be correct. All installed per plans.

Approved this area this date

- | | | |
|---|---|--|
| <input type="checkbox"/> PARTIAL APPROVAL | <input type="checkbox"/> REJECTED-REINSPECTION REQUIRED | <input type="checkbox"/> FINAL APPROVAL |
| <input type="checkbox"/> TEMPORARY APPROVAL | | <input type="checkbox"/> STOP ORDER |
| <input type="checkbox"/> X-1 UNDER/ABOVEGROUND TANK | <input type="checkbox"/> X-5 FIRE ALARM SYSTEM | <input type="checkbox"/> X-8 EXTINGUISHING SYSTEM |
| <input type="checkbox"/> X-2 HOOD SYSTEM | <input type="checkbox"/> X-6 OTHER | <input type="checkbox"/> X-9 MEDICAL GAS |
| <input type="checkbox"/> X-3 UNDERGROUND FINAL/FLOW | <input type="checkbox"/> X-7 FINAL FIRE | <input type="checkbox"/> X-10 LPG |
| <input checked="" type="checkbox"/> X-4 SPRINKLER SYSTEM/OVERHEAD HYDRO | | <input type="checkbox"/> X-11 SUPERVISION/MONITORING |

FOR INSPECTIONS CALL: 799-2071 FOR FURTHER INFORMATION CALL: 383-2888