

700c workroom
711, 713, 715

CITY OF LAS VEGAS
DIVISION OF FIRE SERVICES

JOB ADDRESS 2301 N. Tenaya		PERMIT NO. 90081624
LOT NO. 1	MAP NO. 81145A	INSPECTOR Lisa Indist
PROJECT NAME Memorial High School		DATE 7-12-91
INSPECTOR'S SIGNATURE		PHONE 453-5900
		INSPECTION DATE

fire alarm test please call 2 hrs prior AM
1:30
Monday

Area 700 (Library)

- 1) 700c (workroom) D.B. level below 80 (74 on meter)
- 2) Rooms 711, 713, 715 - D.B. level below 80 (74 avg)

Area 800

- 1) Decibel level below 80 in the two rooms located in 2nd floor office area.

All speakers, pulls functional.
"troubles" - OK

☐ PARTIAL APPROVAL	☒ REJECTED-REINSPECTION REQUIRED	☐ FINAL APPROVAL
☐ TEMPORARY APPROVAL		☐ STOP ORDER
☐ X-1 UNDER/ABOVEGROUND TANK	☒ X-5 FIRE ALARM SYSTEM	☐ X-8 EXTINGUISHING SYSTEM
☐ X-2 HOOD SYSTEM	☐ X-6 OTHER	☐ X-9 MEDICAL GAS
☐ X-3 UNDERGROUND FINAL/FLOW	☐ X-7 FINAL FIRE	☐ X-10 LPG
☐ X-4 SPRINKLER SYSTEM/OVERHEAD HYDRO		☐ X-11 SUPERVISION/MONITORING

FOR INSPECTIONS CALL: 799-2071 FOR FURTHER INFORMATION CALL: 383-2888

