

CITY OF LAS VEGAS
DIVISION OF FIRE SERVICES

Dow Underpinning
Sumner
799-3916

JOB ADDRESS 2300 N. TENAYA		PERMIT NO.	
LOT NO.	MAP NO.	INSPECTOR LAZONBY	DATE 11-6-90
PROJECT NAME Memorial High School		PHONE	
INSPECTOR'S SIGNATURE <i>Rich Lazonby</i>		INSPECTION DATE 11-6-90	

Spkls overhead/hydro

1) *Sup #100*

2) *" " anti-freeze*

a) add head behind decorative wall in reception area

2) *Sup #200*

a) Provide sprinkler coverage in S.W. stairwell

b) Relocate heads in classrooms (S.E. area) as discussed - to be centered in ceiling tile.

3) *anti-freeze system (#100)*

OK

4) *Sup #300*

a) add heads in West corridor, no corridor protection required.

b) add heads to provide sprinkler coverage in N/E stairwell

<input checked="" type="checkbox"/> PARTIAL APPROVAL	<input type="checkbox"/> REJECTED-REINSPECTION REQUIRED	<input type="checkbox"/> FINAL APPROVAL
<input type="checkbox"/> TEMPORARY APPROVAL		<input type="checkbox"/> STOP ORDER
<input type="checkbox"/> X-1 UNDER/ABOVEGROUND TANK	<input type="checkbox"/> X-5 FIRE ALARM SYSTEM	<input type="checkbox"/> X-8 EXTINGUISHING SYSTEM
<input type="checkbox"/> X-2 HOOD SYSTEM	<input type="checkbox"/> X-6 OTHER	<input type="checkbox"/> X-9 MEDICAL GAS
<input type="checkbox"/> X-3 UNDERGROUND FINAL/FLOW	<input type="checkbox"/> X-7 FINAL FIRE	<input type="checkbox"/> X-10 LPG
<input checked="" type="checkbox"/> X-4 SPRINKLER SYSTEM/OVERHEAD HYDRO		<input type="checkbox"/> X-11 SUPERVISION/MONITORING

FOR INSPECTIONS CALL: 799-2071 FOR FURTHER INFORMATION CALL: 383-2888