

INSTALLATION CARD

JOB ADDRESS:

8029 SHORECREST DR.
L.V. NEV.

**MAGNAWALL 1-KOTE
REINFORCED STUCCO SYSTEM**

1-KOTE STUCCO PRODUCTS

ICBO Evaluation Service, Inc. Report No. 4776

Date of Job Completion: 3-17-92

PLASTERING CONTRACTOR:

Name: BELAIR PLASTERING

Address: 706 S. K. PLACK

**Approved Contractor Number as Issued by
the Plastering Manufacturing** 001

Phone: 1-565-6462

This is to certify that the plastering system on the building exterior at the above address has been installed in accordance with the evaluation report specified above and the manufacturer's instructions.

M. J. Hayes
Signature of authorized representative of plastering contractor

3-17-92
Date

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

1	PERMIT NUMBER	91-128768	INSPECTION NUMBER	7
JOB ADDRESS 8029 SHORECREST DR				
LOT NO. 23		BLOCK NO. 2		SUBDIVISION NAME LAKE SHORE
FIRE DEPT. MAP NO. 2117-56	JOB PHONE 451-9154	CALL-IN DATE 03/16/92	CALL-IN TIME 17:13	SCHEDULE DATE 03/17/92
INSPECTOR NO. 50		INSPECTOR NAME JEFF KLEITZ		
INSPECTION REQUESTED		EXTERIOR LATH/STUCCO (129)		
--- MAGNAWALL ONE COAT				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) -- UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL *229-2071		☐ PERMIT REQUIRED	
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE				INSPECTION DATE 3-17-92
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

1	PERMIT NUMBER	91-128762	INSPECTION NUMBER	13
JOB ADDRESS				
8029 SHORECREST DR				
LOT NO.		BLOCK NO		SUBDIVISION NAME
23		2		LAKESHORE
FIRE DEPT MAP NO.	JOB PHONE	CALL-IN DATE	CALL-IN TIME	SCHEDULE DATE
2117-56	361-8808	06/18/92	12:09	06/19/92
INSPECTOR NO		INSPECTOR NAME		
59		BOB GATES		
INSPECTION REQUESTED		BUILDING FINAL (140)		
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☒ APPROVED (A)		☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) -- UNTIL
☐ REJECTED (R)		☐ REINSPECTION REQUIRED - CALL *229-2071		☐ HOLD (H)
☐ REFEE (F)		☐ REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE			INSPECTION DATE	
<i>[Signature]</i>			6/19/92	
☒ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769

For Additional Assistance Call *229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	91-128768	INSPECTION NUMBER	13
JOB ADDRESS 8029 SHORECREST DR				
LOT NO. 23		BLOCK NO. 2	SUBDIVISION NAME LAKE SHORE	
FIRE DEPT MAP NO. 2117-56	JOB PHONE 451-9154	CALL-IN DATE 03/05/92	CALL-IN TIME 14:06	SCHEDULE DATE 03/06/92
INSPECTOR NO. 50		INSPECTOR NAME JEFF KLEITZ		
INSPECTION REQUESTED		DRYWALL NAILING (125)		

INSTALL 1 HOUR RATED ACCESS
IN GARAGE

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) -- UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL *229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE <i>Jeff Kleitz</i>		INSPECTION DATE 3-6-92		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS


☒	PERMIT NUMBER	91-128768	INSPECTION NUMBER	14
JOB ADDRESS 8029 SHORECREST DR				
LOT NO. 23		BLOCK NO 2		SUBDIVISION NAME LAKE SHORE
FIRE DEPT. MAP NO. 2117-56	JOB PHONE 451-9154	CALL-IN DATE 03/05/92	CALL-IN TIME 14:07	SCHEDULE DATE 03/06/92
INSPECTOR NO. 50		INSPECTOR NAME JEFF KLEITZ		
INSPECTION REQUESTED		EXTERIOR LATH/STUCCO (129)		
— VERTICAL BUTT JOINTS ARE TO BE A MINIMUM 16" APART (NO RAILROADING) — BEL-AIR IS NOT AN APPROVED APPLICATION OF MAGNAWALL				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED - CALL *229-2071		
☐ REFEE (F)		REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE		INSPECTION DATE 3-6-92		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769

For Additional Assistance Call *229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER	91-123763	INSPECTION NUMBER	3
JOB ADDRESS 8029 SHORECREST DR			
LOT NO. 23	BLOCK NO. 2	SUBDIVISION NAME LAKE SHORE	
FIRE DEPT MAP NO. 2117-56	JOB PHONE 451-9154	CALL-IN DATE 02/28/92	CALL-IN TIME 10:58
INSPECTOR NO. 50		INSPECTOR NAME JEFF KLEITZ	
INSPECTION REQUESTED		FRAMING (120)	

— FRAMING FIX REQUIRED

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION	
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL *229-2071		☐ HOLD (H)
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE			INSPECTION DATE 3-2-92
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT			229-6769

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER		91-128768		☒ INSPECTION NUMBER		4	
JOB ADDRESS 8029 SHORECREST DR							
LOT NO. 23		BLOCK NO. 2		SUBDIVISION NAME LAKE SHORE			
FIRE DEPT. MAP NO. 2117-56		JOB PHONE 451-9154		CALL-IN DATE 02/28/92		CALL-IN TIME 11:00	
SCHEDULE DATE 03/02/92							
INSPECTOR NO. 50		INSPECTOR NAME JEFF KLEITZ					
☒ INSPECTION REQUESTED		SHEAR (109)					
— FIX FOR HDSAS RECEIVED							
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION			
☒ APPROVED (A)		☐ STOP WORK (S)		☐ COMMENTS (C)		☐ TEMPORARY APPROVAL (T) — UNTIL	
☐ REJECTED (R)		☐ REFEED (F)		☐ HOLD (H)			
		REINSPECTION REQUIRED - CALL * 229-2071				☐ PERMIT REQUIRED	
		REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.					
☒ INSPECTOR SIGNATURE						INSPECTION DATE 3-2-92	
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)					
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT							229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	91-128768	INSPECTION NUMBER	8
JOB ADDRESS 8029 SHORECREST DR				
LOT NO 23		BLOCK NO. 2	SUBDIVISION NAME LAKESHORE	
FIRE DEPT MAP NO. 2117-56	JOB PHONE 451-9154	CALL-IN DATE 02/27/92	CALL-IN TIME 15:46	SCHEDULE DATE 02/28/92
INSPECTOR NO 50		INSPECTOR NAME JEFF KLEITZ		
INSPECTION REQUESTED		INSULATION (123)		

— CITY ORDINANCE REQUIRES A 6'
PERIMETER OF BATTIS IN ATTIC
WHEN A GAS FIRED UNIT IS USED

— GAS PIPING FOR ATTIC UNIT DOES
NOT PENETRATE THRU PLY PLATFORM
FOR INSTALLATION


☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED - CALL *229-2071		☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE		INSPECTION DATE 2-28-92		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER	91-128768	INSPECTION NUMBER	7
JOB ADDRESS 8029 SHORECREST DR			
LOT NO 23	BLOCK NO. 2	SUBDIVISION NAME LAKE SHORE	
FIRE DEPT. MAP NO 2117-56	JOB PHONE 451-9154	CALL-IN DATE 02/27/92	CALL-IN TIME 15:46
SCHEDULE DATE 02/28/92			
INSPECTOR NO. 50	INSPECTOR NAME JEFF KLEITZ		
INSPECTION REQUESTED	FRAMING (120)		

— SEE LIST OF 2-25-92


☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION	
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL
☒ REJECTED (R)	REINSPECTION REQUIRED - CALL *229-2071		☐ HOLD (H)
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE			INSPECTION DATE 2-28-92
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT			229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

7	PERMIT NUMBER	91-128768	INSPECTION NUMBER	6
JOB ADDRESS				
8029 SHORECREST DR				
LOT NO.		BLOCK NO		SUBDIVISION NAME
23		2		LAKE SHORE
FIRE DEPT. MAP NO.	JOB PHONE	CALL-IN DATE	CALL-IN TIME	SCHEDULE DATE
2117-56	451-9154	02/27/92	15:46	02/28/92
INSPECTOR NO.		INSPECTOR NAME		
50		JEFF KLEITZ		
INSPECTION REQUESTED		SHEAR (109)		

— NO ENGINEERED FIX FOR HDSS ON-SITE

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE		INSPECTION DATE		
		2-28-92		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769


For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

X	PERMIT NUMBER	91-128768	INSPECTION NUMBER	10
JOB ADDRESS 8029 SHORECREST DR				
LOT NO. 23		BLOCK NO. 2		SUBDIVISION NAME LAKE SHORE
FIRE DEPT. MAP NO. 2117-56	JOB PHONE 451-9154	CALL-IN DATE 02/24/92	CALL-IN TIME 15:35	SCHEDULE DATE 02/25/92
INSPECTOR NO. 50		INSPECTOR NAME JEFF KLEITZ		
INSPECTION REQUESTED		FRAMING (120)		

A.M.

- INSTALL 6XB & 6X6 HEADERS AS PER PLANS IN GARAGE
- INSTALL DRAFT STOPS AS PER PLANS
- INSTALL STUD SHOTS ON PLUMBING WALL TO GARAGE WALL IS TO BE 2X6
- DOUBLE FIRESTOPS IN FAMILY & M BED FIREPLACE
- INSTALL UPSTAIRS W/ BED PORCH COLUMNS
- RETAIL SHEAR & FRAME
- OIL TO INSULATE

☐ PARTIAL INSPECTION	☒ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION SEE ABOVE		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE 		INSPECTION DATE 2-25-92		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	91-128768	INSPECTION NUMBER	3
JOB ADDRESS 8029 SHORECREST DR				
LOT NO. 23		BLOCK NO. 2	SUBDIVISION NAME LAKE SHORE	
FIRE DEPT. MAP NO. 2117-56	JOB PHONE 451-9154	CALL-IN DATE 02/19/92	CALL-IN TIME 06:55	SCHEDULE DATE 02/20/92
INSPECTOR NO. 50		INSPECTOR NAME JEFF KLEITZ		
INSPECTION REQUESTED		FRAMING (120)		

PAGE 1 OF 2


A.M.

- GARAGE WINDOW HEADER IS TO BE 6"x8" AS PER PLANS, SOUTH DOOR HEADER IS TO BE 6"x6" AS PER PLANS
- INSTALL DRAFT STOPS AS PER PLANS
- A FIRE RATED DOOR WILL BE REQUIRED FOR ACCESS TO FAU IN GARAGE TRUSSES
- INSTALL FIRESTOPS AT ALL CONCEALED HORIZONTAL & VERTICAL CHASES; GARAGE POP-OUTS, LIVING ROOM POP-OUTS
- VACUUM CLEANED METAL SLEEVES ARE TO PENETRATE AT SHEETROCK
- 2x4 ~~STUDS~~ STUDS IN PLUMBING WALLS ARE OVERBUILT; PLANS CALL FOR 2x6 WALL
- FIREBLOCK DROP IN LAUNDRY ROOM
- INSTALL STG224 AT 4x12 HEADER AS PER PLANS
- FIRESTOPS ARE TO BE 3/4" PLY ON 5/8" TYPE-X DRYWALL (FAMILY ROOM FIREPLACE, MBR FIREPLACE)
- STRAP 6x16 GLULAM AT STAIRS TO 4x4 POSTS

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED - CALL *229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE			INSPECTION DATE 2-20-92	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. OF ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER	91-128768		☒ INSPECTION NUMBER	11	
JOB ADDRESS 8029 SHORECREST DR					
LOT NO 23		BLOCK NO 2		SUBDIVISION NAME LAKESHORE	
FIRE DEPT. MAP NO. 2117-56		JOB PHONE 451-9154		CALL-IN DATE 02/19/92	CALL-IN TIME 13:46
SCHEDULE DATE 02/20/92					
INSPECTOR NO. 50		INSPECTOR NAME JEFF KLEITZ			
☒ INSPECTION REQUESTED		FRAMING (120)			
A.M. — SEE LIST ON INSPECTION NUMBERS 3 & 10					
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION	
☐ APPROVED (A)		☐ STOP WORK (S)		☐ COMMENTS (C)	
☐ TEMPORARY APPROVAL (T)		— UNTIL		☐ HOLD (H)	
☒ REJECTED (R)		REINSPECTION REQUIRED - CALL * 229-2071			
☐ REFEE (F)		REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
☐ PERMIT REQUIRED					
INSPECTOR SIGNATURE 		INSPECTION DATE 2-20-92			
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT					 229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	91-128768		INSPECTION NUMBER	10
JOB ADDRESS 8029 SHORECREST DR					
LOT NO. 23		BLOCK NO 2		SUBDIVISION NAME LAKESHORE	
FIRE DEPT. MAP NO. 2117-56		JOB PHONE 451-9154		CALL-IN DATE 02/19/92	CALL-IN TIME 13:44
INSPECTOR NO. 50		INSPECTOR NAME JEFF KLEITZ			
INSPECTION REQUESTED		FRAMING (120)			

PAGE 2 of 2

A.M.

- INSTALL DOUBLE TOP PLATE AT BALCONY FRAME AT ENTRY
- STRAP 4x12 HEADER AT ENTRY INTO M/BED
- FIX BACKLAP OF LAVATORY DRAIN IN M/BATH; REPAIR VENT AT LAV. ALSO
- INSTALL 4x6 HEADER AT M/BATH DOOR 4x4 AT M/BED DOOR, UPSTAIRS BATH DOOR AND BEDROOM DOOR AS PER PLANS
- INSTALL POINT LOAD FOR 6x12 HEADERS AT TOP OF STAIRS
- ATTIC ACCESS FOR UPSTAIRS FAN IS TO HAVE CLEAR ACCESS, NO WIRES IN WAY
- INSTALL 1/2" DRYWALL EACH SIDE OF TRUSS W/ 5d COOLER NAILS 4" O.C. AS PER PLANS UPSTAIRS.
- INSTALL COLUMNS ON UPSTAIRS M/BED PORCH

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION			
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T)	— UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED - CALL *229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE		INSPECTION DATE			
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT					229-6769


For Additional Assistance Call *229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER	91-128768	INSPECTION NUMBER	2
JOB ADDRESS 8029 SHORECREST DR			
LOT NO. 23	BLOCK NO. 2	SUBDIVISION NAME LAKESHORE	
FIRE DEPT. MAP NO. 2117-56	JOB PHONE 451-9154	CALL-IN DATE 02/19/92	CALL-IN TIME 06:55
SCHEDULE DATE 02/20/92			
INSPECTOR NO. 50	INSPECTOR NAME JEFF KLEITZ		
INSPECTION REQUESTED	SHEAR (109)		

— ENGINEERING DOES NOT GIVE FIX
FOR HD 5; ONLY HD2 ~~FIX~~ IS
GIVEN

— HOLES DRILLED TO 10"

☐ PARTIAL INSPECTION	☒ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION SEE ABOVE	
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL *229-2071		☐ HOLD (H)
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE	INSPECTION DATE		
	2-20-92		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT			 229-6769

For Additional Assistance Call *229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER	91-128768	INSPECTION NUMBER	1
---	-----------	-------------------	---

JOB ADDRESS

8029 SHORECREST DR

LOT NO 23	BLOCK NO. 2	SUBDIVISION NAME LAKESHORE	
--------------	----------------	-------------------------------	--

FIRE DEPT MAP NO 2117-56	JOB PHONE 451-9154	CALL-IN DATE 02/19/92	CALL-IN TIME 06:54	SCHEDULE DATE 02/20/92
-----------------------------	-----------------------	--------------------------	-----------------------	---------------------------

INSPECTOR NO. 50	INSPECTOR NAME JEFF KLEITZ
---------------------	-------------------------------

INSPECTION REQUESTED	ROOF SHEATHING (107)
----------------------	----------------------

— PREVIOUSLY APPROVED ON 2-19-92

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)

☐ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071	☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.	

INSPECTOR SIGNATURE	INSPECTION DATE
---------------------	-----------------

Jeff Kleitz 2-20-92


☐ PROJECT COMPLETE	BUILDING CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)
---	---

IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT

229-6769


For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	91-128768	INSPECTION NUMBER	2
JOB ADDRESS				
8029 SHORECREST DR				
LOT NO		BLOCK NO.		SUBDIVISION NAME
23		2		LAKE SHORE
FIRE DEPT. MAP NO.	JOB PHONE	CALL-IN DATE	CALL-IN TIME	SCHEDULE DATE
2117-56	451-9154	02/18/92	07:31	02/19/92
INSPECTOR NO.		INSPECTOR NAME		
50		JEFF KLEITZ		
INSPECTION REQUESTED		SHEAR (109)		
— 10" DEPTH FOR HD FIX; PROVIDE COPY OF ENGINEER'S FIX — CLARIFY SHEAR TRANSFER				
☐ PARTIAL INSPECTION		☒ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
				SEE ABOVE
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE		INSPECTION DATE		
		2-19-92		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7 15 A.M. OR 2 45 P.M. - 3:00 P.M. AT				229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	91-128768	INSPECTION NUMBER	1
JOB ADDRESS				
3029 SHORECREST DR				
LOT NO.		BLOCK NO.	SUBDIVISION NAME	
23		2	LAKESHORE	
FIRE DEPT. MAP NO.	JOB PHONE	CALL-IN DATE	CALL-IN TIME	SCHEDULE DATE
2117-56	451-9154	02/18/92	07:31	02/19/92
INSPECTOR NO.		INSPECTOR NAME		
50		JEFF KLEITZ		
INSPECTION REQUESTED		ROOF SHEATHING (107)		
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL *229-2071		☐ PERMIT REQUIRED	
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE		INSPECTION DATE		
		2-19-92		
		☐ PROJECT COMPLETE		
BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)				
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	91-128768	INSPECTION NUMBER	13
JOB ADDRESS 8029 SHORECREST DR				
LOT NO 23		BLOCK NO. 2	SUBDIVISION NAME LAKESHORE	
FIRE DEPT MAP NO. 2117-56	JOB PHONE 451-9154	CALL-IN DATE 02/14/92	CALL-IN TIME 16:52	SCHEDULE DATE 02/18/92
INSPECTOR NO 71		INSPECTOR NAME KEEFE BEYER		
INSPECTION REQUESTED		ROUGH ELECTRICAL (220)		

ADD HALL LITE SW 2ND FL
 RELOCATE HALL LITE SW 2ND FL.
 ADD SW FOR 1ST FL. BRD RM. HALL LITE
 CAN ON INTERCOMREQ. IN GARAGE

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL *229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE		INSPECTION DATE		
		18 FEB 92		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769

For Additional Assistance Call *229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS


☒	PERMIT NUMBER	91-128768	INSPECTION NUMBER	12
JOB ADDRESS				
8029 SHORECREST DR				
LOT NO. 23		BLOCK NO. 2		SUBDIVISION NAME LAKESHORE
FIRE DEPT. MAP NO. 2117-56	JOB PHONE 451-9154	CALL-IN DATE 02/13/92	CALL-IN TIME 15:58	SCHEDULE DATE 02/14/92
INSPECTOR NO. 83		INSPECTOR NAME JOHN LASKY		
INSPECTION REQUESTED		ROUGH MECHANICAL (320)		

1. One Hour fire rated
self closing access Door
required to service A/C
in garage

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL *229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E STEWART STREET.			
INSPECTOR SIGNATURE		 		INSPECTION DATE 2-14-92
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6765

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	91-128763	INSPECTION NUMBER	11
JOB ADDRESS				
8029 SHORECREST DR				
LOT NO		BLOCK NO.	SUBDIVISION NAME	
23		2	LAKE SHORE	
FIRE DEPT MAP NO.	JOB PHONE	CALL-IN DATE	CALL-IN TIME	SCHEDULE DATE
2117-56	451-9154	02/13/92	15:57	02/14/92
INSPECTOR NO		INSPECTOR NAME		
83		JOHN LASKY		
INSPECTION REQUESTED		TOP OUT-WATER, GAS, WASTE (420)		
1. Back-fill tub traps and pour light weight concrete mix				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) -- UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E STEWART STREET.			
INSPECTOR SIGNATURE			INSPECTION DATE	
			2-14-92	
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6765

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	91-128768	INSPECTION NUMBER	8
JOB ADDRESS				
8029 SHORECREST DR				
LOT NO.		BLOCK NO.		SUBDIVISION NAME
23		2		LAKESHORE
FIRE DEPT MAP NO	JOB PHONE	CALL-IN DATE	CALL-IN TIME	SCHEDULE DATE
2117-56	451-9154	02/13/92	15:57	02/14/92
INSPECTOR NO		INSPECTOR NAME		
at 72		KEEFE BEYER		
INSPECTION REQUESTED				
ROUGH ELECTRICAL (220)				
add Recept in Kitchen Switch Circuits to have only 4 Recept per circuit jacuzzi not wired lights over jacuzzi to be GFI protected				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED - CALL *229-2071		
☐ REFEE (F)		REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE			INSPECTION DATE	
Robert Smith			2-14-92	
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	91-128768	INSPECTION NUMBER	11
-------------------------------------	------------------	-----------	----------------------	----

JOB ADDRESS

8029 SHORECREST DR

LOT NO. 23	BLOCK NO. 2	SUBDIVISION NAME LAKESHORE		
---------------	----------------	-------------------------------	--	--

FIRE DEPT. MAP NO. 2117-56	JOB PHONE 451-9154	CALL-IN DATE 02/13/92	CALL-IN TIME 15:57	SCHEDULE DATE 02/14/92
-------------------------------	-----------------------	--------------------------	-----------------------	---------------------------

INSPECTOR NO. 50	INSPECTOR NAME JEFF KLEITZ
---------------------	-------------------------------

INSPECTION REQUESTED	INSULATION (123)
-------------------------	------------------

UPSTAIRS NORTH BEDROOM INSULATION
INSTALLED BEHIND PLY SHEAR PRIOR
TO LATH

☒ PARTIAL INSPECTION	☒ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION SEE ABOVE
---	---	----------------------------------

☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
--	---	--	--	--------------------------------------

☐ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071	☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.	

INSPECTOR SIGNATURE		INSPECTION DATE 2-14-92
------------------------	---	----------------------------

☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)
--	---

IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY
CALL THE INSPECTOR FROM 7 00 A.M. - 7:15 A.M. OR 2 45 P.M. - 3:00 P.M. AT

229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER	91-128768	INSPECTION NUMBER	6
JOB ADDRESS 8029 SHORECREST DR			
LOT NO 23	BLOCK NO. 2	SUBDIVISION NAME LAKE SHORE	
FIRE DEPT. MAP NO. 2117-56	JOB PHONE 451-9154	CALL-IN DATE 02/12/92	CALL-IN TIME 15:22
SCHEDULE DATE 02/13/92			
INSPECTOR NO. 50	INSPECTOR NAME JEFF KLEITZ		
INSPECTION REQUESTED INSULATION (123)			

P.M.


— NO INSULATION INSTALLED AT
UPSTAIRS NORTH WALL PRIOR TO
LATH

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION	
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL
☒ REJECTED (R)	REINSPECTION REQUIRED - CALL *799-2071		☐ HOLD (H)
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE <i>Jeff Kleitz</i>	INSPECTION DATE 2-13-92		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. OF O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT			229-6769

FOR ADDITIONAL ASSISTANCE CALL *386-6251
SEE REVERSE SIDE FOR INSPECTION TYPES


* EFFECTIVE JULY 1, 1991
PHONE PREFIX WILL BE 229.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

	PERMIT NUMBER	91-128768	INSPECTION NUMBER	18
JOB ADDRESS 8029 SHORECREST DR				
LOT NO. 23		BLOCK NO. 2		SUBDIVISION NAME LAKESHORE
FIRE DEPT. MAP NO 2117-56	JOB PHONE 451-9154	CALL-IN DATE 02/04/92	CALL-IN TIME 16:23	SCHEDULE DATE 02/05/92
INSPECTOR NO 50		INSPECTOR NAME JEFF KLEITZ		
INSPECTION REQUESTED		ROOF SHEATHING (107)		
— INSTALL HANGERS ON TRUSSES IN DINING RM. — SINGLE TOP PLATE REQUIRED UNDER FLOOR TRUSSES NOT DESIGNED AS A BEARING POINT — INSTALL BEARING POINT FOR FLOOR TRUSSES UNDER STAIRS — DBL TOP PLATE AT SOUTH DINING RM REQUIRED — O.K. TO DRY IN & LOAD				
☐ PARTIAL INSPECTION		☒ PARTIAL APPROVAL (P) SEE ABOVE		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)		REINSPECTION REQUIRED - CALL * 229-2071		☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.		
INSPECTOR SIGNATURE				INSPECTION DATE 2-5-92
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769


For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☐	PERMIT NUMBER	91-128768	INSPECTION NUMBER	19
JOB ADDRESS				
8029 SHORECREST DR				
LOT NO		BLOCK NO		SUBDIVISION NAME
23		2		LAKESHORE
FIRE DEPT MAP NO	JOB PHONE	CALL-IN DATE	CALL-IN TIME	SCHEDULE DATE
2117-56	451-9154	02/04/92	16:23	02/05/92
INSPECTOR NO		INSPECTOR NAME		
50		JEFF KLEITZ		
INSPECTION REQUESTED		SHEAR (109)		
A.M. — EXTERIOR SHEAR COMPLETE; O.K. TO LATH				
☐ PARTIAL INSPECTION		☒ PARTIAL APPROVAL (P) PARTIAL DESCRIPTION SEE ABOVE		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE		INSPECTION DATE		
		2-5-92		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M OR 2:45 P.M - 3:00 P.M AT				229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	91-128768	INSPECTION NUMBER	21
JOB ADDRESS 8029 SHORECREST DR				
LOT NO. 23		BLOCK NO. 2		SUBDIVISION NAME LAKE SHORE
FIRE DEPT MAP NO 2117-56		JOB PHONE 451-9154		CALL-IN DATE 01/28/92 CALL-IN TIME 16:26
INSPECTOR NO 50		INSPECTOR NAME JEFF KLEITZ		
INSPECTION REQUESTED		ROOF SHEATHING (107)		
— COMPLETE BOUNDARY NAILING — NAILING OF PLY ROOF IS 6" EDGES 12" IN FIELD — ROOF SHEATHED WITH APA FLOOR SHEATHING PLANS CALL FOR 5/8" CDX — PROVIDE COMPLETE SET OF TRUSS CALCS				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		
☐ APPROVED (A)		☐ STOP WORK (S)		
☒ REJECTED (R)		☐ COMMENTS (C)		
☐ REFEE (F)		☐ TEMPORARY APPROVAL (T) — UNTIL		
☐ PROJECT COMPLETE		☐ HOLD (H)		
INSPECTOR SIGNATURE 		INSPECTION DATE 1-29-92		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7 00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3 00 P.M. AT		229-6769		

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS


☒	PERMIT NUMBER	91-128768	INSPECTION NUMBER	14
JOB ADDRESS 8029 SHORECREST DR				
LOT NO. 23		BLOCK NO 2		SUBDIVISION NAME LAKE SHORE
FIRE DEPT. MAP NO. 2117-56		JOB PHONE 451-9154		CALL-IN DATE 02/03/92 CALL-IN TIME 15:48
INSPECTOR NO. 50		INSPECTOR NAME JEFF KLEITZ		
INSPECTION REQUESTED ROOF SHEATHING (107)				
— NO FIXES FOR SHEATHING ON TRUSS CALLS ON-SITE; RECALL				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☐ APPROVED (A)		☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL ☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED - CALL *229-2071		
☐ REFEE (F)		REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E STEWART STREET		
INSPECTOR SIGNATURE		INSPECTION DATE		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7.00 A.M. - 7.15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	91-123768	INSPECTION NUMBER	12
JOB ADDRESS				
8029 SHORECREST DR				
LOT NO	BLOCK NO	SUBDIVISION NAME		
23	2	LAKE SHORE		
FIRE DEPT MAP NO	JOB PHONE	CALL-IN DATE	CALL-IN TIME	SCHEDULE DATE
2117-56	451-9154	01/30/92	15:50	01/31/92
INSPECTOR NO	INSPECTOR NAME			
50	JEFF KLEITZ			
INSPECTION REQUESTED	SHEAR (109)			

- PROVIDE HDZ FIX (\$HDS)
- ~~PROVIDE EXTERIOR LATHING FOR~~
~~REPAIRS AT STAIRS~~
- COMPLETE INSTALLATION OF ST2122 &
CLARIFY SHEAR TRANSFER
- INSTALL FTA2S AT STAIRS
- COMPLETE SHEAR TRANSFER AT STAIRS
- O.K. TO START EXTERIOR LATH ON
ALL WALLS EXCEPT EAST LIVING ROOM
WALL

☐ PARTIAL INSPECTION	☒ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION SEE ABOVE		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE				INSPECTION DATE 1-31-92
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	91-128768	INSPECTION NUMBER	22
JOB ADDRESS 8029 SHORECREST DR				
LOT NO 23		BLOCK NO. 2	SUBDIVISION NAME LAKE SHORE	
FIRE DEPT. MAP NO. 2117-56	JOB PHONE 451-9154	CALL-IN DATE 01/28/92	CALL-IN TIME 16:26	SCHEDULE DATE 01/29/92
INSPECTOR NO. 50/61		INSPECTOR NAME JEFF KLEITZ		
INSPECTION REQUESTED		SHEAR (109)		
AM ① Bolt FTA 2's at west rear wall. ② Renail all panels where nails have punched too far through. ③ Check all adjoining edge nail spacing. ④ HD 2A missing at back west corner. ⑤ Nail all PAHD 42's ⑥ Install HD 2A by front entry ⑦ PAHD 42's missing at back interior shear wall—provide engineers fix. ⑧ Provide panel blk at int. shear wall.				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071		☐ PERMIT REQUIRED	
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE Jeff Kleitz		INSPECTION DATE 1-29-92		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Type

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	91-128768	INSPECTION NUMBER	17
JOB ADDRESS 8029 SHORECREST DR				
LOT NO 23		BLOCK NO. 2	SUBDIVISION NAME LAKE SHORE	
FIRE DEPT MAP NO 2117-56	JOB PHONE 451-9154	CALL-IN DATE 01/27/92	CALL-IN TIME 13:25	SCHEDULE DATE 01/28/92
INSPECTOR NO. 83		INSPECTOR NAME JOHN LASKY		
INSPECTION REQUESTED		ROUGH MECHANICAL (320)		
A.M. Must have attic access. Must have platform Must have light.				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED - CALL *229-2071		☐ PERMIT REQUIRED	
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE		INSPECTION DATE 1/28/92		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6765

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS



**PERMIT
NUMBER**

91-128768

**INSPECTION
NUMBER**

8

JOB ADDRESS

8029 SHORECREST DR

LOT NO

23

BLOCK NO.

2

SUBDIVISION NAME

LAKESHORE

FIRE DEPT MAP NO.

2117-56

JOB PHONE

451-9154

CALL-IN DATE

12/20/91

CALL-IN TIME

14:45

SCHEDULE DATE

12/23/91

INSPECTOR NO

71

INSPECTOR NAME

KEEFE BEYER

**INSPECTION
REQUESTED**

CONSTRUCTION POWER (227)

A.M.

TAC # 29231



PARTIAL
INSPECTION



PARTIAL
APPROVAL (P)

PARTIAL DESCRIPTION



APPROVED
(A)



STOP
WORK (S)



COMMENTS
(C)



TEMPORARY
APPROVAL (T) - UNTIL



HOLD
(H)



REJECTED (R)

REINSPECTION REQUIRED - CALL 229-2071



REFEE (F)

REINSPECTION FEE REQUIRED - PAY AT CITY HALL
3RD FLOOR - 400 E. STEWART STREET.



PERMIT
REQUIRED

**INSPECTOR
SIGNATURE**

[Signature]

INSPECTION DATE

23 DEC 91



**PROJECT
COMPLETE**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)

IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY
CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2 45 P.M. - 3:00 P.M. AT

229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	91-128768	INSPECTION NUMBER	16
JOB ADDRESS 8029 SHORECREST DR				
LOT NO. 23		BLOCK NO. 2		SUBDIVISION NAME LAKESHORE
FIRE DEPT. MAP NO 2117-56	JOB PHONE 451-9154	CALL-IN DATE 12/18/91	CALL-IN TIME 16:20	SCHEDULE DATE 12/19/91
INSPECTOR NO. 50		INSPECTOR NAME JEFF KLEITZ		
INSPECTION REQUESTED		PRE-SLAB (105)		


AM

— UFER INSTALLED

— I CERTIFY THAT THE PROPERTY SET-
BACKS, LOT LINES, AND PAD ELEVATIONS
ARE CORRECT

TODD WILLIAMS




☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE 		INSPECTION DATE 12-19-91		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. OF O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7 15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

☒ PERMIT NUMBER	91-128768	INSPECTION NUMBER	11
JOB ADDRESS 8029 SHORECREST DR			
LOT NO 23	BLOCK NO 2	SUBDIVISION NAME LAKESHORE	
FIRE DEPT. MAP NO 2117-56	JOB PHONE 451-9154	CALL-IN DATE 12/17/91	CALL-IN TIME 15:12
INSPECTOR NO. 50		INSPECTOR NAME JEFF KLEITZ	
INSPECTION REQUESTED PRE-SLAB (105)			

PM

— SEE FOOTING LIST

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION	
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL
☒ REJECTED (R)	REINSPECTION REQUIRED - CALL *799-2071		☐ HOLD (H)
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE 	INSPECTION DATE 12-18-91		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT			229-6769

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER	91-128768		☒ INSPECTION NUMBER	6
JOB ADDRESS 8029 SHORECREST DR				
LOT NO. 23	BLOCK NO. 2	SUBDIVISION NAME LAKE SHORE		
FIRE DEPT MAP NO. 2117-56	JOB PHONE 451-9154	CALL-IN DATE 12/13/91	CALL-IN TIME 16:42	SCHEDULE DATE 12/16/91
INSPECTOR NO. 83	INSPECTOR NAME JOHN LASKY			
INSPECTION REQUESTED UNDERSLAB PLUMBING (407)				

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL *799-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE	<i>John Lasky</i>		INSPECTION DATE 12-16-91	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. OF O. ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6765

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS



**PERMIT
NUMBER**

91-128768

**INSPECTION
NUMBER**

26

JOB ADDRESS

8029 SHORECREST DR

LOT NO.

23

BLOCK NO.

2

SUBDIVISION NAME

LAKESHORE

FIRE DEPT. MAP NO.

2117-56

JOB PHONE

451-9154

CALL-IN DATE

12/17/91

CALL-IN TIME

15:11

SCHEDULE DATE

12/18/91

INSPECTOR NO.

83

INSPECTOR NAME

JOHN LASKY

**INSPECTION
REQUESTED**

BUILDING SEWER (YARD LINES) (405)

☐ **PARTIAL
INSPECTION**

☐ **PARTIAL
APPROVAL (P)**

PARTIAL DESCRIPTION

☒ **APPROVED
(A)**

☐ **STOP
WORK (S)**

☐ **COMMENTS
(C)**

☐ **TEMPORARY
APPROVAL (T) -- UNTIL**

☐ **HOLD
(H)**

☐ **REJECTED (R)**

REINSPECTION REQUIRED - CALL *799-2071

☐ **REFEE (F)**

**REINSPECTION FEE REQUIRED - PAY AT CITY HALL
3RD FLOOR - 400 E. STEWART STREET.**

☐ **PERMIT
REQUIRED**

**INSPECTOR
SIGNATURE**

John Lasky

INSPECTION DATE

12-18-91

☐ **PROJECT
COMPLETE**

**BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)**

**IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY
CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT**

229-6765

**FOR ADDITIONAL ASSISTANCE CALL *386-6251
SEE REVERSE SIDE FOR INSPECTION TYPES**

*** EFFECTIVE JULY 1, 1991
PHONE PREFIX WILL BE 229.**

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	91-128768	INSPECTION NUMBER	9
JOB ADDRESS 8029 SHORECREST DR				
LOT NO 23		BLOCK NO 2	SUBDIVISION NAME LAKE SHORE	
FIRE DEPT. MAP NO. 2117-56	JOB PHONE 451-9154	CALL-IN DATE 12/17/91	CALL-IN TIME 15:11	SCHEDULE DATE 12/18/91
INSPECTOR NO. 50		INSPECTOR NAME JEFF KLEITZ		
INSPECTION REQUESTED FOOTING, LAYOUT, REBAR, ZONING (101)				
— INSTALL PAHD 42⁵ & HAVE BOLTS FOR HD⁵ ON-SITE — COVER ALL COPPER — WRAP PLUMBING PASSING THROUGH FOOTINGS — INSTALL UFER GROUND — TIE STEEL IN PLACE				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED - CALL *799-2071		☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.		
INSPECTOR SIGNATURE 		INSPECTION DATE 12-18-91		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769

FOR ADDITIONAL ASSISTANCE CALL *386-6251
SEE REVERSE SIDE FOR INSPECTION TYPES

* EFFECTIVE JULY 1, 1991
PHONE PREFIX WILL BE 229.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER	91-128768	INSPECTION NUMBER	10
JOB ADDRESS 8029 SHORECREST DR			
LOT NO. 23	BLOCK NO. 2	SUBDIVISION NAME LAKESHORE	
FIRE DEPT. MAP NO. 2117-56	JOB PHONE 451-9154	CALL-IN DATE 12/17/91	CALL-IN TIME 15:11
INSPECTOR NO. 50		INSPECTOR NAME JEFF KLEITZ	
INSPECTION REQUESTED STEM WALL - FORMS & REBAR (103)			

PM


— SEE FOOTING LIST

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION	
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL
☒ REJECTED (R)	REINSPECTION REQUIRED - CALL *799-2071		☐ HOLD (H)
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE <i>Jeff Kleitz</i>		INSPECTION DATE 12-18-91	
☐ PROJECT COMPLETE	(BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only))		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT			229-6769

FOR ADDITIONAL ASSISTANCE CALL *386-6251
SEE REVERSE SIDE FOR INSPECTION TYPES

*EFFECTIVE JULY 1, 1991
PHONE PREFIX WILL BE 229.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

1	PERMIT NUMBER	91-128763	INSPECTION NUMBER	13
JOB ADDRESS 8029 SHORECREST DR				
LOT NO. 23		BLOCK NO. 2		SUBDIVISION NAME LAKE SHORE
FIRE DEPT. MAP NO 2117-56	JOB PHONE 451-9154	CALL-IN DATE 04/21/92	CALL-IN TIME 15:56	SCHEDULE DATE 04/22/92
INSPECTOR NO 72/71		INSPECTOR NAME BOB SMITH		
INSPECTION REQUESTED		FINAL ELECTRICAL (240)		
A.M.				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE 		INSPECTION DATE 22 APR 92		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6765

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	91-128768	INSPECTION NUMBER	5
JOB ADDRESS				
8029 SHORECREST DR				
LOT NO		BLOCK NO.	SUBDIVISION NAME	
23		2	LAKE SHORE	
FIRE DEPT MAP NO	JOB PHONE	CALL-IN DATE	CALL-IN TIME	SCHEDULE DATE
2117-56	451-9154	04/23/92	12:56	04/24/92
INSPECTOR NO.		INSPECTOR NAME		
59		BOB GATES		
INSPECTION REQUESTED		TEMP POWER/TAG/TEMP BLDG FINAL (139)		

A.M.

30 Day EX 42833


☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR 400 E. STEWART STREET			
INSPECTOR SIGNATURE		4/24/92		INSPECTION DATE
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

*	PERMIT NUMBER	91-128768	INSPECTION NUMBER	5
JOB ADDRESS 8029 SHORECREST DR				
LOT NO. 23		BLOCK NO. 2		SUBDIVISION NAME LAKESHORE
FIRE DEPT MAP NO. 2117-56	JOB PHONE 451-9154	CALL-IN DATE 06/04/92	CALL-IN TIME 10:45	SCHEDULE DATE 06/05/92
INSPECTOR NO. 59/69		INSPECTOR NAME BOB GATES / EO BALLARD		
INSPECTION REQUESTED		BUILDING FINAL (140)		

- ① PROVIDE PERM ADDRESS AFFIXED TO BLDG. CLEARLY VISIBLE FROM STREET
- ② SHEAR OFF SCREWS ON HOSE BIB VACUUM BREAKERS - ALSO REPAIR STUCCO
- ③ OBTAIN FINAL GAS APPROVAL
- ④ DOOR IN 1 HR. WM. SHALL BE SELF CLOSING / LATCHING
- ⑤ HANDRAILS SHALL BE 34" TO 38" MEASURED FROM TREAD NOSE TO TOP - ALSO EXTEND FULL LENGTH OF STAIR RUN
- ⑥ GROUT M/B F/P HEARTH
- ⑦ + 36" GUARDRAIL REQUIRED @ STAIR LANDING

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED - CALL * 229-2071		☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 100 E. STEWART STREET.		
INSPECTOR SIGNATURE 		INSPECTION DATE 6-5		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769


For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	91-128768	INSPECTION NUMBER	4
JOB ADDRESS 8029 SHORECREST DR				
LOT NO. 23		BLOCK NO. 2	SUBDIVISION NAME LAKE SHORE	
FIRE DEPT. MAP NO. 2117-56	JOB PHONE 451-9154	CALL-IN DATE 06/04/92	CALL-IN TIME 10:44	SCHEDULE DATE 06/05/92
INSPECTOR NO 59		INSPECTOR NAME BOB GATES		
INSPECTION REQUESTED FINAL GAS TEST (423)				

gas gage at 0 lbs!

No Numbers on
House

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED - CALL * 229-2071		☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.		
INSPECTOR SIGNATURE 		INSPECTION DATE 6-5-92		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	91-128763	INSPECTION NUMBER	6
JOB ADDRESS 8029 SHORECREST DR				
LOT NO. 23		BLOCK NO. 2	SUBDIVISION NAME LAKESHORE	
FIRE DEPT. MAP NO 2117-56	JOB PHONE 451-9154	CALL-IN DATE 06/03/92	CALL-IN TIME 13:32	SCHEDULE DATE 06/04/92
INSPECTOR NO. 59		INSPECTOR NAME BOB GATES		
INSPECTION REQUESTED		FINAL MECHANICAL (340)		

- Seal around range exhaust duct

Apv Subject to above

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET			
INSPECTOR SIGNATURE <i>[Signature]</i>		INSPECTION DATE 6/4/92		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				➤ 229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	91-128768	INSPECTION NUMBER	7
JOB ADDRESS 8029 SHORECREST DR				
LOT NO. 23		BLOCK NO. 2	SUBDIVISION NAME LAKE SHORE	
FIRE DEPT MAP NO. 2117-56	JOB PHONE 451-9154	CALL-IN DATE 06/03/92	CALL-IN TIME 13:33	SCHEDULE DATE 06/04/92
INSPECTOR NO. 59		INSPECTOR NAME BOB GATES		
INSPECTION REQUESTED		FINAL PLUMBING (440)		

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE <i>Bob Gates</i>		INSPECTION DATE 6/4/92		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7 00 A.M. - 7.15 A.M. OR 2 45 P.M. - 3:00 P.M. AT				229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER	91-128763	INSPECTION NUMBER	8
JOB ADDRESS 8029 SHORECREST DR			
LOT NO 23	BLOCK NO 2	SUBDIVISION NAME LAKE SHORE	
FIRE DEPT MAP NO 2117-56	JOB PHONE 451-9154	CALL-IN DATE 06/03/92	CALL-IN TIME 13:34
SCHEDULE DATE 06/04/92			
INSPECTOR NO. 59	INSPECTOR NAME BOB GATES		
INSPECTION REQUESTED FINAL GAS TEST (423)			

Rg
- NO PRESS ON gas line

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION	
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL
☐ HOLD (H)			
☒ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071		☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E STEWART STREET.		
INSPECTOR SIGNATURE <i>B. Gates</i>	INSPECTION DATE 6/4/92		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7.00 A.M. - 7.15 A.M. OR 2.45 P.M. - 3.00 P.M. AT			229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

7	PERMIT NUMBER	91-128768	INSPECTION NUMBER	1
JOB ADDRESS 8029 SHORECREST DR				
LOT NO 23		BLOCK NO. 2	SUBDIVISION NAME LAKE SHORE	
FIRE DEPT. MAP NO 2117-56	JOB PHONE 451-9154	CALL-IN DATE 06/09/92	CALL-IN TIME 15:03	SCHEDULE DATE 06/11/92
INSPECTOR NO 59		INSPECTOR NAME BOB GATES		
INSPECTION REQUESTED		FINAL GAS TEST (423)		

30 DGT # 22637

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE <i>Bob Gates</i>		INSPECTION DATE 6/11/92		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	92-139534	INSPECTION NUMBER	19
JOB ADDRESS 8029 SHORECREST DR				
LOT NO.		BLOCK NO.	SUBDIVISION NAME LAKE SHORE	
FIRE DEPT. MAP NO. 2117-56	JOB PHONE	CALL-IN DATE 04/17/92	CALL-IN TIME 15:21	SCHEDULE DATE 04/20/92
INSPECTOR NO. 7271		INSPECTOR NAME BOB SMITH		
INSPECTION REQUESTED		FINAL ELECTRICAL (240)		


A.M.

SINGLE 20A RECEPT, FOR VAC
REQ.RECEPTS REQ ON KIT. ISLAND
RECEPT REQ FRONT UPSTAIRS
BED RM.CK MASTER BATH FOR WIRES
BEHIND MIRROR

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE		INSPECTION DATE 20 APR 92		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7 00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6765

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

	PERMIT NUMBER	92-139534	INSPECTION NUMBER	4
JOB ADDRESS				
8029 SHORECREST DR				
LOT NO		BLOCK NO.		SUBDIVISION NAME
FIRE DEPT. MAP NO.	JOB PHONE	CALL-IN DATE	CALL-IN TIME	SCHEDULE DATE
-		03/17/92	14:46	03/18/92
INSPECTOR NO		INSPECTOR NAME		
50		JEFF KLEITZ		
INSPECTION REQUESTED		WALL GROUT & STEEL (131)		
- NO GROUT STEEL ON-SITE - NO PERMIT CARD ON-SITE				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)		REINSPECTION REQUIRED - CALL * 229-2071		☐ PERMIT REQUIRED
☐ REFEE (F)		REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.		
INSPECTOR SIGNATURE				INSPECTION DATE
☐ PROJECT COMPLETE		3-18-92		
		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				 229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

R-196/91

FEBRUARY 26, 1992

REVIEWING AUTHORITY
DEPARTMENT OF BUILDING AND SAFETY
CITY OF LAS VEGAS
LAS VEGAS, NEVADA

SUBJECT : TODD WILLIAMS RESIDENCE : CONTRACTOR MODIFICATIONS


ITEM 1 - USE OF 2X4 STUDS FOR BEARING WALL AT GARAGE (REAR)

PER THE ATTACHED CALCULATIONS, 2X4 (DF #2 OR BETTER) STUDS
ARE PERMISSIBLE FOR USE AT THE BEARING WALL AT THE REAR OF
THE GARAGE. STUDS SHOULD BE SPACED 16" O.C. (MAXIMUM).

ITEM 2 - USE OF 4X12 HEADERS IN LIEU OF 6X6 AND 6X8 (GARAGE)

PER THE ATTACHED CALCULATIONS, 4X12 (DF #1 OR BETTER) HEADERS
MAY BE SUBSTITUTED FOR THE 6X6 AND 6X8 (2'-6" AND 4'-0" OPENINGS)
HEADERS IN THE GARAGE.

ROBERT A. HENNING P.E.



TODD WILLIAMS
RESIDENCE

R. A. HENNING, P. E.

PAGE 1A

REVISED BEARING WALL
DESIGN.Check 2x4 (16" o.c.) @
Rear garage wall.

Ref. pg 16 (original calcs).

Try 2x4 (DFN#2)

$$F_b = 1650 \text{ psi}$$

$$F_{cL} = 625 \text{ psi}$$

$$F_c = 1000 \text{ psi}$$

$$E = 1,700,000$$

$$\frac{L_{cx}}{d_x} = \frac{96.5}{3.5} = 27.57$$

Case (2) DL+LL (Floor) + VL

$$P = 1414 \text{ #}$$

$$m = 218 \text{ #}$$

$$f_b = \frac{218(12)}{3.063} = 854 \text{ psi}$$

$$F_b' = 1650(1.33) = 2195 \text{ psi}$$

$$K_x = 0.671 \sqrt{\frac{1,700,000}{1000(1.33)}} = 23.99$$

27.57 > 23.99 $\therefore$ long col.

$$F_c' = \frac{0.3 E'}{\left(\frac{L_c}{d}\right)^2}$$

$$= \frac{0.3(1,700,000)}{(27.57)^2} = 671 \text{ psi}$$

$$f_c = \frac{1414}{5.25} = 269 \text{ psi}$$

< 671 ok.

$$J_x = \frac{27.57 - 11}{23.99 - 11} = 1.28$$

$$\frac{f_c}{F_c'} + \frac{f_b x}{F_b x - J_x f_c} \leq 1.0$$

$$\frac{269}{671} + \frac{854}{2195 - 1.28(269)} = 0.86 < 1.0 \text{ ok.}$$

2x4 studs 16" o.c. OKREVISED DOOR / WINDOW HDR.

Ref. pg. 18 & 19 (original calcs)

Try substitution of 4x12
for 6x6 & 6x8 headers
in garage.4th opening controls

$$W(DL+LL) = 39\left(\frac{1}{2}\right)(32) = 624 \text{ #}$$

$$m = \frac{624(4.5)^2}{8} = 1580 \text{ #}$$

$$V = \frac{624(4.5)}{2} = 1404 \text{ #}$$

Try 4x12

$$L_c = 1.63(4.5)(12) + 8(11.25) = 121.77$$

$$C_s = \sqrt{\frac{122(11.25)}{(3.5)^2}} = 10.58 > 10$$

$\therefore$ int br.

$$C_k = 0.811 \sqrt{\frac{1,600,000}{1300(1.25)}} = 25.45$$

$$F_b' = 1300(1.25) \left[1 - \frac{1}{3} \left(\frac{10.58}{25.45} \right)^4 \right]$$

$$f_b = \frac{1580(12)}{73.83} = 257 < 1609 \text{ psi}$$

$$f_v = \frac{1.5(1404)}{39.38} = 53 < 1.25(95) \text{ ok}$$

door and window

FEBRUARY 28, 1992


REVIEWING AUTHORITY
DEPARTMENT OF BUILDING AND SAFETY
CITY OF LAS VEGAS
LAS VEGAS, NEVADA

SUBJECT : TODD WILLIAMS RESIDENCE : CONTRACTOR MODIFICATIONS

ITEM 1 -- EPOXY GROUTING OF "SIMPSON" HDS HOLDDOWNS

"SIMPSON" HDS HOLDDOWNS MAY BE EPOXY GROUTED INTO THE
FOUNDATION IN LIEU OF CASTING IN PLACE.

ROBERT A. HENNING P.E.



CITY OF LAS VEGAS, NEVADA

PERMIT NO. 91-128768

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

FOR INSPECTIONS CALL 386-6251

BUILDING PERMIT

FOR: Single Family Dwelling, Remodel
Additions, Misc. Residential ConstructionLOG NO. & AREA **R-196 91**

35



65011

CONST. VAL. \$ **72082.00**ADDRESS OF CONSTRUCTION **8029 Shorecrest Dr** OWNER **Jeff Williams** PHONE **451-9154**LOT(s) **23** BLOCK **2** SUBDIVISION **Lake Shore** ZONE **R-PDS**PROPOSED CONSTRUCTION **SFD w/ 2 FD** USE _____THIS PERMIT FOR BLDG. ☒ A/C ☒ ELEC ☒ PLBG ☒ OTHER PERMITS REQD: FENCE ☐ OFF SITE ☐ SWIM POOL ☐FLOOR AREA BSMT **—** 1ST **1346** 2ND **984** GARAGE **704** PORCH **216 271** TOTAL **3305**CONTRACTOR **Owner** STATE LICENSE NO. _____ CITY LICENSE NO. _____ARCHITECT **John Sherman** ENGINEER **R. Henning CE 295-1513**


MASTER PLUMBER/CONTRACTOR _____ MASTER ELECTRICIAN/CONTRACTOR _____

OTHER INSPECTIONS AND FEES

- 1 Inspections outside of normal business hours = \$30.00 per hour (minimum charge three hours)
- 2 Re-inspection fee during normal business hours assessed under provisions of TABLE 3-A of the Uniform Building Code = \$30.00 per hour.
- 3 Inspections during normal business hours for which no fee is specifically indicated = \$30.00 per hour (minimum charge one half hour).
- 4 Additional plan review required by changes, additions, or revisions to approved plans = \$30.00 per hour (minimum charge two hours)

CONDITIONS OF THE PERMIT:

- 1 I agree to call the City Building Department for inspections before concrete is poured, before rough wiring, electrical, plumbing, framing is covered. Also for air conditioning, drywall and sheathing inspection.
- 2 I agree that when the job is completed that I will call for final inspection before occupancy.
- 3 I agree to perform all construction in accordance with City Ordinances and Building Codes.
- 4 The Contractor's signature below denotes authority from the owner to sign in his behalf and that the owner is aware of all requirements of this application and permit. Separate permits must be taken out for work outlined above this agreement.
- 5 I have read and understand the contents of this application and permit, I hereby state that the information I have supplied on this application is true and correct
- 6 Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way
7. 24 HOUR MINIMUM NOTICE REQUIRED FOR INSPECTIONS.

By  I HEREBY DECLARE THAT I AM THE LEGAL OWNER OF THE ABOVE PROPERTY OWNER

By _____ AGENT

I hereby certify that I have reviewed this application and the proposed plans and have found that the proposed development meets the requirements of the City of Las Vegas Flood Hazard Reduction Ordinance for the issuance of this Development Permit

LAND DEVELOPMENT AND FLOOD CONTROL ENGINEER DATE **10/11/91**PLANNING DEPT DATE **10/9/91**BUILDING DEPT. DATE **12-11-91**

ELECTRICAL

FEE

RECEPTACLE _____ SWITCH _____	.40
EACH LIGHT FIXTURE OR SOCKET _____	.30
SPECIAL OUTLET, APPLIANCE ETC. _____	.70
SERVICE/PANEL-SUB/3 00-200A/6.00-400A/12.50	
A/C UNIT OR MOTORS _____	3.00
2310 - 2432	TOTAL 89.95
MISC TEMP POLE	6

PLUMBING	FEE
WATER DISTRIBUTION	6.00
SEWER SYSTEM - NEW OR MODIFICATION	10.00
FIXTURES - WATER SOFTENER, H.W. HEATER	2.00
GARBAGE DISPOSAL - WASHER	2.00
FUEL PIPING	6.00
IRRIGATION SYSTEM	8.00
MISC.	89
2310 - 2433	TOTAL
AIR CONDITIONING	FEE
NEW UNIT - 3 TON = 9.00 OVER = 16.50	
FURNACE TO 100,000/9.00 OVER/11.00	
VAPORATIVE COOLER	6.50
VENTILATION FAN	2.35
2310 - 2435	TOTAL 67

2310 - 2431 PLAN REVIEW

2310 - 2401 BLDG. PERMIT

7143 - 2973 SEWER CONNECTION

6122 - 3352 TORTOISE

- 2897 P.I.F.

88100-1232 TRANSPORT

TOTAL FEES

8.00**449.00****650.00** 12/11/91**500****1858.00**

SPECIAL CONDITIONS:


RECEIPT
MUST BE MACHINE VALIDATED

ELEC	95.00
PLBG	89.00
A/C	67.00
PLCK	8.00
SFD	449.00
SEWR	650.00
TRAN	500.00
CHEK	1858.00
6694A000	12:51

PERMIT NO.

Permit Expires 180 Days After Abandonment of Work

R196-91



LEGAL
LOT 13 BLK 2
LAKE SHORE, 510'0"
BK 43 PLATS, PG. 77 CLINTON
COUNTY RECORDS

APPROVED ST12

10/9/91
COMMUNITY PLANNING & DEVELOPMENT
City of Las Vegas

ITE PLAN

CITY OF LAS VEGAS, NEVADA

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

PERMIT NO. 92-139534



DEVELOPMENT PERMIT

FOR: Fence, Wall, Retaining Wall

LOG NO. & AREA

M-1713 -K

DATE

3/17/92

CONST. VAL. \$

1800.00

ADDRESS OF
CONSTRUCTION

8029 Shorecrest Dr.

OWNER

Wilman

PHONE

CONTRACTOR

Iovino Masonry

STATE

LICENSE NO.

020977

CITY

LICENSE NO.

024852

LOT(s)

33

BLOCK

2

SUBDIVISION

Lakeshore

ZONE

R-PDS

☐ CONSTRUCTION PLANS SUBMITTED BY OWNER/CONTRACTOR☒ CONSTRUCTION DESIGN BY CITY DESIGN SHEET.

ENGINEER

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way


DESCRIPTION	TOTAL LIN FT	TOTAL SQ FT
CHAIN LINK OR WIRE MESH		
ORNAMENTAL IRON		
WOOD		
MASONRY	6' 190	720
RETAINING		

OTHER INSPECTIONS AND FEES

- 1 Inspections outside of normal business hours = \$30.00 per hour (minimum charge three hours)
- 2 Re-inspection fee during normal business hours assessed under provisions of TABLE 3-A of the Uniform Building Code = \$30.00 each
- 3 Inspections during normal business hours for which no fee is specifically indicated = \$30.00 per hour (minimum charge one half hour)
- 4 Additional plan review required by changes, additions or revisions at approved plans = \$30.00 per hour (minimum charge two hours)

CONDITIONS OF THE PERMIT:

1. Any type of retaining wall must be engineered by a Civil or Structural Engineer.
2. If a home owner takes out the Building Permit and if the owner sublets the work to a Contractor, then the Contractor must take out the permit and pay for it.
3. No fence or wall can be built on City property or rights-of-way, but this is not intended to preclude construction within utility easements if utilities will not be damaged or made inaccessible.
4. The fence or wall shall not enclose any water meter, light standard, or fire alarm box and shall not come closer than 24" from the nearest fire hydrant outlet.
5. Department Inspectors must approve footings before concrete is poured and block wall reinforcing before grouting is done.
6. Maximum height of any wall or fence is 6', side and rear yards; 4' maximum in front yard with the vertical surface above the height of 2' - 50% open.
7. I must not obstruct required onsite parking space (2 spaces for each dwelling unit) by the erection of this fence or wall.
8. By the signing of this application I herewith agree to the requirements outlined above.



THIS FENCE OR WALL SHALL NOT BLOCK THE
NATURAL FLOW OF SURFACE WATER ACROSS
THE PROPERTY NOR SHALL IT DIVERT
THE FLOW OF SURFACE WATERS ONTO
ANOTHER'S PROPERTY.

FOR INSPECTIONS, CALL 799-2071

SIGNED Francis J. Arling
PLANNING DEPT.

CONTRACTOR - AGENT - OWNER

3/17/92

DATE

I hereby certify that I have reviewed this application and the proposed plans and have found that the proposed development meets the requirements of the City of Las Vegas Flood Hazard Reduction Ordinance for the issuance of this Development Permit.

LAND DEVELOPMENT AND FLOOD CONTROL ENGINEER

BUILDING DEPT

PLAN
REVIEW
FEEPERMIT
FEE
2310-2401TOTAL
FEES

RECEIPT

0002
WALL 41.00
CHEK 41.00
1978A000 12:57

03/17/92

As per
City Design
Sheet

MUST BE MACHINE VALIDATED

Permit Expires 180 Days After Abandonment of Work