

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☐ PERMIT NUMBER 91095477		☐ INSPECTION NUMBER	
JOB ADDRESS 2432 Ocean Front Dr.			
LOT NO. 14	BLOCK NO. 1	SUBDIVISION NAME Desert Shores/LaJolla	
FIRE DEPT. MAP NO.	JOB PHONE	CALL-IN DATE 6-13-91	CALL-IN TIME 9 2:25p.
INSPECTOR NO. 60		INSPECTOR NAME	
INSPECTION REQUESTED Top out water, gas & waste. R/vent, elect, frame.			
① Label Brace garage - 1 HOUST ② DEPR vent cannot terminate in Tee TOP - MUST RUN HORIZ with Back Draft Dampen ③ WHOLE HOUSE IS RUN IN 14-2 WIRE NODS TO BG 12 GAUGE EXCEPT LITE WIRE RUN'S ④ NAVL walls together southwest corner LIV-RM (AND THRU OUT HOUSE (CHANNEL) OUT OF ROOM TO WASTE			
☒ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)	
PARTIAL DESCRIPTION COND. LINES (PVC)			
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL
☐ HOLD (H)			
☒ REJECTED (R) REINSPECTION REQUIRED - CALL *799-2071		☐ PERMIT REQUIRED	
☐ REFEE (F) REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE S. Ventaf		INSPECTION DATE 6-14-91	
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)	
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT			