

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☐	PERMIT NUMBER	092477	INSPECTION NUMBER		
JOB ADDRESS 2929 Harbor Cove Dr.					
LOT NO		BLOCK NO.		SUBDIVISION NAME	
				HARBOR COVE	
FIRE DEPT MAP NO.		JOB PHONE		CALL-IN DATE	CALL-IN TIME
				5-2-91	8 8:28A.
INSPECTOR NO		INSPECTOR NAME			
50					
INSPECTION REQUESTED		F/Elect./F/Plumb, Mech, Bldg.			
140, 240, 340, 440, 940, 423 - GAS HOLDING 10 lbs; 15 lbs required (am) - INSTALL CLEAN OUT CAP FOR FOOT VENT OF KITCHEN SINK - INSTALL SHUT OFF KEY FOR GAS TO FIREPLACE - SECURE 10/3 WIRE TO GAR D/W TO BOX - SEAL HOLE IN GARAGE WALL AT W/H BOND - WINDOW IN FRONT S.E. CORNER IS 46" ABOVE FLOOR (ALSO N.E. CORNER) - REMOVE TEMPORARY POWER POLE - 30 DAY TEMP POWER E-TAG # 31457 31457					
☐ PARTIAL INSPECTION		☒ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION 229	
				240, 340, & 440 only	
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL		☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL 799-2071				☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.				
INSPECTOR SIGNATURE		[Signature]		INSPECTION DATE	
				5-3-91	
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7 00 A.M. - 7 15 A.M. OR 2:45 P.M. - 3:00 P.M. AT					

FOR ADDITIONAL ASSISTANCE CALL 386-6251
SEE REVERSE SIDE FOR INSPECTION TYPES