

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS



PERMIT
NUMBER

092477

INSPECTION
NUMBER

JOB ADDRESS

2929 Harbor Cove Dr.

LOT NO

BLOCK NO.

SUBDIVISION NAME

HARBOR COVE

FIRE DEPT MAP NO.

JOB PHONE

CALL-IN DATE

CALL-IN TIME

SCHEDULE DATE

5-2-91

8 8:28A.

INSPECTOR NO

INSPECTOR NAME

50

INSPECTION
REQUESTED

F/Elect./F/Plumb, Mech, Bldg.

140, 240, 340, 440, 940, 423

- GAS HOLDING 10 lbs; 15 lbs required (am)
- INSTALL CLEAN OUT CAP FOR FOOT VENT OF KITCHEN SINK
- INSTALL SHUT OFF KEY FOR GAS TO FIREPLACE
- SECURE 10/3 WIRE TO GAR D/W TO BOX
- SEAL HOLE IN GARAGE WALL AT W/H BOND
- WINDOW IN FRONT S.E. CORNER IS 46" ABOVE FLOOR (ALSO N.E. CORNER)
- REMOVE TEMPORARY POWER POLE
- 30 DAY TEMP POWER
- E-TAG # ~~31457~~ 31457

☐ PARTIAL
INSPECTION

☒ PARTIAL
APPROVAL (P)

PARTIAL DESCRIPTION 229
240, 340, & 440 ONLY

☐ APPROVED
(A)

☐ STOP
WORK (S)

☐ COMMENTS
(C)

☐ TEMPORARY
APPROVAL (T) - UNTIL

☐ HOLD
(H)

☐ REJECTED (R)

REINSPECTION REQUIRED - CALL 799-2071

☐ REFEE (F)

REINSPECTION FEE REQUIRED - PAY AT CITY HALL
3RD FLOOR - 400 E. STEWART STREET.

☐ PERMIT
REQUIRED

INSPECTOR
SIGNATURE

Jim Kuntz

INSPECTION DATE

5-3-91

☐ PROJECT
COMPLETE

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)

IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY
CALL THE INSPECTOR FROM 7 00 A.M. - 7 15 A.M. OR 2:45 P.M. - 3:00 P.M. AT

FOR ADDITIONAL ASSISTANCE CALL 386-6251
SEE REVERSE SIDE FOR INSPECTION TYPES