

**CITY OF LAS VEGAS
DIVISION OF FIRE SERVICES**

JOB ADDRESS 1701 W Charleston			PERMIT NO
LOT NO	MAP NO	INSPECTOR	DATE
PROJECT NAME Charleston Towers			PHONE
INSPECTOR'S SIGNATURE <i>Gojardo</i>			INSPECTION DATE 10/22/90

Met with John Carreras, building owner, concerning completion of inspections necessary. Fire pump test is suppose to be scheduled for this coming weekend.

Pump room still needs power for heater and battery-backup emergency lighting.

Sprinkler heads dropped below ceiling in open area in rear building but no walls installed.

- | | | |
|--|---|--|
| ☐ PARTIAL APPROVAL | ☐ REJECTED REINSPECTION REQUIRED | ☐ FINAL APPROVAL |
| ☐ TEMPORARY APPROVAL | | ☐ STOP ORDER |
| ☐ X 1 UNDER/ABOVEGROUND TANK | ☐ X 5 FIRE ALARM SYSTEM | ☐ X 8 EXTINGUISHING SYSTEM |
| ☐ X 2 HOOD SYSTEM | ☐ X 6 OTHER | ☐ X 9 MEDICAL GAS |
| ☐ X 3 UNDERGROUND FINAL/FLOW | ☐ X 7 FINAL FIRE | ☐ X 10 LPG |
| ☐ X 4 SPRINKLER SYSTEM/OVERHEAD HYDRO | | ☐ X 11 SUPERVISION/MONITORING |

FOR INSPECTIONS CALL 799-2071 FOR FURTHER INFORMATION CALL 383-2888