

**CITY OF LAS VEGAS
DIVISION OF FIRE SERVICES**

| | | | |
|---|--------|-----------|------------------------------------|
| JOB ADDRESS 1501 W. Sahara | | | PERMIT NO |
| LOT NO | MAP NO | INSPECTOR | DATE |
| PROJECT NAME Las Vegas Inn | | | PHONE |
| INSPECTOR'S SIGNATURE Jopards | | | INSPECTION DATE 11/22/90 |

① Water flows previously tested and found to be o.k

*② Remote central station monitoring required as per approved plans.

③ Sprinkler head K factors verified

*④ Head in elevator lobby - 3rd floor shall be replaced - painted - Problem corrected

⑤ Spot checked all rooms and hallway - all o.k (except for above)

*⑥ Tested flow over tamper on 2-4th floors. Problem with wiring on 2nd floor.

| | | |
|---|--|--|
| <input type="checkbox"/> PARTIAL APPROVAL | <input checked="" type="checkbox"/> REJECTED REINSPECTION REQUIRED | <input type="checkbox"/> FINAL APPROVAL |
| <input checked="" type="checkbox"/> TEMPORARY APPROVAL | | <input type="checkbox"/> STOP ORDER |
| <input type="checkbox"/> X 1 UNDER/ABOVEGROUND TANK | <input type="checkbox"/> X 5 FIRE ALARM SYSTEM | <input type="checkbox"/> X 8 EXTINGUISHING SYSTEM |
| <input type="checkbox"/> X 2 HOOD SYSTEM | <input type="checkbox"/> X 6 OTHER | <input type="checkbox"/> X 9 MEDICAL GAS |
| <input type="checkbox"/> X 3 UNDERGROUND FINAL/FLOW | <input type="checkbox"/> X 7 FINAL FIRE | <input type="checkbox"/> X 10 LPG |
| <input checked="" type="checkbox"/> X 4 SPRINKLER SYSTEM/OVERHEAD HYDRO | | <input type="checkbox"/> X 11 SUPERVISION/MONITORING |

FOR INSPECTIONS CALL 799-2071 FOR FURTHER INFORMATION CALL 383-2888