


DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☐	PERMIT NUMBER	11111	INSPECTION NUMBER	
JOB ADDRESS 804 GLEN ABBY CR.				
LOT NO.		BLOCK NO.	SUBDIVISION NAME	
FIRE DEPT. MAP NO.	JOB PHONE	CALL-IN DATE	CALL-IN TIME	SCHEDULE DATE
INSPECTOR NO. 69		INSPECTOR NAME EDB		
INSPECTION REQUESTED		115 INVESTIGATION		
UPON VISUAL INSPECTION ONLY GARAGE TO HOUSE WALL SOUTH TO NORTH - ACROSS ENTRY @ BEAM APPEARS TO BE RACKING, CAUSING DRYWALL AND STUCCO CRACKS ALSO OBSERVED 1/4" TO 3/8" GARAGE SLAB CRACKS AND DRIVEWAY FOOTWORK LIFTING - GARAGE STEM WALL CANNOT BE SEEN DUE TO MATERIAL & STUCCO COVERING - SUGGEST SOILS AND STRUCTURAL ENGINEERS TO INVESTIGATE & PROVIDE WRITTEN REPORT				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL *229-2071		☐ PERMIT REQUIRED	
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE 		INSPECTION DATE 10-6-92		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. OF O. ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT 				

For Additional Assistance Call *229-6251. See Reverse Side For Inspection Types.