

CITY of LAS VEGAS DIVISION of BUILDING and SAFETY

INFORMATION INSPECTION RECORD

JOB _____
ADDRESS 737 NO MAIN
DATE Aug 31, 1989
INSPECTOR Robert Smith
TYPE OF INSPECTION ELECTRICAL

ACTION REQUIRED

Numerous Violations were found
thru-out. Some items were; Broken
Conduit, open wiring, fixtures falling
from ceiling, Cord connected Solid
Mounted Receptacles and the main
disconnect is inside a room that
is hard to get to from the outside
the Fire dept would have a hard time
disconnecting the Service in a
Emergency

REMARKS/INFORMATIONSIGNATURE

Robert Smith