

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒ PERMIT NUMBER	91-128904	INSPECTION NUMBER	34
JOB ADDRESS 2217 SILVER PINE DR			
LOT NO. 47	BLOCK NO. 17	SUBDIVISION NAME TORREY PINES III	
FIRE DEPT. MAP NO. 2219-24	JOB PHONE 387-3585	CALL-IN DATE 07/09/92	CALL-IN TIME 14:59
INSPECTOR NO. 67		INSPECTOR NAME JESSE SCHELL	
INSPECTION REQUESTED		BUILDING FINAL (140)	

GFI REQ'D FOR BATHROOM RECEPTACLES
- 20 AMP RECEPTACLE & WASHER/DRAIN

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION	
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL
☒ REJECTED (R)		☐ HOLD (H)	
☐ REFEE (F)		☐ PERMIT REQUIRED	
INSPECTOR SIGNATURE <i>Jesse Schell</i>		INSPECTION DATE 7-10-92	
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)	
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT		229-6769	

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.