

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. Rancho		PERMIT NO. 91-098625
LOT NO.	MAP NO.	INSPECTOR 75
SUBDIVISION NAME S.W. Medical Center		DATE 3/7/91
INSPECTOR SIGNATURE A. Patterson		PHONE 362-6288
Ceiling Electrical		INSPECTION DATE 3-8-91
T I		Holland + Holland

☐ PARTIAL INSPECTION - DESCRIPTION:

☒ **APPROVED**
☐ **PERMIT REQUIRED**
☐ **STOP WORK**

☒ **REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 792-2071**

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☒ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT.	☒ E-2	ROUGH ELECTRICAL
☐ B-10	<u>POOL</u> PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	<u>POOL</u> PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE - CALL: 366-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. Ranchos Dr		PERMIT NO. 98764	
LOT NO	MAP NO 13-122P	INSPECTOR 75	DATE 3-4-91
SUBDIVISION NAME L.W. Medical			PHONE 362-9878
INSPECTOR SIGNATURE A. Patterson			INSPECTION DATE 3-5-91

NEVCO

T.I.

☐ PARTIAL INSPECTION - DESCRIPTION

☒ **APPROVED**

☐ **PERMIT REQUIRED**

☐ **STOP WORK**

☒ **REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071**

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☒ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 386-0251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

1	PERMIT NUMBER	92-131686	INSPECTION NUMBER	13
JOB ADDRESS 888 S RANCHO DR -				
LOT NO.		BLOCK NO		SUBDIVISION NAME SIERRA HEALTH SERVICE
FIRE DEPT MAP NO.	JOB PHONE	CALL-IN DATE	CALL-IN TIME	SCHEDULE DATE
2423-88	458-6579	01/27/92	17:10	01/28/92
INSPECTOR NO.		INSPECTOR NAME		
68		JOHN CARSON		
INSPECTION REQUESTED		BUILDING - FINAL (140)		
458-6579				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☒ APPROVED (A)		☐ STOP WORK (S)		
		☐ COMMENTS (C)		☐ TEMPORARY APPROVAL (T) - UNTIL
				☐ HOLD (H)
☐ REJECTED (R)		REINSPECTION REQUIRED - CALL * 229-2071		
☐ REFEE (F)		REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET		
☐ PERMIT REQUIRED				
INSPECTOR SIGNATURE		INSPECTION DATE		
John Carson		1-28-92		
☒ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7 00 A.M - 7:15 A.M. OR 2:45 P.M - 3:00 P.M. AT				229-6765

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS


PERMIT NUMBER 92-151686		INSPECTION NUMBER 2		
JOB ADDRESS 888 S RANCHO DR				
LOT NO	BLOCK NO	SUBDIVISION NAME SIERRA HEALTH SERVICE		
FIRE DEPT. MAP NO. 2423-88	JOB PHONE 458-6579	CALL-IN DATE 01/21/92	CALL-IN TIME 14:53	SCHEDULE DATE 01/22/92
INSPECTOR NO. 68	INSPECTOR NAME JOHN CARSON			
INSPECTION REQUESTED BUILDING FINAL (140)				
458-6579 "FINAL" ① Smoke Seal Required on 1st Corridor doors. ② Identify emergency light circuits on sub-panel so that a test can be done. ③ Final fire is required. OK per 1-28-92				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE <i>E. Russell</i>		INSPECTION DATE 1-22-92		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6765

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

1	PERMIT NUMBER	92-131685	INSPECTION NUMBER	3
JOB ADDRESS				
888 S RANCHO DR				
LOT NO		BLOCK NO.		SUBDIVISION NAME
				SIERRA HEALTH SERVICE
FIRE DEPT. MAP NO.		JOB PHONE		CALL-IN DATE
2423-88		458-6579		01/16/92
				CALL-IN TIME
				12:05
				SCHEDULE DATE
				01/17/92
INSPECTOR NO.		INSPECTOR NAME		
58 57		JOHN CARSON		
INSPECTION REQUESTED		CEILING GRID (127)		
458-6579 OK 1-28-92				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T)	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071		☐ PERMIT REQUIRED	
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE		INSPECTION DATE		
R S Schmedes		1-17-92		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7 00 A.M. - 7:15 A.M OR 2:45 P.M. - 3 00 P.M. AT				229-6765

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

M	PERMIT NUMBER 92-131686	INSPECTION NUMBER 4
JOB ADDRESS 888 S RANCHO DR		
LOT NO. 1	BLOCK NO. 	SUBDIVISION NAME SIERRA HEALTH SERVICE
FIRE DEPT. MAP NO 2423-88	JOB PHONE 458-6579	CALL-IN DATE 01/10/92
		CALL-IN TIME 13:55
		SCHEDULE DATE 01/13/92
INSPECTOR NO. 68	INSPECTOR NAME JOHN CARSON	
INSPECTION REQUESTED DRYHALL NAILING (125)		
SOUTHWEST MEDICAL 		
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION OK 10-28-92
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)
		☐ TEMPORARY APPROVAL (T) — UNTIL
		☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL *229-2071	
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.	
		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE 	INSPECTION DATE 1-13-92	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)	
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT		
229-6765		

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☐ PERMIT NUMBER 92-131686		☐ INSPECTION NUMBER	
JOB ADDRESS 888 S. Rancho			
LOT NO.	BLOCK NO.	SUBDIVISION NAME	
FIRE DEPT. MAP NO.	JOB PHONE	CALL-IN DATE	CALL-IN TIME
INSPECTOR NO. 44		INSPECTOR NAME TIA ON COONEY	
INSPECTION REQUESTED		125 FARMING	
Room #110 & 125 OK TO TAPE Drywall OK # 399 JOE COWNER			
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION	
☒ APPROVED.. (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL
☐ REJECTED (R)		REINSPECTION REQUIRED - CALL * 799-2071	
☐ REFEE (F)		REINSPECTION FEE REQUIRED - PAY AT CITY HALL, 3RD FLOOR - 400 E. STEWART STREET.	
INSPECTOR SIGNATURE [Signature]		INSPECTION DATE 11-10-92	
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)	
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT			

FOR ADDITIONAL ASSISTANCE CALL *386-6251
SEE REVERSE SIDE FOR INSPECTION TYPES

* EFFECTIVE JULY 1, 1991
PHONE PREFIX WILL BE 229.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	92-131686	☒	INSPECTION NUMBER	13
JOB ADDRESS 388 S RANCHO DR					
LOT NO.		BLOCK NO.	SUBDIVISION NAME SIERRA HEALTH SERVICE		
FIRE DEPT MAP NO. 2423-88	JOB PHONE 458-6579	CALL-IN DATE 01/27/92	CALL-IN TIME 17:10	SCHEDULE DATE 01/28/92	
INSPECTOR NO. 68		INSPECTOR NAME JOHN CARSON			
INSPECTION REQUESTED		BUILDING FINAL (140)			
458-6579 also 940					
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION			
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)	
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071			☐ PERMIT REQUIRED	
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.				
INSPECTOR SIGNATURE <i>John Carson</i>		INSPECTION DATE 1-28-92			
☒ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT					229-6765

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	92-132339	INSPECTION NUMBER	6
JOB ADDRESS 888 S RANCHO DR				
LOT NO		BLOCK NO	SUBDIVISION NAME	
SIERRA HEALTH SERVICES				
FIRE DEPT MAP NO	JOB PHONE	CALL-IN DATE	CALL-IN TIME	SCHEDULE DATE
2423-88	362-6812	01/17/92	13:31	01/21/92
INSPECTOR NO		INSPECTOR NAME		
75		RON PATTERSON		
INSPECTION REQUESTED		FINAL ELECTRICAL (240)		
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL *229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE		<i>R. Patterson</i>		INSPECTION DATE <i>1-21-92</i>
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7 00 A.M. - 7:15 A.M OR 2 45 P.M - 3:00 P.M. AT				229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

1	PERMIT NUMBER	92-132339	INSPECTION NUMBER	6
JOB ADDRESS 888 S RANCHO DR				
LOT NO		BLOCK NO.	SUBDIVISION NAME SIERRA HEALTH SERVICES	
FIRE DEPT. MAP NO 2423-88	JOB PHONE 362-6812	CALL-IN DATE 01/17/92	CALL-IN TIME 13:31	SCHEDULE DATE 01/21/92
INSPECTOR NO. 75		INSPECTOR NAME RON PATTERSON		
INSPECTION REQUESTED		FINAL ELECTRICAL (240)		
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL *229-2071		☐ PERMIT REQUIRED	
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE <i>R. Patterson</i>		INSPECTION DATE <i>1-20-92</i>		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7 00 A.M. - 7:15 A.M OR 2:45 P.M - 3:00 P.M. AT				229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY - CITY OF LAS VEGAS


PERMIT NUMBER 92132339		INSPECTION NUMBER		
JOB ADDRESS: 800 S RANCHO SIERRA HEALTH				
LOT NO.		BLOCK NO.		SUBDIVISION NAME
FIRE DEPT MAP NO.	JOB PHONE	CALL-IN DATE 01/10/92	CALL-IN TIME 07:28	SCHEDULE DATE 01/13/92
INSPECTOR NO 75		INSPECTOR NAME PATTERSON, RON		
INSPECTION REQUESTED		220 ROUGH ELECTRICAL		
WALL Done 1-10-92				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE <i>R. Patterson</i>		INSPECTION DATE 1-13-92		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT ▶				

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

1	PERMIT NUMBER 92-131683	INSPECTION NUMBER 25		
JOB ADDRESS 838 S RANCHO DR				
LOT NO. 	BLOCK NO. 	SUBDIVISION NAME 		
FIRE DEPT MAP NO 2423-88	JOB PHONE 452-0906	CALL-IN DATE 01/06/92	CALL-IN TIME 14:52	SCHEDULE DATE 01/07/92
INSPECTOR NO. 61	INSPECTOR NAME TOM TAUBER			
INSPECTION REQUESTED TOP OUT-WATER, GAS, WASTE (420)				
Need to drop copper on S/east lw. (over head down wall.) App. pending above.				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION 		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE T. Tauber	INSPECTION DATE 1/7/92			
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M AT				229-6765

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

	PERMIT NUMBER	92131688	INSPECTION NUMBER	
JOB ADDRESS 888 S RANCHO DR				
LOT NO.		BLOCK NO.		SUBDIVISION NAME
FIRE DEPT MAP NO	JOB PHONE	CALL-IN DATE 01/02/92	CALL-IN TIME 1:05	SCHEDULE DATE 01/03/92
INSPECTOR NO. 81	INSPECTOR NAME TAUBER, TOM			
INSPECTION REQUESTED		407 UNDERSLAB PLUMBING		
<i>Handwritten notes:</i> 1. Check for proper installation of plumbing fixtures. 2. Verify that all plumbing work is done in accordance with the City of Las Vegas Plumbing Code. 3. Ensure that all plumbing work is done in accordance with the City of Las Vegas Building Code.				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE			INSPECTION DATE 1/3/92	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7 00 A.M. - 7:15 A.M OR 2:45 P.M. - 3:00 P.M. AT ▶				

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	92-131688	INSPECTION NUMBER	9
JOB ADDRESS				
888 S RANCHO DR				
LOT NO.		BLOCK NO.		SUBDIVISION NAME
FIRE DEPT. MAP NO.		JOB PHONE	CALL-IN DATE	CALL-IN TIME
2423-88		458-0906	01/17/92	13:36
SCHEDULE DATE		01/21/92		
INSPECTOR NO		INSPECTOR NAME		
81		TOM TAUBER		
INSPECTION REQUESTED		FINAL PLUMBING (440)		
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☒ APPROVED (A)		☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL
				☐ HOLD (H)
☐ REJECTED (R)		REINSPECTION REQUIRED - CALL * 229-2071		
☐ REFEE (F)		REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET		
☐ PERMIT REQUIRED				
INSPECTOR SIGNATURE			INSPECTION DATE	
<i>P. Paul</i>			1/21/92	
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6765

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	92-131686	INSPECTION NUMBER	2
JOB ADDRESS 883 S RANCHO DR				
LOT NO.		BLOCK NO.	SUBDIVISION NAME SIERRA HEALTH SERVICE	
FIRE DEPT MAP NO 2423-88	JOB PHONE 458-6579	CALL-IN DATE 01/21/92	CALL-IN TIME 14:53	SCHEDULE DATE 01/22/92
INSPECTOR NO. 68		INSPECTOR NAME JOHN CARSON		
INSPECTION REQUESTED		BUILDING FINAL (140)		
458-6579/"FINAL"				
① Smoke Seal Required on 1st Corridor doors. ② Identify emergency light circuits on sub-panel so that a test can be done. ③ Final fire is required.				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☐ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☒ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071		☐ PERMIT REQUIRED	
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E STEWART STREET			
INSPECTOR SIGNATURE	<i>E. Russell</i>		INSPECTION DATE 1-22-92	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6765


For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	92-131686		INSPECTION NUMBER	3	
JOB ADDRESS 888 S RANCHO DR						
LOT NO		BLOCK NO.		SUBDIVISION NAME SIERRA HEALTH SERVICE		
FIRE DEPT. MAP NO. 2423-88		JOB PHONE 458-6579		CALL-IN DATE 01/16/92	CALL-IN TIME 12:05	SCHEDULE DATE 01/17/92
INSPECTOR NO. 68 54		INSPECTOR NAME JOHN CARSON				
INSPECTION REQUESTED		CEILING GRID (127)				
458-6579						
☐ PARTIAL INSPECTION ☐ PARTIAL APPROVAL (P) PARTIAL DESCRIPTION						
☒ APPROVED (A) ☐ STOP WORK (S) ☐ COMMENTS (C) ☐ TEMPORARY APPROVAL (T) — UNTIL ☐ HOLD (H)						
☐ REJECTED (R) REINSPECTION REQUIRED - CALL * 229-2071 ☐ PERMIT REQUIRED						
☐ REFEE (F) REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.						
INSPECTOR SIGNATURE R S Schmeder				INSPECTION DATE 1-17-92		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)				
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT						229-6765

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

1	PERMIT NUMBER	92-132265	INSPECTION NUMBER	12
JOB ADDRESS 888 RANCHO LA				
LOT NO		BLOCK NO.		SUBDIVISION NAME SIERRA HEALTH SRVC
FIRE DEPT. MAP NO 2423-88	JOB PHONE 646-8306	CALL-IN DATE 01/13/92	CALL-IN TIME 13:58	SCHEDULE DATE 01/14/92
INSPECTOR NO. 81		INSPECTOR NAME TON TAUBER		
INSPECTION REQUESTED		ROUGH MECHANICAL (320)		
385-7546/CAT SCAN ROOM				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☒ APPROVED (A)		☐ STOP WORK (S)		
☐ REJECTED (R)		☐ COMMENTS (C)		☐ TEMPORARY APPROVAL (T) — UNTIL
☐ REFEE (F)		☐ HOLD (H)		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE		INSPECTION DATE		
		1/14/92		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6765



For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

CITY OF LAS VEGAS

[illegible]

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

X	PERMIT NUMBER	92-131688	INSPECTION NUMBER	25
JOB ADDRESS 888 S RANCHO DR				
LOT NO		BLOCK NO.	SUBDIVISION NAME	
FIRE DEPT. MAP NO. 2423-88	JOB PHONE 458-0906	CALL-IN DATE 01/06/92	CALL-IN TIME 14:52	SCHEDULE DATE 01/07/92
INSPECTOR NO. 81		INSPECTOR NAME TOM TAUBER		
INSPECTION REQUESTED		TOP OUT-WATER, GAS, WASTE (420)		
Need to strip copper on S/east low. (over head & dwn wall.) App. pending above. $\begin{array}{r} 25 \\ 13 \\ \hline 12 \end{array}$				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☒ APPROVED (A)		☐ STOP WORK (S)		
☐ REJECTED (R)		☐ COMMENTS (C)		☐ TEMPORARY APPROVAL (T) - UNTIL
☐ REFEE (F)		☐ REINSPECTION FEE REQUIRED - CALL *229-2071 ☐ REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.		☐ HOLD (H)
☐ PERMIT REQUIRED				
INSPECTOR SIGNATURE		INSPECTION DATE		
				
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6765

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

1	PERMIT NUMBER	92-132265	INSPECTION NUMBER	12
JOB ADDRESS				
888 RANCHO LA				
LOT NO.		BLOCK NO		SUBDIVISION NAME
				SIERRA HEALTH SRVC
FIRE DEPT. MAP NO.	JOB PHONE	CALL-IN DATE	CALL-IN TIME	SCHEDULE DATE
2423-88	646-8300	01/13/92	13:58	01/14/92
INSPECTOR NO.		INSPECTOR NAME		
81		TOM TAUBER		
INSPECTION REQUESTED				
ROUGH MECHANICAL (320)				
385-7548/CAT SCAN ROOM				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☒ APPROVED (A)		☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL
☐ REJECTED (R)		☐ REINSPECTION REQUIRED - CALL * 229-2071		☐ HOLD (H)
☐ REFEE (F)		☐ REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE			INSPECTION DATE	
			1/14/92	
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6765

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	92-131686	INSPECTION NUMBER	4
-------------------------------------	----------------------	-----------	--------------------------	---

JOB ADDRESS 883 S RANCHO DR				
LOT NO	BLOCK NO	SUBDIVISION NAME SIERRA HEALTH SERVICE		
FIRE DEPT. MAP NO. 2423-83	JOB PHONE 458-6579	CALL-IN DATE 01/10/92	CALL-IN TIME 13:55	SCHEDULE DATE 01/13/92
INSPECTOR NO. 68	INSPECTOR NAME JOHN CARSON			

INSPECTION REQUESTED	DRYWALL NAILING (125)
-----------------------------	-----------------------

SOUTHWEST MEDICAL

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE <i>John Carson</i>	INSPECTION DATE 1-13-92			
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7 15 A.M. OR 2 45 P.M. - 3.00 P.M. AT				229-6765

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	92132339	INSPECTION NUMBER	
JOB ADDRESS				
888 S RANCHO SIERRA HEALTH				
LOT NO.		BLOCK NO.		SUBDIVISION NAME
FIRE DEPT. MAP NO	JOB PHONE	CALL-IN DATE	CALL-IN TIME	SCHEDULE DATE
		01/10/92	07:28	01/13/92
INSPECTOR NO		INSPECTOR NAME		
75		PATTERSON, RON		
INSPECTION REQUESTED				
220 ROUGH ELECTRICAL				
WALL Done 1-10-92				
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL * 229-2071		☐ PERMIT REQUIRED	
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE		INSPECTION DATE		
R. Patterson		1-13-92		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

[illegible]☐ PARTIAL INSPECTION - DESCRIPTION

APPROVED

☐ PERMIT REQUIRED

☐ STOP WORK

REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071

INSPECT	DESCRIPTION		INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING		☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL – FORMS & REBAR		☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB		☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING		☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING		☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION		☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING		☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO				☐ E-1	UNDERGROUND ELETRICAL
☐ B-9	WALL GROUT & STEEL		☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	☐ POOL	PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	☐ POOL	PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL				☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC		☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 386-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS <i>888 S. Rancho Dr.</i>		PERMIT NO. <i>07365</i>	
LOT NO.	MAP NO. <i>2-922a</i>	INSPECTOR <i>75</i>	DATE <i>11-6-90</i>
SUBDIVISION NAME <i>SUNM</i>			PHONE <i>645-7020</i>
INSPECTOR SIGNATURE <i>A. Patterson</i>			INSPECTION DATE <i>11-7-90</i>

*hole
sign*

AM

382-1871

(No Plans or Permit on site)

☐ PARTIAL INSPECTION - DESCRIPTION:

Return on or before 11-14-90

☐ APPROVED
 ☐ PERMIT REQUIRED
 ☐ STOP WORK

☒ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071


INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 386-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 RANCHO			PERMIT NO. 084788
LOT NO.	MAP NO. 12 3:46P	INSPECTOR 81	DATE 10-27-90
SUBDIVISION NAME SIERRA HEALTH SERVICES			PHONE
INSPECTOR SIGNATURE 			INSPECTION DATE 10/30/90

"Rough Duct"

Need to install exhaust fans & connect duct thereto. Also condenser lines do not have proper grade or do not have hanger's installed.

☐ PARTIAL INSPECTION - DESCRIPTION

☐ APPROVED
 ☐ PERMIT REQUIRED
 ☐ STOP WORK

☒ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER.
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☒ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	<u>POOL</u> PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	<u>POOL</u> PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 386-8251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS <i>888 Ranch</i>		PERMIT NO. <i>078788</i>	
LOT NO	MAP NO <i>17 12:27</i>	INSPECTOR <i>81</i>	DATE <i>10-30-90</i>
SUBDIVISION NAME <i>Surra Health Services</i>			PHONE
INSPECTOR SIGNATURE <i>J.P. Paul</i>			INSPECTION DATE <i>11/1/90</i>

Need to install grade to condense
lines

☐ PARTIAL INSPECTION - DESCRIPTION.

☐ APPROVED

☐ PERMIT REQUIRED

☐ STOP WORK

☒ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELETRICAL
☐ B-9	WALL GROUT & STEEL	☒ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	<u>POOL</u> PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	<u>POOL</u> PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 366-8251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS H.H.S. Rancho		PERMIT NO. 084788	
LOT NO	MAP NO 18 9-26/A	INSPECTOR 81	DATE 11-1-90
SUBDIVISION NAME Sierra			PHONE
INSPECTOR SIGNATURE [Signature]			INSPECTION DATE 11/2/90

Condensate line have grade.

m-1 approved
 m-3 partial need to
 complete installation of register's
 Also need to install exhaust fans in
 bathrms.

☒ PARTIAL INSPECTION - DESCRIPTION.

m-3

☒ APPROVED m-1

☐ PERMIT REQUIRED

☐ STOP WORK

☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071


INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELETRICAL
☐ B-9	WALL GROUT & STEEL	☒ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☒ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
 SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 368-8251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 Rancho			PERMIT NO 81788
LOT NO	MAP NO 5 1:26P	INSPECTOR 81	DATE 11-2-90
SUBDIVISION NAME			PHONE
INSPECTOR SIGNATURE 			INSPECTION DATE 11/5/90

Exhaust Fans not installed in bathrooms.

*partial was given on 11/2/90
have needs to be completed for
final.*

☐ PARTIAL INSPECTION - DESCRIPTION

☒ APPROVED

☐ PERMIT REQUIRED

☐ STOP WORK

☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL — FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER:
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELETRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☒ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 386-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

[illegible]

FOR ASSISTANCE -CALL: 386-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. Rancho			PERMIT NO. 80312
LOT NO	MAP NO 2 11:19A	INSPECTOR 75	DATE 11-1-90
SUBDIVISION NAME Southwest Medical			PHONE
INSPECTOR SIGNATURE R. Patterson			INSPECTION DATE 11-2-90 P.M.

T I

☒ PARTIAL INSPECTION - DESCRIPTION:					
Ceiling					
☒ APPROVED		☐ PERMIT REQUIRED		☐ STOP WORK	
☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071					
INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELETTRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☒ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☒ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☒ E-5	FINAL ELECTRICAL
☐ B-13	CERT. OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER
☐ FINAL INSPECTION		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)			

FOR ASSISTANCE -CALL: 386-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. Rancho		PERMIT NO. 080312
LOT NO	MAP NO. 14 124/p	INSPECTOR 75
SUBDIVISION NAME		DATE 11-2-90
INSPECTOR SIGNATURE ▷ R. Patterson		PHONE
		INSPECTION DATE 11-5-90

Not ready

☐ PARTIAL INSPECTION - DESCRIPTION:

☐ APPROVED

☐ PERMIT REQUIRED

☐ STOP WORK

☒ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELETRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	<u>POOL</u> PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	<u>POOL</u> PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☒ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 386-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. Rancho		PERMIT NO 80312	
LOT NO.	MAP NO 14-844A	INSPECTOR 75	DATE 11-6-90
SUBDIVISION NAME			PHONE
INSPECTOR SIGNATURE 			INSPECTION DATE 11-7-90
<i>Emergency generator test to be done at later date within 7 days</i>			
☒ PARTIAL INSPECTION - DESCRIPTION: 			
☒ APPROVED		☐ PERMIT REQUIRED	☐ STOP WORK
☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071			

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRY WALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELETRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	☐ POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	☐ POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☒ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
 SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 8.8.8. 88 Ranch		PERMIT NO 80312	
LOT NO.	MAP NO.	INSPECTOR 75	DATE
SUBDIVISION NAME			PHONE
INSPECTOR SIGNATURE R. Patterson			INSPECTION DATE 11-13-90
4 AM. Emergency Generator & Lighting test in new add.			
☐ PARTIAL INSPECTION - DESCRIPTION			
☒ APPROVED		☐ PERMIT REQUIRED	
☐ REJECTED - CORRECTION		☐ STOP WORK	
☐ NOTICE - REINSPECTION REQUIRED CALL 799-2071			
INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING
☐ B-8	EXTERIOR LATH/STUCCO		
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT
☐ B-10	☐ POOL PRE-GUNITE	☐ M-2	HOOD
☐ B-11	☐ POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL
☐ B-12	BUILDING FINAL		
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH
		☐ X-2	UNDERGROUND HYDRO
		☐ X-3	UNDERGROUND FINAL/FLOW
		☐ X-4	SPRINKLER SYSTEM HYDRO
		☐ X-5	FIRE ALARM
		☐ X-6	OTHER
		☐ X-7	FINAL FIRE
		☐ E-1	UNDERGROUND ELETRICAL
		☐ E-2	ROUGH ELECTRICAL
		☐ E-3	LOW VOLTAGE ELECTRICAL
		☐ E-4	SIGN INSPECTION
		☒ E-5	FINAL ELECTRICAL
		☐ E-6	TEMP POWER
☐ FINAL INSPECTION		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O ISSUANCE (Commercial Only)	

FOR ASSISTANCE -CALL: 386-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS <i>888 S. Rancho</i>		PERMIT NO. <i>79247</i>	
LOT NO.	MAP NO. <i>14-2590</i>	INSPECTOR <i>81</i>	DATE <i>8/31/90</i>
SUBDIVISION NAME <i>Radiology Associates</i>		PHONE <i>51-7488</i>	
INSPECTOR SIGNATURE <i>[Signature]</i>		INSPECTION DATE <i>8/4/90</i>	

Am

☐ PARTIAL INSPECTION - DESCRIPTION:

☒ **APPROVED**
☐ **PERMIT REQUIRED**
☐ **STOP WORK**

☐ **REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071**

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL — FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☒ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELETRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL- 306-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS <i>888 S. Rancho</i>		PERMIT NO. <i>79247</i>	
LOT NO.	MAP NO. <i>10-240p</i>	INSPECTOR <i>81</i>	DATE <i>8-30-90</i>
SUBDIVISION NAME			PHONE <i>871-7488</i>
INSPECTOR SIGNATURE <i>J.P. Paul</i>			INSPECTION DATE <i>8/31/90</i>

partial

need to connect to bldg

sewer.

pm

☒ PARTIAL INSPECTION - DESCRIPTION

☐ APPROVED		☐ PERMIT REQUIRED		☐ STOP WORK	
☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071					
INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☒ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELETRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ FINAL INSPECTION	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)
--	--

FOR ASSISTANCE -CALL: 386-8251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 So. Rancho			PERMIT NO.		
LOT NO		MAP NO		INSPECTOR 86	
SUBDIVISION NAME					DATE
INSPECTOR SIGNATURE M. Hal					INSPECTION DATE 10-1-90

- 1/2 Water pipe drops must be secured so as not to Rattle

- Nail plate waste lines at Bottom plate

- Isolate Copper water pipe from Elec. Conduit

☐ PARTIAL INSPECTION - DESCRIPTION.

☒ **APPROVED**

☐ **PERMIT REQUIRED**

☐ **STOP WORK**

☐ **REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071**

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☒ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
 SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL- 388-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. Rancho Rd			PERMIT NO. 79247
LOT NO.	MAP NO. 11-1045A	INSPECTOR 81	DATE 10-31-90
SUBDIVISION NAME			PHONE 8717488
INSPECTOR SIGNATURE [Signature]			INSPECTION DATE 11/2/90

need to complete installation
of lvs.

☒ PARTIAL INSPECTION - DESCRIPTION

☐ APPROVED
 ☐ PERMIT REQUIRED
 ☐ STOP WORK
☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☒ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELETRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)


FOR ASSISTANCE -CALL: 386-8251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

[illegible]

FOR ASSISTANCE -CALL: 386-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 So. Pancho		PERMIT NO. In Office	
LOT NO	MAP NO	INSPECTOR 81	DATE
SUBDIVISION NAME			PHONE
INSPECTOR SIGNATURE 			INSPECTION DATE 3/28/89
Under ground gas installed and sleeved correctly.			
☐ PARTIAL INSPECTION - DESCRIPTION			
☒ APPROVED ☐ PERMIT REQUIRED ☐ STOP WORK			
☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 793-2071			
INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE
☐ B-6	INSULATION	☒ P-6	FINAL GAS TEST
☐ B-7	DRYWALL NAILING	☒ P-7	FINAL PLUMBING
☐ B-8	EXTERIOR LATH/STUCCO		
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT
☐ B-10	☐ POOL PRE-GUNITE	☐ M-2	HOOD
☐ B-11	☐ POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL
☐ B-12	BUILDING FINAL		
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH
		☐ X-2	UNDERGROUND HYDRO
		☐ X-3	UNDERGROUND FINAL/FLOW
		☐ X-4	SPRINKLER SYSTEM HYDRO
		☐ X-5	FIRE ALARM
		☐ X-6	OTHER
		☐ X-7	FINAL FIRE
		☐ E-1	UNDERGROUND ELETRICAL
		☐ E-2	ROUGH ELECTRICAL
		☐ E-3	LOW VOLTAGE ELECTRICAL
		☐ E-4	SIGN INSPECTION
		☐ E-5	FINAL ELECTRICAL
		☐ E-6	TEMP POWER
☐ FINAL INSPECTION		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O ISSUANCE (Commercial Only)	

FOR TECHNICAL ASSISTANCE - CALL: 799-6916

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS <i>888 S. Rancho Dr.</i>		PERMIT NO. <i>07315</i>	
LOT NO.	MAP NO. <i>2-922a</i>	INSPECTOR <i>75</i>	DATE <i>11-6-90</i>
SUBDIVISION NAME <i>SWM</i>		PHONE <i>645-7020</i>	
INSPECTOR SIGNATURE <i>A. Patterson</i>		INSPECTION DATE <i>11-7-90</i>	
<i>note sign</i>		<i>322-1871</i>	
<i>To Place or Permit on site</i>			

☐ PARTIAL INSPECTION - DESCRIPTION:

Return on or before 11-13-90

☐ APPROVED

☐ PERMIT REQUIRED

☐ STOP WORK

☒ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	<u>POOL</u> PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	<u>POOL</u> PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 393-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. Ranch		PERMIT NO. 91-098625	
LOT NO.	MAP NO. 2:50p	INSPECTOR 75	DATE 3/7/91
SUBDIVISION NAME S.W. Medical Center		PHONE 362-6282	
INSPECTOR SIGNATURE R. Patterson		INSPECTION DATE 3-8-91	
Ceiling Electrical		Holland + Holland	

T I

☐ PARTIAL INSPECTION - DESCRIPTION

☒ **APPROVED**

☐ **PERMIT REQUIRED**

☐ **STOP WORK**

☐ **REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 792-2071**

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL -- FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☒ E-2	ROUGH ELECTRICAL
☐ B-10	<u>POOL</u> PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	<u>POOL</u> PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC.	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 393-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

[illegible]☐ PARTIAL INSPECTION - DESCRIPTION:

☒ **APPROVED**

☐ PERMIT REQUIRED

☐ STOP WORK

REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071

INSPECT	DESCRIPTION		INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING		☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL – FORMS & REBAR		☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB		☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING		☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING		☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION		☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING		☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO				☐ E-1	UNDERGROUND ELETRICAL
☐ B-9	WALL GROUT & STEEL		☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL	PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL	PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☒ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL				☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC		☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 386-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. Rancho		PERMIT NO. 74853	
LOT NO	MAP NO 14-460	INSPECTOR CF	DATE 10-1-90
SUBDIVISION NAME Sierra Health		PHONE 848-687	
INSPECTOR SIGNATURE 		INSPECTION DATE 10-2-90	
wall framing - Radiology			
Interior Remodel			
Frame - Rejected			
1) Seal Penetrations			
2) See Sheet A-Z for Framing details			

☐ PARTIAL INSPECTION - DESCRIPTION.

☒ **APPROVED**

☐ **PERMIT REQUIRED**

☐ **STOP WORK**

☐ **REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071**

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☒ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELETRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 396-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. Rancho			PERMIT NO. 74853	
LOT NO.	MAP NO. 4-1206P	INSPECTOR 68	DATE 10-3-90	
SUBDIVISION NAME			PHONE 458-6579	
INSPECTOR SIGNATURE			INSPECTION DATE 10-5-90 AM	

Interior Remodel

Frame - OK

☐ PARTIAL INSPECTION - DESCRIPTION.

☒ **APPROVED**

☐ **PERMIT REQUIRED**

☐ **STOP WORK**

☐ **REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071**

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☒ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	<u>POOL</u> PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	<u>POOL</u> PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 386-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS <i>888 S. Rancho</i>		PERMIT NO. <i>74853</i>	
LOT NO.	MAP NO. <i>S-850a</i>	INSPECTOR <i>Leif</i>	DATE <i>11-15-90</i>
SUBDIVISION NAME			PHONE
INSPECTOR SIGNATURE <i>A Carson</i>			INSPECTION DATE <i>11-16-90</i>

also Grid Ctg approved

☐ PARTIAL INSPECTION - DESCRIPTION:

☒ **APPROVED**
☐ **PERMIT REQUIRED**
☐ **STOP WORK**

☐ **REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 793-2071**

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELETRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	☐ POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	☐ POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☒ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☒ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☒ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 393-3251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. Ranchos		PERMIT NO. 076622	
LOT NO	MAP NO. 5 3:18 p	INSPECTOR 68	DATE 9-12-90
SUBDIVISION NAME			PHONE 458-6579
INSPECTOR SIGNATURE Carson		INSPECTION DATE 9-14-90	

- ① Ro. ELEC. Req.
- ② Facing on insu. to Be removed
- ③. Brace walls to structure ABOVE

☐ PARTIAL INSPECTION - DESCRIPTION:

☐ APPROVED

☐ PERMIT REQUIRED

☐ STOP WORK

☒ **REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071**

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☒ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 393-8251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. RANCHO		PERMIT NO. 76622	
LOT NO	MAP NO	INSPECTOR 64	DATE
SUBDIVISION NAME			PHONE
INSPECTOR SIGNATURE 			INSPECTION DATE 10/1/90
LEADED SHEETROCK ONLY GOES UP TO 7' APPROVED PRINTS SHOW IT UP TO 8' DETAIL A OF SHEET A2 SHOWS 2 LAYERS OF 5/8" ROCK BEHIND 1 LAYER OF 5/8" LEADED ROCK OVER 1 1/2" METAL STUDS @ 16" O.C.			
☒ PARTIAL INSPECTION - DESCRIPTION			
☐ APPROVED		☐ PERMIT REQUIRED	
☒ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071			
INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST
☒ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING
☐ B-8	EXTERIOR LATH/STUCCO		
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL
☐ B-12	BUILDING FINAL		
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH
		☐ X-2	UNDERGROUND HYDRO
		☐ X-3	UNDERGROUND FINAL/FLOW
		☐ X-4	SPRINKLER SYSTEM HYDRO
		☐ X-5	FIRE ALARM
		☐ X-6	OTHER
		☐ X-7	FINAL FIRE
		☐ E-1	UNDERGROUND ELETRICAL
		☐ E-2	ROUGH ELECTRICAL
		☐ E-3	LOW VOLTAGE ELECTRICAL
		☐ E-4	SIGN INSPECTION
		☐ E-5	FINAL ELECTRICAL
		☐ E-6	TEMP POWER
☐ FINAL INSPECTION		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)	

FOR ASSISTANCE -CALL: 386-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS <i>888 S. Rancho</i>		PERMIT NO. <i>76622</i>	
LOT NO.	MAP NO. <i>1-327p</i>	INSPECTOR <i>68</i>	DATE <i>10-3-90</i>
SUBDIVISION NAME			PHONE <i>458-6579</i>
INSPECTOR SIGNATURE 			INSPECTION DATE <i>10-4-90</i>

Frame - Rejected

☐ PARTIAL INSPECTION - DESCRIPTION:

☐ APPROVED
 ☐ PERMIT REQUIRED
 ☐ STOP WORK

☒ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071

ASPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☒ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELETRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	<u>POOL</u> PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	<u>POOL</u> PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC.	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 393-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. Rancho			PERMIT NO. 80312		
LOT NO.		MAP NO. 1-823A	INSPECTOR 68	DATE 9-20-90	
SUBDIVISION NAME				PHONE	
INSPECTOR SIGNATURE 				INSPECTION DATE 9-21-90	
"partial wall rough"					
Interior Remodel					
Frame - Rejected					
1) Rough Electric Not signed					
2) Facing on Insulation to be removed					
☐ PARTIAL INSPECTION - DESCRIPTION:					
☐ APPROVED		☐ PERMIT REQUIRED		☐ STOP WORK	
☒ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071					
INSPECT	DESCRIPTION		INSPECT	DESCRIPTION	
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING		☐ P-1	ON SITE SEWER	
☐ B-2	STEM WALL -- FORMS & REBAR		☐ P-2	ON SITE WATER	
☐ B-3	PRE-SLAB		☐ P-3	BUILDING SEWER (YARD LINES)	
☐ B-4	ROOF SHEATHING		☐ P-4	UNDERSLAB PLUMBING	
☒ B-5	FRAMING		☐ P-5	TOP OUT-WATER, GAS, WASTE	
☒ B-6	INSULATION		☐ P-6	FINAL GAS TEST	
☐ B-7	DRYWALL NAILING		☐ P-7	FINAL PLUMBING	
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1 UNDERGROUND ELETRICAL	
☐ B-9	WALL GROUT & STEEL		☐ M-1	ROUGH VENT	
☐ B-10	☐ POOL	PRE-GUNITE	☐ M-2	HOOD	
☐ B-11	☐ POOL	PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	
☐ B-12	BUILDING FINAL			☐ E-5 FINAL ELECTRICAL	
☐ B-13	CERT OF OCC		☐ X-1	KICKER / FLUSH	
			☐ E-6	TEMP POWER	
☐ FINAL INSPECTION		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)			

FOR ASSISTANCE -CALL: 386-6251

JOB ADDRESS 888 S. Rancho		PERMIT NO. 84810
LOT NO.	MAR NO. 8-1041a	INSPECTOR 68
SUBDIVISION NAME Radiology Remodel		DATE 10-5-90
INSPECTOR SIGNATURE J. Carson		PHONE 458-6579
INSPECTION DATE 10-8-90		

Am - early

☒ APPROVED	☐ PERMIT REQUIRED	☐ STOP WORK
---	---	---

INSPECT	DESCRIPTION		INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING		☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL – FORMS & REBAR		☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB		☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING		☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING		☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION		☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☒ B-7	DRY WALL NAILING		☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO				☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL		☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	☐ POOL	PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	☐ POOL	PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL				☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC		☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 386-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS <i>888 S. Karcho</i>		PERMIT NO. <i>84810</i>	
LOT NO.	MAP NO. <i>2-1033a</i>	INSPECTOR <i>68</i>	DATE <i>10-15-90</i>
SUBDIVISION NAME		PHONE <i>458-6579</i>	
INSPECTOR SIGNATURE <i>Wall J. Carson</i>		INSPECTION DATE <i>10-16-90</i>	

Not per detail: A/
AC

☐ PARTIAL INSPECTION - DESCRIPTION.

☐ APPROVED

☐ PERMIT REQUIRED

☐ STOP WORK

☒ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELETRICAL
☒ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	<u>POOL</u> PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	<u>POOL</u> PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 393-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS <i>888 S Rancho</i>		PERMIT NO. <i>84810</i>	
LOT NO	MAP NO. <i>11-246p</i>	INSPECTOR <i>LG</i>	DATE <i>10-16-90</i>
SUBDIVISION NAME		PHONE <i>458-1579</i>	
INSPECTOR SIGNATURE <i>[Signature]</i>		INSPECTION DATE <i>10-17-90</i>	

masonry wall - am

☐ PARTIAL INSPECTION - DESCRIPTION

☒ **APPROVED**
☐ **PERMIT REQUIRED**
☐ **STOP WORK**

☐ **REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071**

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER.
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL, NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELETRICAL
☒ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 383-8251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

X	PERMIT NUMBER	92131688	INSPECTION NUMBER		
JOB ADDRESS 888 S RANCHO DR					
LOT NO		BLOCK NO.		SUBDIVISION NAME	
FIRE DEPT MAP NO		JOB PHONE		CALL-IN DATE 01/02/92	CALL-IN TIME 16:05
SCHEDULE DATE 01/03/92					
INSPECTOR NO 81		INSPECTOR NAME TAUBER, TOM			
INSPECTION REQUESTED		407 UNDERSLAB PLUMBING			
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION	
☒ APPROVED (A)		☐ STOP WORK (S)		☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL
☐ REJECTED (R)		☐ HOLD (H)			
☐ REFEE (F)		REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
☐ PERMIT REQUIRED					
INSPECTOR SIGNATURE		<i>R.P. Taub</i>		INSPECTION DATE 1/3/92	
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O ISSUANCE (Commercial Only)			
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT					

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. Rancho dr.		PERMIT NO. 98235	
LOT NO.	MAP NO. 10 12:47p	INSPECTOR 80	DATE 3/20/91
SUBDIVISION NAME			PHONE
INSPECTOR SIGNATURE J. G. [Signature]			INSPECTION DATE 3/21/91

☐ PARTIAL INSPECTION - DESCRIPTION:

☒ **APPROVED**

☐ PERMIT REQUIRED

☐ STOP WORK

☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 790-2071

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☒ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	<u>POOL</u> PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	<u>POOL</u> PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 300-0251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS: <i>888 S. Kancho</i>		PERMIT NO. <i>98235</i>
LOT NO.	MAP NO. <i>8-215f</i>	INSPECTOR <i>80</i>
SUBDIVISION NAME		DATE <i>2-26-91</i>
		PHONE
INSPECTOR SIGNATURE <i>Tom Nguyen</i>		INSPECTION DATE <i>2-27-91</i>

☐ PARTIAL INSPECTION - DESCRIPTION.

☒ **APPROVED**

 ☐ **PERMIT REQUIRED**

 ☐ **STOP WORK**

☐ **REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071**

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☒ P-5	TOP OUT WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELETRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 386-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 1888 S. Rancho		PERMIT NO. 98191	
LOT NO	MAP NO 6- 9.02A	INSPECTOR 80	DATE 3-20-91
SUBDIVISION NAME S.W. Medical			PHONE
INSPECTOR SIGNATURE [Signature]			INSPECTION DATE 3/21/91

No approved plans on job.
Need to install supply duct in
south west rm.

☐ PARTIAL INSPECTION - DESCRIPTION:

☐ APPROVED

☐ PERMIT REQUIRED

☐ STOP WORK

☒ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 790-2071

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELETRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☒ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 393-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. Rancho		PERMIT NO. 98191	
LOT NO	MAP NO 16 2:58p.	INSPECTOR 80	DATE 2-26-91
SUBDIVISION NAME			PHONE
INSPECTOR SIGNATURE Don Gregorio			INSPECTION DATE 2-27-91
S.W. Medical			
☐ PARTIAL INSPECTION - DESCRIPTION			
☒ APPROVED ☐ PERMIT REQUIRED ☐ STOP WORK			
☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071			
INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING
☐ B-8	EXTERIOR LATH/STUCCO	☐ E-1	UNDERGROUND ELETTRICAL
☐ B-9	WALL GROUT & STEEL	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL	☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ E-6	TEMP POWER
☐ M-1	ROUGH VENT		
☐ M-2	HOOD		
☐ M-3	FINAL MECHANICAL		
☐ X-1	KICKER / FLUSH		
☐ FINAL INSPECTION		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)	

FOR ASSISTANCE -CALL- 388-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☐ PERMIT NUMBER 98191		☐ INSPECTION NUMBER 81	
JOB ADDRESS 888 S. Rancho			
LOT NO	BLOCK NO.	SUBDIVISION NAME	
FIRE DEPT MAP NO	JOB PHONE	CALL-IN DATE 3-21-91	CALL-IN TIME 11-11:00A
SCHEDULE DATE			
INSPECTOR NO. 80	INSPECTOR NAME		
INSPECTION REQUESTED 340 - Final Mechanical			
☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION	
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL
			☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL 799-2071		☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.		
INSPECTOR SIGNATURE [Signature]		INSPECTION DATE 3/22/91	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7 00 A.M - 7 15 A.M OR 2:45 P.M - 3:00 P.M AT			

FOR ADDITIONAL ASSISTANCE CALL 386-6251
SEE REVERSE SIDE FOR INSPECTION TYPES

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S Rancho Dr		PERMIT NO. 95506	
LOT NO.	MAP NO 1-301P	INSPECTOR 68	DATE 3-21-91
SUBDIVISION NAME			PHONE 458-6579
INSPECTOR SIGNATURE Carson JE			INSPECTION DATE 3-25-91

"final" bldg

Subject to Fire Dept Final and Suite No. on Front Exit Door.

☐ PARTIAL INSPECTION - DESCRIPTION:

☒ **APPROVED**

☐ PERMIT REQUIRED

☐ STOP WORK

☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 789-2071

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELETRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☒ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☒ B-13	CERT OF OCC.	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☒ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE - CALL: 386-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. Rancho			PERMIT NO. 95506
LOT NO. 11	MAP NO. 3 1:22p	INSPECTOR 55 68	DATE 3-5-91
SUBDIVISION NAME			PHONE 4586579
INSPECTOR SIGNATURE 			INSPECTION DATE 3-6-91

☐ PARTIAL INSPECTION - DESCRIPTION

☒ **APPROVED**

☐ **PERMIT REQUIRED**

☐ **STOP WORK**

☐ **REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071**

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☒ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 393-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. Rancho Dr.		PERMIT NO. 95506
LOT NO. 7	MAP NO 1:50p	INSPECTOR 68
SUBDIVISION NAME		DATE 2-28-91
INSPECTOR SIGNATURE Carson		PHONE 4586579
		INSPECTION DATE 3-1-91

Interior

subject to :

- ① Brace new walls in center
- ② Seal holes in corridor walls - (main corridor of Bld.)
- ③ WEST WALL - seal holes in draft stop.

Completed
3-25-91/jc

☐ PARTIAL INSPECTION - DESCRIPTION

☒ **APPROVED**
☐ **PERMIT REQUIRED**
☐ **STOP WORK**

☐ **REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071**

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☒ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 388-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S Rancho Dr		PERMIT NO. 95506	
LOT NO.	MAP NO 1-301P	INSPECTOR 68	DATE 3-21-91
SUBDIVISION NAME			PHONE 458-6579
INSPECTOR SIGNATURE Carson JE			INSPECTION DATE 3-25-91

"final" bldg

*Subject to Fire Dept Final
and Suite No. on Front
Exit Door.*

☐ PARTIAL INSPECTION - DESCRIPTION:

☒ **APPROVED**
☐ **PERMIT REQUIRED**
☐ **STOP WORK**
☐ **REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 793-2071**

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☒ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☒ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☒ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE - CALL: 393-8251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☐ PERMIT NUMBER 98191		☐ INSPECTION NUMBER 81	
JOB ADDRESS 888 S. Rancho			
LOT NO.	BLOCK NO.	SUBDIVISION NAME	
FIRE DEPT MAP NO.	JOB PHONE.	CALL-IN DATE 3-21-91	CALL-IN TIME 11-11:00A
INSPECTOR NO. 80	INSPECTOR NAME		
INSPECTION REQUESTED 340 - Final Mechanical			

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION	
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) - UNTIL
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL 799-2071		☐ HOLD (H)
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE <i>[Signature]</i>		INSPECTION DATE 3/22/91	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		

IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7 15 A.M. OR 2:45 P.M. - 3 00 P.M. AT

FOR ADDITIONAL ASSISTANCE CALL 386-6251
SEE REVERSE SIDE FOR INSPECTION TYPES

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S Rancho		PERMIT NO. 98625	
LOT NO.	MAP NO. 2-127a	INSPECTOR 75	DATE 3-27-91
SUBDIVISION NAME SW M		PHONE 362-6812	
INSPECTOR SIGNATURE R. Butters		INSPECTION DATE 3-28-91	

TI

NOTE (ALL WIRING TO CONDUIT NOT IN USE TO BE REMOVED TO NEAREST PANEL)

☒ PARTIAL INSPECTION - DESCRIPTION. Walls only			
☒ APPROVED		☐ PERMIT REQUIRED	
☐ STOP WORK			
☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071			
INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING
☐ B-8	EXTERIOR LATH/STUCCO		
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL
☐ B-12	BUILDING FINAL		
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH
		☐ X-2	UNDERGROUND HYDRO
		☐ X-3	UNDERGROUND FINAL/FLOW
		☐ X-4	SPRINKLER SYSTEM HYDRO
		☐ X-5	FIRE ALARM
		☐ X-6	OTHER
		☐ X-7	FINAL FIRE
		☐ E-1	UNDERGROUND ELECTRICAL
		☒ E-2	ROUGH ELECTRICAL
		☐ E-3	LOW VOLTAGE ELECTRICAL
		☐ E-4	SIGN INSPECTION
		☐ E-5	FINAL ELECTRICAL
		☐ E-6	TEMP POWER

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 386-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☐	PERMIT NUMBER 91-098624	INSPECTION NUMBER		
JOB ADDRESS 888 S. Rancho				
LOT NO.		BLOCK NO.	SUBDIVISION NAME	
FIRE DEPT MAP NO.	JOB PHONE	CALL-IN DATE 3-21-91	CALL-IN TIME	SCHEDULE DATE 3-22-91
INSPECTOR NO 75 per 75		INSPECTOR NAME A. Patterson		
INSPECTION REQUESTED		240- F/Elec.		

TJ

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION		
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL	☐ HOLD (H)
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL 799-2071			☐ PERMIT REQUIRED
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.			
INSPECTOR SIGNATURE A. Patterson		INSPECTION DATE 3-22-91		
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O ISSUANCE (Commercial Only)			

IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT

FOR ADDITIONAL ASSISTANCE CALL 386-6251
SEE REVERSE SIDE FOR INSPECTION TYPES

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☐ PERMIT NUMBER 91-098625		INSPECTION NUMBER	
JOB ADDRESS 888 S. Ranchos			
LOT NO	BLOCK NO	SUBDIVISION NAME	
FIRE DEPT MAP NO	JOB PHONE	CALL-IN DATE 3-21-91	CALL-IN TIME
INSPECTOR NO. 75 Per 75		INSPECTOR NAME A. Patterson	
INSPECTION REQUESTED 240- F/Elec.		SCHEDULE DATE 3-22-91	

TJ

☐ PARTIAL INSPECTION	☐ PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION	
☒ APPROVED (A)	☐ STOP WORK (S)	☐ COMMENTS (C)	☐ TEMPORARY APPROVAL (T) — UNTIL
☐ REJECTED (R)	REINSPECTION REQUIRED - CALL 799-2071		☐ HOLD (H)
☐ REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE A. Patterson		INSPECTION DATE 3-22-91	
☐ PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT			

FOR ADDITIONAL ASSISTANCE CALL 386-6251
SEE REVERSE SIDE FOR INSPECTION TYPES

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

[illegible]

FOR ASSISTANCE -CALL: 388-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. Rancho Rd		PERMIT NO. 098625	
LOT NO.	MAP NO. 4	INSPECTOR 75	DATE 3-20-91
SUBDIVISION NAME SW. Med. Ctr.			PHONE 3626812
INSPECTOR SIGNATURE A. Patterson			INSPECTION DATE 3-21-91

3:00 pm
is when generator
comes on.

**NOT Ready will be
back tomorrow**

☐ PARTIAL INSPECTION - DESCRIPTION:

☐ APPROVED

☐ PERMIT REQUIRED

☐ STOP WORK

☒ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☒ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC.	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 366-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. Rancho			PERMIT NO. 98191
LOT NO.	MAP NO 6 9:02A	INSPECTOR 80	DATE 3-20-91
SUBDIVISION NAME S.W. Medical			PHONE
INSPECTOR SIGNATURE J. J. Paul			INSPECTION DATE 3/21/91

No approved plans on job.
Need to install supply duct in
south west rm.

☐ PARTIAL INSPECTION - DESCRIPTION:

☐ APPROVED
 ☐ PERMIT REQUIRED
 ☐ STOP WORK

☒ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL -- FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☒ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 396-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS <i>888 S Rancho Dr</i>			PERMIT NO. <i>98764</i>
LOT NO.	MAP NO. <i>13-122P</i>	INSPECTOR <i>75</i>	DATE <i>3-4-91</i>
SUBDIVISION NAME <i>S.W. Medical</i>			PHONE <i>362-9878</i>
INSPECTOR SIGNATURE <i>R. Batterson</i>			INSPECTION DATE <i>3-5-91</i>

NEVCO

TI

☐ PARTIAL INSPECTION - DESCRIPTION

☒ APPROVED	☐ PERMIT REQUIRED	☐ STOP WORK
☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071		

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☒ E-2	ROUGH ELECTRICAL
☐ B-10	☐ POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	☐ POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE - CALL: 393-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. Rancho Dr.			PERMIT NO. 95506
LOT NO	MAP NO 10 9:31a	INSPECTOR 68	DATE 3-1-91
SUBDIVISION NAME			PHONE 4586579
INSPECTOR SIGNATURE ▶ Carson			INSPECTION DATE 3-4-91

Sheet Rock/Nailing

Cancelled

☐ PARTIAL INSPECTION - DESCRIPTION:

☐ **APPROVED**

☐ **PERMIT REQUIRED**

☐ **STOP WORK**

☐ **REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071**

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☒ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	<u>POOL</u> PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	<u>POOL</u> PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 386-8251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. Rancho Dr.		PERMIT NO 95506
LOT NO	MAP NO 7 1:50p.	INSPECTOR 68
SUBDIVISION NAME		DATE 2-28-91
INSPECTOR SIGNATURE Carson		PHONE 4586579
		INSPECTION DATE 3-1-91

Interior

subject to :

- ① Brace new walls in center
- ② Seal holes in corridor walls - (main corridor of Bld.)
- ③ WEST WALL - seal holes in draft stop.

☐ PARTIAL INSPECTION - DESCRIPTION

☒ APPROVED

☐ PERMIT REQUIRED

☐ STOP WORK

☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☒ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. OF O ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 398-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 888 S. Rancho			PERMIT NO. 95506	
LOT NO	MAP NO 3	INSPECTOR 1:22p. 55 68	DATE 3-5-91	
SUBDIVISION NAME			PHONE 4586579	
INSPECTOR SIGNATURE ▶ E Russell			INSPECTION DATE 3.6.91	

☐ PARTIAL INSPECTION - DESCRIPTION:

☒ **APPROVED**

☐ **PERMIT REQUIRED**

☐ **STOP WORK**

☐ **REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071**

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☒ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELETRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	<u>POOL</u> PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	<u>POOL</u> PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 386-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

[illegible]

FOR ASSISTANCE -CALL: 386-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS <i>888 S. Rancho</i>		PERMIT NO. <i>98625</i>	
LOT NO.	MAP NO. <i>5-1127a</i>	INSPECTOR <i>75</i>	DATE <i>2-27-91</i>
SUBDIVISION NAME <i>SWM</i>		PHONE <i>362-6812</i>	
INSPECTOR SIGNATURE <i>R. Patterson</i>		INSPECTION DATE <i>2-28-91</i>	

T I

NOTE (ALL WIRING & CONDUIT NOT IN USE TO BE REMOVED TO NEAREST PANEL)

☒ PARTIAL INSPECTION DESCRIPTION: *Wells only*

☒ APPROVED
 ☐ PERMIT REQUIRED
 ☐ STOP WORK

☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER:
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☒ E-2	ROUGH ELECTRICAL
☐ B-10	<u>POOL</u> PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	<u>POOL</u> PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 393-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS <i>888 S. Rancho</i>		PERMIT NO. <i>98235</i>	
LOT NO.	MAP NO. <i>8-1 Sp</i>	INSPECTOR <i>80</i>	DATE <i>2-26-91</i>
SUBDIVISION NAME			PHONE

INSPECTOR SIGNATURE <i>Tom Nguyen</i>	INSPECTION DATE <i>2-27-91</i>
---	-----------------------------------

☐ PARTIAL INSPECTION - DESCRIPTION:

☒ **APPROVED**

 ☐ **PERMIT REQUIRED**

 ☐ **STOP WORK**

☐ **REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071**

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☒ P-5	<u>TOP OUT-WATER</u> GAS, WASTE	☐ X-6	OTHER
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELETRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	<u>POOL</u> PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	<u>POOL</u> PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT OF OCC	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ **FINAL INSPECTION**

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE -CALL: 388-6251

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

PERMIT
NUMBER

92-131686

INSPECTION
NUMBER

JOB ADDRESS

888 S. Rancho

LOT NO

BLOCK NO.

SUBDIVISION NAME

FIRE DEPT MAP NO.

JOB PHONE

CALL-IN DATE

CALL-IN TIME

SCHEDULE DATE

INSPECTOR NO.

44

INSPECTOR NAME

TITON COONEY

INSPECTION
REQUESTED

125 FAMILING

Room #110 & RSY

OK TO TAPE Drywall
OK # 399
LOE CONNER

☐ PARTIAL
INSPECTION

☐ PARTIAL
APPROVAL (P)

PARTIAL DESCRIPTION

☒ APPROVED
(A)

☐ STOP
WORK (S)

☐ COMMENTS
(C)

☐ TEMPORARY
APPROVAL (T) - UNTIL

☐ HOLD
(H)

☐ REJECTED (R) REINSPECTION REQUIRED - CALL *799-2071

☐ REFEE (F) REINSPECTION FEE REQUIRED - PAY AT CITY HALL
3RD FLOOR - 400 E. STEWART STREET.

☐ PERMIT
REQUIRED

INSPECTOR
SIGNATURE

TITON COONEY #44

INSPECTION DATE

1-10-92

☐ PROJECT
COMPLETE

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY
CALL THE INSPECTOR FROM 7 00 A.M. - 7:15 A.M OR 2 45 P.M. - 3:00 P.M AT

FOR ADDITIONAL ASSISTANCE CALL *386-6251
SEE REVERSE SIDE FOR INSPECTION TYPES

* EFFECTIVE JULY 1, 1991
PHONE PREFIX WILL BE 229.

DEPARTMENT OF BUILDING AND SAFETY
PHONE 229-6251

FOR

DEVELOPMENT PERMIT
FOR: Commercial and Public StructuresPLAN CHECK NO. L-2112 92DATE 12/10/92CONST. VAL. \$ 200,000.00ADDRESS OF
CONSTRUCTION888 S. RanchoSTE 106Urgent Care Facility
Sierra HealthPHONE 383-0027

CONTRACTOR

GROVE INC.

STATE

LICENSE NO. 012339

CITY

LICENSE NO. 03210

LOT(S)

3

BLOCK

PM 25/25

SUBDIVISION

ZONE

C1

PROPOSED CONSTRUCTION:

Urgent Care FacilityINT Rem

USE:

GALE

ADD'L. PERMITS REQ'D.:

Air Cond. ☒Elec. ☒Plumbing ☒Signs ☒Paving ☐Fence ☐Fire S.S. ☒Off-Site P. ☐

OCCUPANCY GROUP

IS-12 B2

CONSTRUCTION TYPE

V-N1 SPRINKLERED

MATERIALS OF CONSTRUCTION:

Wood Frame ☒Concrete Block ☐Reinforced Concrete ☐Steel Frame ☐

SQUARE FEET OF FLOOR AREAS:

1st 7145

2nd

3rd

Other

TOTAL SQ. FT. 7145

ARCHITECT:

HSA Architects

ENGINEER

Mendenhall-Smith

NO. of UNITS

1

NO. of STORIES

1

OTHER INSPECTIONS AND FEES

- 1 Inspections outside of normal business hours = \$30.00 per hour (minimum charge three hours)
- 2 Re-inspection fee during normal business hours assessed under provisions of TABLE 3-A of the Uniform Building Code = \$30.00 each
- 3 Inspections during normal business hours for which no fee is specifically indicated = \$30.00 per hour (minimum charge one half hour)
- 4 Additional plan review required by changes, additions or revisions to approved plans = \$30.00 per hour (minimum charge two hours).

FOR INSPECTIONS, CALL 229-2071

CONDITIONS OF THE PERMIT:

- 1 I agree to call the City Building Department for inspections before concrete is poured, before rough wiring, electrical, plumbing, framing is covered. Also for air conditioning, drywall and sheathing inspection.
- 2 I agree that when the job is completed that I will call for final inspection before occupancy.
- 3 I agree to perform all construction in accordance with City Ordinances and Building Codes.
- 4 The Contractor's signature below denotes authority from the owner to sign in his behalf and that the owner is aware of all requirements of this application and permit. Separate permits must be taken out for work outlined above this agreement.
- 5 I have read and understand the contents of this application and permit; I hereby state that the information I have supplied on this application is true and correct.

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way

SPECIAL CONDITIONS:

See plans

SIGNED

CONTRACTOR

BY

AGENT/OWNER

7114-3654 SEWER CONNECTION

USE CODE

FIXTURES

0

05/24/93

FEE

2310-2431

PLAN REVIEW

PD.

2310-2401

BUILDING PERMIT

913.00

88100-1207

TRANSPORT

6122-3352

TORTOISE

88100-1211

WATER

TOTAL FEES

\$ 913.00RECEIPT
MUST BE MAINTAINEDCOMM 913.00
CHEK 913.00
9063A000 12:34

LICENSE DEPT

DATE

PLANNING DEPT

DATE

I hereby certify that I have reviewed this application and the proposed plans and have found that the proposed development meets the requirements of the City of Las Vegas Flood Hazard Reduction Ordinance for the issuance of this Development Permit.

LAND DEVELOPMENT AND FLOOD CONTROL ENGINEER

DATE

FIRE DEPARTMENT

DATE

BUILDING DEPT

DATE

PERMIT NO.

Permit Expires 180 Days After Abandonment of Work

CITY OF LAS VEGAS, NEVADA

PERMIT NO. 1-098764

75

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

FOR INSPECTIONS, CALL 799-2071

ELECTRICAL PERMIT

LOG NO. & AREA M-1424 DATE 2/27/91 CONST. VAL. \$

ADDRESS OF CONSTRUCTION 888 S. RANCHO DRIVE OWNER SOUTHWEST MEDICAL, INC.

CONTRACTOR NEVCO AIR CONDITIONING & SHEET METAL STATE LICENSE NO. 24377 CITY LICENSE NO. C11023112033209

JOHN O'BRYAN
(PRINT NAME OF MASTER ELECTRICIAN) F-137 PHONE 362-9878
MASTER CARD NO.

PROPOSED CONSTRUCTION SMOKE DETECTORS & HORNS USE:

ELECTRIC
PERMIT NO.

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
1	For Issuing Each Permit	10 00	10.00
	Supplemental Fee	4 50	
APPLIANCE CHARGE			
	Residential or General Commercial		
	Receptacle _____ Switch _____	40	
	Each Light Fixture, Socket, or Exit Light, Smoke Detector or Exhaust Fan	30	
	EACH OUTLET FOR SPECIAL PURPOSE Dishwasher, Garbage Grinder, Trash Compactor, G.F.I., Clothes Washer, Dryer, Electric Range, Ovens, Water Heater, Space Heater, Blast Coil Heater, (PER K.W.), Mercury Lamp, Quartz Lamp, Sodium Lamp, 20AMP Sign Circuit	70	
	X-Ray Unit	10 00	
	Area Lighting (First 3,000 Watts)	8 00	
	Each Additional 1,000 Watts	3 00	
MOTORS (1 H.P. AND OVER) TRANSFORMERS, ELEVATORS, WELDERS, GENERATORS, CHILLERS, SIGNS AND A/C UNITS (OVER 5 TONS)			
	First H.P. or Ton For each Unit	3 00	
	First KVA For Each Unit	3 00	
	Each Additional H.P., Ton or KVA up to 50	50	
	Each Additional H.P., Ton or KVA over 50	35	
	Temporary power or Pole	6 00	
ELECTRIC SERVICE OR MAIN DISCONNECT			
	Up to 200 AMP	6.00	
	400 AMP And 600 AMP	12 50	
	Over 600 AMP To 1200 AMP	25.00	
	Over 1200 AMP	50 00	
	Each Additional Meter Socket	50	
	Sub Panel, Motor Control Center Disconnect Switch, Transfer Switch (Each)	3.00	
	Swimming Pool (Residential)	20 00	
	Swimming Pool (Semi-Public)	30 00	
	Spas	8 00	
	Recreational Vehicle Spaces (Each)	3 00	

UNITS	DESCRIPTION	FEE	TOTAL
	Busways-Trolley or Plug-in (Ea 100 Ft)	3 00	
	Gas Pumps, Dispensers (Each)	3 00	
	Permanent A/C Unit (5 Tons or Less)	3 00	
	Each Air Handler	1 00	
RESIDENTIAL LOW VOLTAGE INSTALLATIONS			
	Speaker Outlets (Each)	30	
	Signal or Alarm Outlets (Each)	30	
	Amplifiers	2.00	
	Control Panel	50	
	TV Master System	30	
	Telephone or Computer Outlet	30	
OTHER INSPECTIONS AND FEES: INCLUDES ISSUANCE FEES WHEN APPLICABLE			
	Inspections outside of normal business hours (minimum charge — three hours)	30 00 per hour	
	Reinspection fee assessed under provisions of TABLE 3-A of the Uniform Building Code = \$30 00 EACH	30 00 each	
	Inspections for which no fee is specifically indicated (minimum charge — one-half hour)	30 00 per hour	
	Additional plan review required by changes, additions or revisions to approved plans (minimum charge — one-half hour) After work hours — \$30 00 per hour — minimum 1 hour	30.00 per hour	
	Starter Permit	50 00	
CONTRACT PRICE OR COST OF INSTALLATION			
	Commercial —Burglar Alarms		
	—Music Systems		
	—Data Processing		
	—Communication		
	Conduit Only—Contract Price		
	All Misc Electric FIRE ALARM	56.00	56.00

Electrical permit fees may be computed the same as building permit fees by using the cost of installation for valuation amount when such work is not included in the above schedule

2310-2432

02/28/91

RECEIPT

##0002##

ELEC 66.00

CHEK 66.00

9882A000 09:40

I hereby certify that I have carefully examined and read the above application, that the same is true and correct, and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not

Julie Cullina Nevco
SIGNED HOMEOWNER, CONTRACTOR

DB

2/27/91

BUILDING DEPT

DATE

Permit Expires 180 Days After Abandonment of Work

PERMIT FEE 10.00

LESS STARTER PERMIT

TOTAL FEES 66.00

PERMIT NO.

MUST BE MACHINE VALIDATED

CITY OF LAS VEGAS, NEVADA

PERMIT NO.

FOR INSPECTIONS, CALL 799-2071

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

90-088070
ELECTRICAL PERMIT

LOG NO. & AREA M-5685 DATE 11-6-90 CONST. VAL. \$ 4098⁰⁰

ADDRESS OF CONSTRUCTION 888 S. RANCHO OWNER South West Medical

CONTRACTOR FIRE MASTER STATE LICENSE NO 0028644 CITY LICENSE NO 37472

(PRINT NAME OF MASTER ELECTRICIAN) William Wimberly MASTER CARD NO C-1545 PHONE 384 1257

PROPOSED CONSTRUCTION: Fire Alarm USE: _____

ELECTRIC PERMIT NO _____

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
	For Issuing Each Permit	10.00	12.00
	Supplemental Fee	4.50	
APPLIANCE CHARGE			
	Residential or General Commercial		
	Receptacle _____ Switch _____	40	
	Each Light Fixture, Socket, or Exit Light, Smoke Detector or Exhaust Fan	30	
	EACH OUTLET FOR SPECIAL PURPOSE Dishwasher, Garbage Grinder, Trash Compactor, G.F.I., Clothes Washer, Dryer, Electric Range, Ovens, Water Heater, Space Heater, Blast Coil Heater, (PER K.W.), Mercury Lamp, Quartz Lamp, Sodium Lamp, 20AMP Sign Circuit	70	
	X-Ray Unit	10.00	
	Area Lighting (First 3,000 Watts)	8.00	
	Each Additional 1,000 Watts	3.00	
MOTORS (1 H.P. AND OVER) TRANSFORMERS, ELEVATORS, WELDERS, GENERATORS, CHILLERS, SIGNS AND A/C UNITS (OVER 5 TONS)			
	First H.P. or Ton For each Unit	3.00	
	First KVA For Each Unit	3.00	
	Each Additional H.P., Ton or KVA up to 50	50	
	Each Additional H.P., Ton or KVA over 50	35	
	Temporary power or Pole	6.00	
ELECTRIC SERVICE OR MAIN DISCONNECT			
	Up to 200 AMP	6.00	
	400 AMP And 600 AMP	12.50	
	Over 600 AMP To 1200 AMP	25.00	
	Over 1200 AMP	50.00	
	Each Additional Meter Socket	.50	
	Sub Panel, Motor Control Center Disconnect Switch, Transfer Switch (Each)	3.00	
	Swimming Pool (Residential)	20.00	
	Swimming Pool (Semi-Public)	30.00	
	Spas	8.00	
	Recreational Vehicle Spaces (Each)	3.00	

UNITS	DESCRIPTION	FEE	TOTAL
	Busways-Trolley or Plug-in (Ea. 100 Ft.)	3.00	
	Gas Pumps, Dispensers (Each)	3.00	
	Permanent A/C Unit (5 Tons or Less)	3.00	
	Each Air Handler	1.00	
RESIDENTIAL LOW VOLTAGE INSTALLATIONS			
	Speaker Outlets (Each)	30	
	Signal or Alarm Outlets (Each)	30	
	Amplifiers	2.00	
	Control Panel	.50	
	TV Master System	.30	
	Telephone or Computer Outlet	30	
OTHER INSPECTIONS AND FEES: INCLUDES ISSUANCE FEES WHEN APPLICABLE			
	Inspections outside of normal business hours (minimum charge — three hours)	30.00 per hour	
	Reinspection fee assessed under provisions of TABLE 3-A of the Uniform Building Code = \$30.00 EACH	30.00 each	
	Inspections for which no fee is specifically indicated (minimum charge — one-half hour).	30.00 per hour	
	Additional plan review required by changes, additions or revisions to approved plans (minimum charge — one-half hour) After work hours — \$30.00 per hour — minimum 1 hour	30.00 per hour	
	Starter Permit	50.00	
CONTRACT PRICE OR COST OF INSTALLATION			
	Commercial — Burglar Alarms <u>Fire</u>		<u>61.00</u>
	— Music Systems		
	— Data Processing		
	— Communication		
	Conduit Only—Contract Price		
	All Misc. Electric		

Electrical permit fees may be computed the same as building permit fees by using the cost of installation for valuation amount when such work is not included in the above schedule

2310-2432 11/06/90

RECEIPT

***0005**
ELEC 71.00
CASH 71.00
4357A000 10:27

I hereby certify that I have carefully examined and read the above application, that the same is true and correct; and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not.

SIGNED HOMEOWNER, CONTRACTOR

PERMIT FEE

LESS STARTER PERMIT

TOTAL FEES 71.00

PERMIT NO _____

MUST BE MACHINE VALIDATED

BUILDING DEPT

DATE

Permit Expires 180 Days After Abandonment of Work

CITY OF LAS VEGAS, NEVADA

PERMIT NO. 2 131596

68

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

FOR INSPECTIONS, CALL 799-2071

DEVELOPMENT PERMIT
FOR: Commercial and Public StructuresLOG NO. & AREA M 9383 DATE 12-24-91 CONST. VAL. \$ 20,000ADDRESS OF CONSTRUCTION 888 S. RANCHO LN OWNER SIERRA HEALTH SERVICE FAX 458-0906 PHONE 458-6579CONTRACTOR DUNN COAST INC. STATE LICENSE NO. 0018138 CITY LICENSE NO. 035664LOT(s) _____ BLOCK _____ SUBDIVISION 63 330 675 ZONE C-1PROPOSED CONSTRUCTION: TENANT IMPROVEMENT USE: _____ADD'L. PERMITS REQ'D.: Air Cond. ☐ Elec ☒ Plumbing ☒ Signs ☐ Paving ☐ Fence ☐ Fire S.S. ☐ Off-Site P. ☐OCCUPANCY GROUP B-2 CONSTRUCTION TYPE V-NMATERIALS OF CONSTRUCTION: Wood Frame ☒ Concrete Block ☐ Reinforced Concrete ☐ Steel Frame ☐SQUARE FEET OF FLOOR AREAS: 1st 2300 2nd _____ 3rd _____ Other _____ TOTAL SQ. FT. 2300ARCHITECT: NONE ENGINEER: NONE NO. of UNITS 1 NO. of STORIES 1

7456A000 12/24CHK 117.00

OTHER INSPECTIONS AND FEES

- 1 Inspections outside of normal business hours = \$30.00 per hour (minimum charge three hours)
- 2 Re-inspection fee during normal business hours assessed under provisions of TABLE 3-A of the Uniform Building Code = \$30.00 each
- 3 Inspections during normal business hours for which no fee is specifically indicated = \$30.00 per hour (minimum charge one half hour)
- 4 Additional plan review required by changes, additions or revisions to approved plans = \$30.00 per hour (minimum charge two hours)

FOR INSPECTIONS, CALL 799-2071

CONDITIONS OF THE PERMIT:

1. I agree to call the City Building Department for inspections before concrete is poured, before rough wiring, electrical, plumbing, framing is covered. Also for air conditioning, drywall and sheathing inspection
2. I agree that when the job is completed that I will call for final inspection before occupancy.
3. I agree to perform all construction in accordance with City Ordinances and Building Codes.
4. The Contractor's signature below denotes authority from the owner to sign in his behalf and that the owner is aware of all requirements of this application and permit. Separate permits must be taken out for work outlined above this agreement.
5. I have read and understand the contents of this application and permit; I hereby state that the information I have supplied on this application is true and correct

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way

SPECIAL CONDITIONS:

*Interior remodel only*SIGNED [Signature] CONTRACTORBY [Signature] AGENT/OWNERLICENSE DEPT. [Signature] DATE 12/24/91PLANNING DEPT. [Signature] DATE 12/24/91

I hereby certify that I have reviewed this application and the proposed plans and have found that the proposed development meets the requirements of the City of Las Vegas Flood Hazard Reduction Ordinance for the issuance of this Development Permit.

LAND DEVELOPMENT AND FLOOD CONTROL ENGINEER [Signature] DATE 11/2/92FIRE DEPARTMENT [Signature] DATE 11/2/92BUILDING DEPT. [Signature] DATE 11/2/92

7114-3654 SEWER CONNECTION _____

USE CODE _____

FIXTURES _____ X _____ 01/02/92

FEE _____

2310-2431 PLAN REVIEW _____

2310-2401 BUILDING PERMIT 180.00

88100-1207 TRANSPORT _____

6122-3352 TORTOISE _____

88100-1211 WATER _____

TOTAL FEES 180.00RECEIPT
MUST BE MACHINE-VALIDATEDCOMM 180.00
CHK 180.00
7902A000 14:25

PERMIT NO.

Permit Expires 180 Days After Abandonment of Work

LOG NO. & AREA

m - 509

DATE



68123

CONST. VAL.

400.00/10

DEPARTMENT OF FIRE SERVICE

LIFE SAFETY SYSTEMS PERMIT

TELEPHONE: 383-2888

92-133758

(File Rm.) 92-133758 No. 3807

ADDRESS OF CONSTRUCTION

888 S. Rancho

OWNER

Sierra Health Serv.

CONTRACTOR

Sierra Fire

STATE LICENSE NO.

0024397

CITY LICENSE NO.

2-033112

LOT(S)

BLOCK

SUBDIVISION

ZONE

PROPOSED CONSTRUCTION

Tenant Improvement USE Fire Sprinkler

FIRE PERMIT NO.

APPROVAL FOR THE WORK UNDER THIS PERMIT WILL BE GIVEN ONLY AFTER REFUSE AND DEBRIS HAVE BEEN REMOVED FROM JOB SITE AND PUBLIC RIGHT OF WAY.

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
	For Issuing Each Permit	10	10
	For Issuing Each Supplemental Permit		
LOW VOLTAGE INSTALLATIONS			
	Speaker Outlets (Each)		
	Signal or Alarm Outlets (Each)		
	Amplifiers		
	Control Panel		
	Smoke Detectors		
	Telephone or Computer Outlet		
OTHER INSPECTIONS AND FEES			
	Halon Total Flooding Ext. System		
	CO ₂ Local Application System		
	Underground Water Distribution		
	System Supplying Fire Systems		
	Starter Permit		
	Contract Price of Cost of Installation		
	Misc.		
	Fire Pump(s)		
	On Site Water Supply		

UNITS	DESCRIPTION	FEE	TOTAL
	Gas System (plan check)		
	Each Gas Appliance (any type)		
	Standby Emergency (generating engines)		
	Service Station Fuel Tank and Piping System		
	Fuel Tanks (each)		
AUTOMATIC FIRE EXTINGUISHING SYSTEM			
	Underground Piping		
	Distribution Piping-per foot		
	Sprinkler Head	13	13
	In Range Hood and Vent		
	Dry Standpipe System		
	Piping		
	Each Outlet		
	Wet Standpipe System		
	Piping		
	Fire Hose Cabinet		
SMOKE CONTROL SYSTEM			
	Mechanical Ventilation		
	Natural Ventilation		
	For Onsite Water Contract Value. Fee Based on Building Code Permit Valuation Chart.		
OTHER INSPECTIONS AND FEES			
	Inspections outside of normal business hours (minimum charge — three hours).		
	Reinspection fee assessed under provisions of TABLE 3-A of the Uniform Building Code.		
	Inspections for which no fee is specifically indicated (minimum charge — one half hour).		
	Additional plan review required by changes, additions or revisions to approved plans (minimum charge two hours).		

I hereby certify that I have carefully examined and read the above application, that the same is true and correct and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinance of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not.

Signed

Contractor

Master Card No.

By Fire Protection Engineer/Fire Marshal

DATE

FIXTURES

X

FEE

\$

13

PERMIT FEE

\$

10

TOTAL FEES

\$

23

Fire permit fees may be computed the same as building permit fees by using the cost of installation for valuation amount when such work is not included in the above schedule.

PERMIT EXPIRES 180 DAYS AFTER ABANDONMENT OF WORK

RECEIPT

0005

FIRE 23.00

CHECK 23.00

9036A000 09:17

01/27/92

Must Be Machine Validated

AH2150A6

CITY OF LAS VEGAS, NEVADA

PERMIT NO. 92-132339

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

FOR INSPECTIONS, CALL 799-2071

ELECTRICAL PERMIT

75

LOG NO. & AREA M-9383 91-CDATE 1-9-92

CONST. VAL. \$

ADDRESS OF
CONSTRUCTION888 So Rancho

OWNER

Sierra Health Svcs
South West Medical

CONTRACTOR

Holland & Holland Elec

STATE

LICENSE NO.

21113

CITY

LICENSE NO.

021963

(PRINT NAME OF MASTER ELECTRICIAN)

Bill Holland

MASTER CARD NO

165

PHONE

362-6812

PROPOSED CONSTRUCTION:

USE

ELECTRIC
PERMIT NO.Approval for the work under this permit will be given only after refuse
and debris have been removed from job site and public right of way

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
<u>1</u>	For Issuing Each Permit	10 00	<u>10.00</u>
	Supplemental Fee	4 50	
APPLIANCE CHARGE			
Residential or General Commercial			
<u>6</u>	Receptacle <u>4</u> Switch <u>2</u>	40	<u>2.40</u>
<u>7</u>	Each Light Fixture, Socket, or Exit Light, Smoke Detector or Exhaust Fan	30	<u>2.10</u>
	EACH OUTLET FOR SPECIAL PURPOSE: Dishwasher, Garbage Grinder, Trash Compactor, GFI, Clothes Washer, Dryer, Electric Range, Ovens, Water Heater, Space Heater, Blast Coil Heater, (PER K.W.), Mercury Lamp, Quartz Lamp, Sodium Lamp, 20AMP Sign Circuit	70	
	X-Ray Unit	10 00	
	Area Lighting (First 3,000 Watts)	8 00	
	Each Additional 1,000 Watts	3 00	
MOTORS (1 H.P. AND OVER) TRANSFORMERS, ELEVATORS, WELDERS, GENERATORS, CHILLERS, SIGNS AND A/C UNITS (OVER 5 TONS)			
<u>1</u>	First H.P. or Ton For each Unit	3 00	<u>3.00</u>
	First KVA For Each Unit	3 00	
	Each Additional H.P., Ton or KVA up to 50	50	
	Each Additional H.P., Ton or KVA over 50	35	
	Temporary power or Pole	6 00	
ELECTRIC SERVICE OR MAIN DISCONNECT			
<u>1</u>	Up to 200 AMP	6.00	<u>6.00</u>
	400 AMP And 600 AMP	12 50	
	Over 600 AMP To 1200 AMP	25 00	
	Over 1200 AMP	50 00	
	Each Additional Meter Socket	50	
<u>1</u>	Sub Panel, Motor Control Center Disconnect Switch, Transfer Switch (Each)	3 00	<u>3.00</u>
	Swimming Pool (Residential)	20 00	
	Swimming Pool (Semi-Public)	30 00	
	Spas	8.00	
	Recreational Vehicle Spaces (Each)	3.00	

UNITS	DESCRIPTION	FEE	TOTAL
<u>1</u>	Busways-Trolley or Plug-in (Ea 100 Ft.)	3 00	<u>3.00</u>
	Gas Pumps, Dispensers (Each)	3 00	
<u>1</u>	Permanent A/C Unit (5 Tons or Less)	3 00	<u>3.00</u>
	Each Air Handler	1 00	
RESIDENTIAL LOW VOLTAGE INSTALLATIONS			
	Speaker Outlets (Each)	30.	
	Signal or Alarm Outlets (Each)	30	
	Amplifiers	2 00	
	Control Panel	.50	
	TV Master System	30	
	Telephone or Computer Outlet	30	
OTHER INSPECTIONS AND FEES: INCLUDES ISSUANCE FEES WHEN APPLICABLE			
	Inspections outside of normal business hours (minimum charge — three hours)	30.00 per hour	
	Reinspection fee assessed under provisions of TABLE 3-A of the Uniform Building Code = \$30.00 EACH	30 00 each	
	Inspections for which no fee is specifically indicated (minimum charge — one-half hour).	30 00 per hour	
	Additional plan review required by changes, additions or revisions to approved plans (minimum charge — one-half hour) After work hours — \$30 00 per hour — minimum 1 hour.	30 00 per hour	
	Starter Permit	50.00	
CONTRACT PRICE OR COST OF INSTALLATION			
	Commercial — Burglar Alarms		
	— Music Systems		
	— Data Processing		
	— Communication		
	Conduit Only—Contract Price		
	All Misc Electric		

Electrical permit fees may be computed
the same as building permit fees by
using the cost of installation for valuation
amount when such work is not included
in the above schedule

2310-2432

01/09/92

RECEIPT

0002

ELEC 34.77

CHEK 34.77

8274A000 15:08

I hereby certify that I have carefully examined and read the above application, that the
same is true and correct; and that the work herein described is to be done in accordance
with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and
the State Laws, whether herein specified or not

SIGNED HOMEOWNER, CONTRACTOR

BUILDING DEPT

DATE

Permit Expires 180 Days After Abandonment of Work

PERMIT
FEE32.50

LESS

STARTER PERMIT

2.27TOTAL
FEES34.77

PERMIT NO.

MUST BE MACHINE VALIDATED

CITY OF LAS VEGAS, NEVADA

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

PERMIT NO. 92-131688

PLUMBING PERMIT

81

LOG NO. & AREA M 9383 DATE 1/2/92 CONST. VAL. \$ADDRESS OF CONSTRUCTION 888 So Rancho Dr OWNER Suzana Harit Services PHONE 458-0906CONTRACTOR LAKE MEAD PLUMBING CO STATE LICENSE NO 29305 CITY LICENSE NO 042490

LOT(s) BLOCK SUBDIVISION ZONE

PROPOSED CONSTRUCTION REMODEL USE

PLUMBING PERMIT NO

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way

UNITS	DESCRIPTION	FEE	TOTAL
1	PERMIT ISSUANCE		
	For Issuing Each Permit	10 70	10.70
	For Issuing Each Supplemental Permit	4 85	
	FIXTURE CHARGE		
	Bathub, Shower, Lavatory, Toilet, Urinal EA	2 15	
2	Floor Drain, Floor Sink, Wash Tray, Sink EA	2 15	4.30
	Garbage Disposal, Clothes Washer, Dishwasher (residential) EA	2 15	
	Garbage Disposal (commercial) EA	8 60	
	Clothes Washer, Dishwasher (commercial) EA	2 15	
	Clothes Dryer (gas) (venting)	2 15	
	Dental Unit	8 60	
	Drinking Fountain	2 15	
	Refrigerator - Ice Maker, Water Dispenser	2 15	
	Any other water using equipment, Attached Coffee Makers, Ice Makers	2 15	
	Hot Water Heater (Gas or Electric) EA	2 15	
	SEWER SYSTEM		
	New, Replacement, Modification, or Any Drainage Work	10 70	
	Grease or Sand Trap or Interceptor	2 15	
	Trailer Trap (rental parks)	5 35	
	WATER SOFTENERS		
	Non Permanent Type (rental)	2 15	
	Permanent Type (connected to drain)	2 15	
	WATER DISTRIBUTION SYSTEM		
	Single Family Dwelling	6 45	
	Multi-Family Dwelling	6 45	
	Plus Each Dwelling Unit	3 25	
	Commercial Building per floor	3 25	3.25
	Plus Each Unit (leased space or office)	2 15	2.15
	Hotel or Motel	8 60	
	Plus Each Unit	3 25	
	Trailer Park	32 10	
	Plus Each Space	2 15	
	Irrigation Single Family Dwelling	8 60	
	Irrigation Commercial Fee Based on Building Code Valuation Chart		
	Construction Valuation		

UNITS	DESCRIPTION	FEE	TOTAL
	FUEL PIPING SYSTEM		
	Single Family Dwelling	6 45	
	Multi-Family Dwelling	10 70	
	Plus Each Unit	2 15	
	Commercial Building (per floor)	6 45	
	Plus Each Unit (leased space or office)	6 45	
	Medium Pressure System (Plan Check)	12 85	
	Each Gas Appliance (Any Type)	2 15	
	Steam Boilers	5 60	
	SOLAR ENERGY SYSTEMS		
	Collectors (including piping) (per collector)	5 60	
	Storage Tanks (each)	5 60	
	PIPELINE CONTRACT		
	For Onsite Sewer, Gas or Water Contract Value Fee based on Building Code Permit Valuation Chart		
	OTHER INSPECTIONS AND FEES:		
	Inspections outside of normal business hours (minimum charge—three hours)	25 00 per hour	
	Under provisions of Table 3-A of the Uniform Building Code, work which has been inspected once and not approved may be subject to a Reinspection Fee not less than \$30 00 per each inspection during business hours	30 00 each	
	Additional plan review required by changes Additions to or revisions to approved plans (minimum charge two hours)	30 00 per hour	
	Plumbing permit fees may be computed the same as building permit fees by using the cost of installation for valuation amount when such work is not included in the above schedule		
	Construction Valuation		

FOR INSPECTIONS
CALL 799-2071SEWER # 7114-3654
CONNECTION

RECEIPT

0002

PLBG 20.40

CHEK 20.40

7904A000 14:33

FIXTURES X 01/02/92

FEE

2310-2403

PERMIT

FEE 20.40

TOTAL

FEES

PERMIT NO

MUST BE MACHINE VALIDATED

I hereby certify that I have carefully examined and read the above application; that the same is true and correct, and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not

SIGNED [Signature] CONTRACTOR 29305 MASTER CARD NO

BY Registered Master Plumber Spec Contractor or Owner

[Signature] 1/2/92
BUILDING DEPT DATE

CITY OF LAS VEGAS, NEVADA

PERMIT NO. 92-132265

80

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

FOR INSPECTIONS, CALL 799-2071

AIR CONDITIONING PERMIT

LOG NO. & AREA M9383-C DATE 1/9/92 CONST. VAL. \$ADDRESS OF CONSTRUCTION 888 Rancho OWNER Sierra Health Services PHONE 646-8300CONTRACTOR Sahara Air Conditioning STATE LICENSE NO. 017859 CITY LICENSE NO. C11012472019928

LOT(s) BLOCK SUBDIVISION ZONE:

PROPOSED CONSTRUCTION install two ton split system cooling unit USE:

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way.

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
	For the issuance of each permit	15 00	15
	For issuing each supplemental permit	4 50	
UNIT FEE SCHEDULE			
	For the installation or relocation of each forced-air or gravity-type furnace or burner, including ducts and vents attached to such appliance, up to and including 100,000 Btu/h	9 00	
	For the installation or relocation of each forced-air or gravity-type furnace or burner, including ducts and vents attached to such appliance over 100,000 Btu/h	11 00	
	For the installation or relocation of each floor furnace, including vent	9 00	
	For the installation or relocation of each suspended heater, recessed wall heater or floor-mounted unit heater	9.00	
	For the installation, relocation or replacement of each appliance vent installed and not included in an appliance permit.	4 50	
	For the repair of, alteration of, or addition to each heating appliance, refrigeration unit, cooling unit, absorption unit, or each heating, cooling absorption, or evaporative cooling system, including installation of controls regulated by this code	9 00	
1	For the installation or relocation of each boiler or compressor to and including three tons, or each absorption system to and including 100 000 Btu/h	9 00	9.00
1	For the installation or relocation of each boiler or compressor over three tons to and including 15 tons, or each absorption system over 100,000 Btu/h and including 500,000 Btu/h	16 50	
	For the installation or relocation of each boiler or compressor over 15 tons to and including 30 tons, or each absorption system over 500,000 Btu/h to and including 1,000,000 Btu/h.	22 50	
	For the installation or relocation of each boiler or compressor over 30 tons to and including 50 tons, or for each absorption system over 1,000,000 Btu/h to and including 1,750,000 Btu/h	33 50	
	For the installation or relocation of each boiler or refrigeration compressor over 50 tons, or each absorption system over 1,750,000 Btu/h	56.00	

UNITS	DESCRIPTION	FEE	TOTAL
	For each air-handling unit to and including 10,000 cubic feet per minute, including ducts attached thereto Note: This fee shall not apply to an air-handling unit which is a portion of a factory-assembled appliance, cooling unit, evaporative cooler or absorption unit for which a permit is required elsewhere in this code	6 50	
	For each air-handling unit over 10,000 cfm	11 00	
	For each evaporative cooler other than portable type	6 50	
1	For each ventilation fan COMMERCIAL RESIDENTIAL	4 50 2 35	4.50
	For each ventilation system which is not a portion of any heating or air-conditioning system authorized by a permit	6 50	
	For the installation of each hood which is served by mechanical exhaust, including the ducts for such hood	6 50	
	For each fire damper installed in an existing system	4 50	
OTHER INSPECTIONS AND FEES:			
	Inspections outside of normal business hours (minimum charge — three hours)	25 00 per hour	
	Reinspection fee assessed under provisions of TABLE 3-A of the Uniform Building Code = \$15 00 EACH	15 00 each	
	Inspections for which no fee is specifically indicated (minimum charge — one-half hour)	30 00 per hour	
	Additional plan review required by changes, additions or revisions to approved plans (minimum charge — two hours)	30 00 per hour	
	Mechanical permit fees may be computed the same as building permit fees by using the cost of installation for valuation amount when such work is not included in the above schedule		
	Gas piping which is directly related and necessary to the repair or replacement of heating, air conditioning, or refrigeration systems not exceeding 500,000 BTU H	6 00	

2310-2435

RECEIPT

0006

A/C 30.50

CHEK 30.50

8211A000 09:27

01/09/92

I hereby certify that I have carefully examined and read the above application; that the same is true and correct, and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not

SIGNED RmH CONTRACTOR MASTER CARD NOBY David H. H. Spec Cont'r or OwnerBUILDING DEPT DATE 1/9/92

PERMIT FEE

28.50

TOTAL FEES

79.200

30.50

MUST BE MACHINE VALIDATED

Permit Expires 180 Days After Abandonment of Work

CITY OF LAS VEGAS, NEVADA

PERMIT NO. 92-132339

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

FOR INSPECTION



67242

ELECTRICAL PERMIT

LOG NO. & AREA

M-9383 '91-C

DATE

CONST. VAL. \$

ADDRESS OF
CONSTRUCTION

888 So. Ranch

OWNER

Sierra Health Svcs
South West Medical

CONTRACTOR

Holland + Holland P

STATE

LICENSE NO.

21113

CITY

LICENSE NO.

021963

(PRINT NAME OF MASTER ELECTRICIAN)

Bill Holland

165

PHONE

362-6812

PROPOSED CONSTRUCTION:

USE:

ELECTRIC
PERMIT NO.Approval for the work under this permit will be given only after refuse
and debris have been removed from job site and public right of way

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
1	For Issuing Each Permit	10.00	10.00
	Supplemental Fee	4.50	
APPLIANCE CHARGE			
Residential or General Commercial			
6	Receptacle 4 Switch 2	.40	2.40
7	Each Light Fixture, Socket, or Exit Light, Smoke Detector or Exhaust Fan	30	2.10
	EACH OUTLET FOR SPECIAL PURPOSE. Dishwasher, Garbage Grinder, Trash Compactor, GFI, Clothes Washer, Dryer, Electric Range, Ovens, Water Heater, Space Heater, Blast Coil Heater, (PER K.W.), Mercury Lamp, Quartz Lamp, Sodium Lamp, 20AMP Sign Circuit	.70	
	X-Ray Unit	10.00	
	Area Lighting (First 3,000 Watts)	8.00	
	Each Additional 1,000 Watts	3.00	
MOTORS (1 H.P. AND OVER) TRANSFORMERS, ELEVATORS, WELDERS, GENERATORS, CHILLERS, SIGNS AND A/C UNITS (OVER 5 TONS)			
1	First H.P. or Ton For each Unit	3.00	3.00
	First KVA For Each Unit	3.00	
	Each Additional H.P., Ton or KVA up to 50	.50	
	Each Additional H.P., Ton or KVA over 50	35	
	Temporary power or Pole	6.00	
ELECTRIC SERVICE OR MAIN DISCONNECT			
1	Up to 200 AMP	6.00	6.00
	400 AMP And 600 AMP	12.50	
	Over 600 AMP To 1200 AMP	25.00	
	Over 1200 AMP	50.00	
	Each Additional Meter Socket	50	
1	Sub Panel, Motor Control Center Disconnect Switch, Transfer Switch (Each)	3.00	3.00
	Swimming Pool (Residential)	20.00	
	Swimming Pool (Semi-Public)	30.00	
	Spas	8.00	
	Recreational Vehicle Spaces (Each)	3.00	

UNITS	DESCRIPTION	FEE	TOTAL
1	Busways-Trolley or Plug-in (Ea 100 Ft)	3.00	3.00
	Gas Pumps, Dispensers (Each)	3.00	
1	Permanent A/C Unit (5 Tons or Less)	3.00	3.00
	Each Air Handler	1.00	
RESIDENTIAL LOW VOLTAGE INSTALLATIONS			
	Speaker Outlets (Each)	30	
	Signal or Alarm Outlets (Each)	30	
	Amplifiers	2.00	
	Control Panel	50	
	TV Master System	30	
	Telephone or Computer Outlet	30	
OTHER INSPECTIONS AND FEES: INCLUDES ISSUANCE FEES WHEN APPLICABLE			
	Inspections outside of normal business hours (minimum charge — three hours)	30.00 per hour	
	Reinspection fee assessed under provisions of TABLE 3-A of the Uniform Building Code = \$30.00 EACH	30.00 each	
	Inspections for which no fee is specifically indicated (minimum charge — one-half hour)	30.00 per hour	
	Additional plan review required by changes, additions or revisions to approved plans (minimum charge — one-half hour) After work hours — \$30.00 per hour — minimum 1 hour.	30.00 per hour	
	Starter Permit	50.00	
CONTRACT PRICE OR COST OF INSTALLATION			
	Commercial — Burglar Alarms		
	— Music Systems		
	— Data Processing		
	— Communication		
	Conduit Only—Contract Price		
	All Misc Electric		

Electrical permit fees may be computed
the same as building permit fees by
using the cost of installation for valuation
amount when such work is not included
in the above schedule.

2310-2432 01/09/92

RECEIPT

0002

ELEC 34.77

CHEK 34.77

8274A000 15:08

I hereby certify that I have carefully examined and read the above application, that the
same is true and correct, and that the work herein described is to be done in accordance
with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and
the State Laws, whether herein specified or not.

SIGNED HOMEOWNER, CONTRACTOR

BUILDING DEPT

DATE

Permit Expires 180 Days After Abandonment of Work

PERMIT
FEE

32.50

LESS
STARTER PERMIT

7.27 2.27

TOTAL
FEES

34.77

PERMIT NO.

MUST BE MACHINE VALIDATED

CITY OF LAS VEGAS, NEVADA

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

F



PERMIT NO. 92-132265

AIR CONDITIONING PERMIT

LOG NO. & AREA

M9383-C

DATE

1/9/92

CONST. VAL. \$

ADDRESS OF
CONSTRUCTION

888 Rancho

OWNER

Sierra Health Services

PHONE

646-8300

CONTRACTOR

Sahara Air Conditioning

STATE

017859

CITY

C11012472019928

LICENSE NO.

LICENSE NO.

LOT(s)

BLOCK

SUBDIVISION

ZONE

PROPOSED CONSTRUCTION

install two ton split system cooling unit

USE

Approval for the work under this permit will be given only after refuse
and debris have been removed from job site and public right of way

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
	For the issuance of each permit	15 00	15 00
	For issuing each supplemental permit	4.50	
UNIT FEE SCHEDULE			
	For the installation or relocation of each forced-air or gravity-type furnace or burner, including ducts and vents attached to such appliance, up to and including 100,000 Btu/h	9 00	
	For the installation or relocation of each forced-air or gravity-type furnace or burner, including ducts and vents attached to such appliance over 100,000 Btu/h	11 00	
	For the installation or relocation of each floor furnace, including vent	9 00	
	For the installation or relocation of each suspended heater, recessed wall heater or floor-mounted unit heater	9 00	
	For the installation, relocation or replacement of each appliance vent installed and not included in an appliance permit	4 50	
	For the repair of, alteration of, or addition to each heating appliance, refrigeration unit, cooling unit, absorption unit, or each heating, cooling absorption, or evaporative cooling system, including installation of controls regulated by this code	9 00	
/	For the installation or relocation of each boiler or compressor to and including three tons, or each absorption system to and including 100 000 Btu/h	9 00	9.00
	For the installation or relocation of each boiler or compressor over three tons to and including 15 tons, or each absorption system over 100,000 Btu/h and including 500,000 Btu/h	16 50	
	For the installation or relocation of each boiler or compressor over 15 tons to and including 30 tons, or each absorption system over 500,000 Btu/h to and including 1,000,000 Btu/h.	22 50	
	For the installation or relocation of each boiler or compressor over 30 tons to and including 50 tons, or for each absorption system over 1,000,000 Btu/h to and including 1,750,000 Btu/h.	33.50	
	For the installation or relocation of each boiler or refrigeration compressor over 50 tons, or each absorption system over 1,750,000 Btu/h	56 00	

UNITS	DESCRIPTION	FEE	TOTAL
	For each air-handling unit to and including 10,000 cubic feet per minute, including ducts attached thereto Note: This fee shall not apply to an air-handling unit which is a portion of a factory-assembled appliance, cooling unit, evaporative cooler or absorption unit for which a permit is required elsewhere in this code	6 50	
	For each air-handling unit over 10,000 cfm	11 00	
	For each evaporative cooler other than portable type	6 50	
/	For each ventilation fan COMMERCIAL RESIDENTIAL	4 50 2 35	4.50
	For each ventilation system which is not a portion of any heating or air-conditioning system authorized by a permit	6 50	
	For the installation of each hood which is served by mechanical exhaust, including the ducts for such hood	6 50	
	For each fire damper installed in an existing system.	4 50	
OTHER INSPECTIONS AND FEES:			
	Inspections outside of normal business hours (minimum charge — three hours)	25 00 per hour	
	Reinspection fee assessed under provisions of TABLE 3-A of the Uniform Building Code = \$15 00 EACH	15 00 each	
	Inspections for which no fee is specifically indicated (minimum charge — one-half hour)	30 00 per hour	
	Additional plan review required by changes, additions or revisions to approved plans (minimum charge — two hours)	30 00 per hour	
	Mechanical permit fees may be computed the same as building permit fees by using the cost of installation for valuation amount when such work is not included in the above schedule		
	Gas piping which is directly related and necessary to the repair or replacement of heating, air conditioning, or refrigeration systems not exceeding 500,000 BTU H	6 00	

2310-2435

RECEIPT

0006

A/C 30.50

CHEK 30.50

8211A000 09:27

01/09/92

I hereby certify that I have carefully examined and read the above application; that the same is true and correct; and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not.

SIGNED

CONTRACTOR

MASTER CARD NO

BY

Spec Cont'r or Owner

BUILDING DEPT

DATE

PERMIT
FEE

28.50

7% 2.00

TOTAL
FEES

30.50

MUST BE MACHINE VALIDATED

Permit Expires 180 Days After Abandonment of Work

CITY OF LAS VEGAS, NEVADA

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

FO



MIT NO. 82-131686

DEVELOPMENT PERMIT

FOR: Commercial and Public Structures

LOG NO. & AREA M 9383DATE 12-24-91CONST. VAL. \$ 20,000.00ADDRESS OF CONSTRUCTION 888 S. RANCHO LN OWNER SIERRA HEALTH SERVICE PHONE 458-0906
458-6579CONTRACTOR DUNRITE CONST INC STATE LICENSE NO. 0018138 CITY LICENSE NO. 035664LOT(S) _____ BLOCK _____ SUBDIVISION 63 330 675 ZONE: C-1PROPOSED CONSTRUCTION TENANT IMPROVEMENT USE: _____ADD'L. PERMITS REQ'D.: Air Cond ☐ Elec. ☒ Plumbing ☒ Signs ☐ Paving ☐ Fence ☐ Fire S.S. ☐ Off-Site P. ☐OCCUPANCY GROUP B-2 CONSTRUCTION TYPE V-NMATERIALS OF CONSTRUCTION: Wood Frame ☒ Concrete Block ☐ Reinforced Concrete ☐ Steel Frame ☐SQUARE FEET OF FLOOR AREAS: 1st 2300 2nd _____ 3rd _____ Other _____ TOTAL SQ. FT. 2300ARCHITECT. NONE ENGINEER: NONE NO. of UNITS 1 NO. of STORIES 1

7456A000 12/24CHEK 117.00

OTHER INSPECTIONS AND FEES

1. Inspections outside of normal business hours = \$30.00 per hour (minimum charge three hours)
2. Re-inspection fee during normal business hours assessed under provisions of TABLE 3-A of the Uniform Building Code = \$30.00 each
3. Inspections during normal business hours for which no fee is specifically indicated = \$30.00 per hour (minimum charge one half hour)
4. Additional plan review required by changes, additions or revisions to approved plans = \$30.00 per hour (minimum charge two hours)

FOR INSPECTIONS, CALL 799-2071

CONDITIONS OF THE PERMIT:

1. I agree to call the City Building Department for inspections before concrete is poured, before rough wiring, electrical, plumbing, framing is covered. Also for air conditioning, drywall and sheathing inspection.
2. I agree that when the job is completed that I will call for final inspection before occupancy.
3. I agree to perform all construction in accordance with City Ordinances and Building Codes.
4. The Contractor's signature below denotes authority from the owner to sign in his behalf and that the owner is aware of all requirements of this application and permit. Separate permits must be taken out for work outlined above this agreement.
5. I have read and understand the contents of this application and permit; I hereby state that the information I have supplied on this application is true and correct.

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way

SPECIAL CONDITIONS:

Interior remodel onlySIGNED DUNRITE CONST CONTRACTOR

BY _____ AGENT/OWNER

LICENSE DEPT. _____ DATE 12/24/91
PLANNING DEPT. _____ DATE _____

I hereby certify that I have reviewed this application and the proposed plans and have found that the proposed development meets the requirements of the City of Las Vegas Flood Hazard Reduction Ordinance for the issuance of this Development Permit.

LAND DEVELOPMENT AND FLOOD CONTROL ENGINEER _____ DATE _____

FIRE DEPARTMENT _____ DATE 1/2/92
BUILDING DEPT. _____ DATE _____

7114-3654 SEWER CONNECTION _____

USE CODE _____

FIXTURES _____ X _____ 01/02/92

FEE _____

2310-2431 PLAN REVIEW _____

2310-2401 BUILDING PERMIT 180.00

88100-1207 TRANSPORT _____

6122-3352 TORTOISE _____

88100-1211 WATER _____

TOTAL FEES 180.00

RECEIPT
MUST BE MAILED
COMM 180.00
CHEK 180.00
7902A000 14:25

PERMIT NO. _____

Permit Expires 180 Days After Abandonment of Work

CITY OF LAS VEGAS, NEVADA

PERMIT NO.

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-625190 000070
ELECTRICAL PERMITLOG NO. & AREA M-5685

46734

CONST. VAL. \$ 4088.00ADDRESS OF CONSTRUCTION 888 S. Rancho

OWNER

South West MedicalCONTRACTOR FIRE MASTER

STATE

LICENSE NO.

0028644

CITY

LICENSE NO.

00000000

(PRINT-NAME OF MASTER ELECTRICIAN)

William WimberlyC-1545
MASTER CARD NO.PHONE 384 1257

PROPOSED CONSTRUCTION:

Fire Alarm

USE:

ELECTRIC PERMIT NO. _____

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
	For Issuing Each Permit	10 00	<u>10.00</u>
	Supplemental Fee	4 50	
APPLIANCE CHARGE			
Residential or General Commercial			
	Receptacle _____ Switch _____	40	
	Each Light Fixture, Socket, or Exit Light, Smoke Detector or Exhaust Fan	.30	
	EACH OUTLET FOR SPECIAL PURPOSE: Dishwasher, Garbage Grinder, Trash Compactor, G.F.I., Clothes Washer, Dryer, Electric Range, Ovens, Water Heater, Space Heater, Blast Coil Heater, (PER K.W.), Mercury Lamp, Quartz Lamp, Sodium Lamp, 20AMP Sign Circuit	70	
	X-Ray Unit	10.00	
	Area Lighting (First 3,000 Watts)	8 00	
	Each Additional 1,000 Watts	3 00	
MOTORS (1 H.P. AND OVER) TRANSFORMERS, ELEVATORS, WELDERS, GENERATORS, CHILLERS, SIGNS AND A/C UNITS (OVER 5 TONS)			
	First H.P. or Ton For each Unit	3 00	
	First KVA For Each Unit	3.00	
	Each Additional H.P., Ton or KVA up to 50	50	
	Each Additional H.P., Ton or KVA over 50	35	
	Temporary power or Pole	6 00	
ELECTRIC SERVICE OR MAIN DISCONNECT			
	Up to 200 AMP	6 00	
	400 AMP And 600 AMP	12 50	
	Over 600 AMP To 1200 AMP	25 00	
	Over 1200 AMP	50 00	
	Each Additional Meter Socket	50	
	Sub Panel, Motor Control Center Disconnect Switch, Transfer Switch (Each)	3 00	
	Swimming Pool (Residential)	20 00	
	Swimming Pool (Semi-Public)	30 00	
	Spas	8.00	
	Recreational Vehicle Spaces (Each)	3 00	

UNITS	DESCRIPTION	FEE	TOTAL
	Busways-Trolley or Plug-in (Ea 100 Ft)	3 00	
	Gas Pumps, Dispensers (Each)	3.00	
	Permanent A/C Unit (5 Tons or Less)	3 00	
	Each Air Handler	1 00	
RESIDENTIAL LOW VOLTAGE INSTALLATIONS			
	Speaker Outlets (Each)	30	
	Signal or Alarm Outlets (Each)	30	
	Amplifiers	2.00	
	Control Panel	.50	
	TV Master System	30	
	Telephone or Computer Outlet	30	
OTHER INSPECTIONS AND FEES: INCLUDES ISSUANCE FEES WHEN APPLICABLE			
	Inspections outside of normal business hours (minimum charge — three hours)	30 00 per hour	
	Reinspection fee assessed under provisions of TABLE 3-A of the Uniform Building Code = \$30 00 EACH	30 00 each	
	Inspections for which no fee is specifically indicated (minimum charge — one-half hour)	30 00 per hour	
	Additional plan review required by changes, additions or revisions to approved plans (minimum charge — one-half hour). After work hours — \$30 00 per hour — minimum 1 hour	30 00 per hour	
	Starter Permit	50 00	
CONTRACT PRICE OR COST OF INSTALLATION			
	Commercial — Security Alarms <u>Fire</u>		<u>61.00</u>
	— Music Systems		
	— Data Processing		
	— Communication		
	Conduit Only—Contract Price		
	All Misc Electric		

Electrical permit fees may be computed the same as building permit fees by using the cost of installation for valuation amount when such work is not included in the above schedule

2310-2432 11/06/90

RECEIPT

0005

ELEC 71.00

CASH 71.00

4357A000 10:27

I hereby certify that I have carefully examined and read the above application, that the same is true and correct, and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not.

SIGNED HOMEOWNER, CONTRACTOR

PERMIT FEE

LESS STARTER PERMIT

TOTAL FEES

71.00

PERMIT NO.

MUST BE MACHINE VALIDATED

BUILDING DEPT

DATE

Permit Expires 180 Days After Abandonment of Work

CITY OF LAS VEGAS, NEVADA

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

MIT NO. 90-007035



071

DEVELOPMENT PERMIT
FOR: SIGNS

LOG NO. & AREA

030-330-018
M/ 5476 attached

CONST. VAL. \$

500

ADDRESS OF
CONSTRUCTION888
2314 S RANCHO DE

OWNER

SOUTH WEST MEDICAL

PHONE

647-7020

CONTRACTOR

ACTION SIGNS

STATE
LICENSE NO.

24479

CITY
LICENSE NO.

211-01702-2-017328

LOT(S)

BLOCK

SUBDIVISION

PT. SE 4, SE 4, SEC. 32, T20S, R 61E

ZONE:

C-1
PR

PROPOSED CONSTRUCTION:

MATERIAL FOR SIGN

Metal ☒ Wood ☐ Plastic ☒ Other ☐

TYPE OF PROJECT.

New Sign ☒ Replacement ☐ Relocation ☐

TYPE	SIZE	HEIGHT ZONE			VALUATION	PERMIT FEE
NON-ELECTRIFIED:		A Up to 30'	B Over 30' up to 50'	C Over 50'		
Single faced	sq ft @	\$5 00	\$7.00	\$9.00	\$	\$
Double faced	50 # sq. ft. @	\$10.00	\$12.00	\$14.00	\$500	\$ 12
NEON OR OTHER ELECTRIFIED:						
Single faced	sq ft @	\$12.00	\$14 00	\$16.00	\$	\$
Double faced	sq ft @	\$16.00	\$18.00	\$20.00	\$	\$
FOR COMPUTER SIGNS OR SIGNS NOT INCLUDED ABOVE-USE CONST VAL						\$

FOR INSPECTIONS
CALL 799-2071

I hereby certify that I have examined and read the above application; that the same is true and correct; and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not.

SIGNED

MASTER NEON-ELECTRIC BILLBOARD CONTRACTOR

RECEIPT

SEE ATTACHED
ENGINEERING / PLANS
MONUMENT SIGN ONLYREPLACE EXIST.
SIGN.
(MONUMENT)

PLANNING DEPT

BUILDING DEPT

PLAN
REVIEW
FEEPERMIT
FEE
2310-2401TOTAL
FEES12-
12-

MUST BE MACHINE VALIDATED

Permit Expires 180 Days After Abandonment of Work

CITY OF LAS VEGAS, NEVADA

PERMIT NO.

90 00 3

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

F



46733

AIR CONDITIONING PERMIT

LOG NO. & AREA

2159

DATE

CONST. VAL. \$

8600

ADDRESS OF
CONSTRUCTION

888 Rancho

OWNER

Savira Health

PHONE

CONTRACTOR Sahara Air Conditioning

STATE
LICENSE NO

017859

CITY

LICENSE NO. C11012472019928

LOT(s) BLOCK

SUBDIVISION

ZONE

PROPOSED CONSTRUCTION

USE

Approval for the work under this permit will be given only after refuse
and debris have been removed from job site and public right of way.

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
1	For the issuance of each permit	15 00	15 00
	For issuing each supplemental permit	4 50	
UNIT FEE SCHEDULE			
	For the installation or relocation of each forced-air or gravity-type furnace or burner, including ducts and vents attached to such appliance, up to and including 100,000 Btu/h	9.00	
	For the installation or relocation of each forced-air or gravity-type furnace or burner, including ducts and vents attached to such appliance over 100,000 Btu/h.	11.00	
	For the installation or relocation of each floor furnace, including vent.	9 00	
	For the installation or relocation of each suspended heater, recessed wall heater or floor-mounted unit heater	9.00	
	For the installation, relocation or replacement of each appliance vent installed and not included in an appliance permit	4 50	
	For the repair of, alteration of, or addition to each heating appliance, refrigeration unit, cooling unit, absorption unit, or each heating, cooling absorption, or evaporative cooling system, including installation of controls regulated by this code	9 00	
	For the installation or relocation of each boiler or compressor to and including three tons, or each absorption system to and including 100 000 Btu/h	9 00	
	For the installation or relocation of each boiler or compressor over three tons to and including 15 tons, or each absorption system over 100,000 Btu/h and including 500,000 Btu/h.	16 50	
	For the installation or relocation of each boiler or compressor over 15 tons to and including 30 tons, or each absorption system over 500,000 Btu/h to and including 1,000,000 Btu/h	22.50	
	For the installation or relocation of each boiler or compressor over 30 tons to and including 50 tons, or for each absorption system over 1,000,000 Btu/h to and including 1,750,000 Btu/h.	33.50	
	For the installation or relocation of each boiler or refrigeration compressor over 50 tons, or each absorption system over 1,750,000 Btu/h	56 00	

UNITS	DESCRIPTION	FEE	TOTAL
	For each air-handling unit to and including 10,000 cubic feet per minute, including ducts attached thereto Note: This fee shall not apply to an air-handling unit which is a portion of a factory-assembled appliance, cooling unit, evaporative cooler or absorption unit for which a permit is required elsewhere in this code	6 50	
	For each air-handling unit over 10,000 cfm.	11 00	
	For each evaporative cooler other than portable type	6.50	
2	For each ventilation fan COMMERCIAL RESIDENTIAL	4 50 2 35	9 00
	For each ventilation system which is not a portion of any heating or air-conditioning system authorized by a permit.	6.50	
	For the installation of each hood which is served by mechanical exhaust, including the ducts for such hood	6 50	
	For each fire damper installed in an existing system	4 50	
OTHER INSPECTIONS AND FEES:			
	Inspections outside of normal business hours (minimum charge — three hours)	25 00 per hour	
	Reinspection fee assessed under provisions of TABLE 3-A of the Uniform Building Code = \$15 00 EACH	15 00 each	
	Inspections for which no fee is specifically indicated (minimum charge — one-half hour)	30 00 per hour	
	Additional plan review required by changes, additions or revisions to approved plans (minimum charge — two hours)	30 00 per hour	
	Mechanical permit fees may be computed the same as building permit fees by using the cost of installation for valuation amount when such work is not included in the above schedule		87.40
	Gas piping which is directly related and necessary to the repair or replacement of heating, air conditioning, or refrigeration systems not exceeding 500,000 BTU H	6 00	

2310-2435

RECEIPT

0006

A/C 113.40

CHEK 113.40

2701A000 14:09

10/03/90

I hereby certify that I have carefully examined and read the above application, that the same is true and correct; and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not.

SIGNED

CONTRACTOR

MASTER CARD NO

PERMIT
FEE

BY

Spec Cont'r or Owner

BUILDING DEPT

DATE

TOTAL
FEES

113.40


MUST BE MACHINE VALIDATED

Permit Expires 180 Days After Abandonment of Work

CITY OF LAS VEGAS, NEVADA

PERMIT NO.

00-000000

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

ELECTRICAL PERMIT

LOG NO. & AREA M-3831 DATE 0-24-90 CONST. VAL. \$ _____ADDRESS OF CONSTRUCTION 888 So. RANCHO OWNER SOUTHWEST MEDICALCONTRACTOR ABCO ELECTRIC, INC STATE LICENSE NO. 26334 CITY LICENSE NO. 628079
011-01795-2-JOE BLAUSTIKEN 218 PHONE 454-6254
(PRINT NAME OF MASTER ELECTRICIAN) MASTER CARD NO.PROPOSED CONSTRUCTION REMODEL X-RAY ROOMS USE _____ELECTRIC
PERMIT NO _____Approval for the work under this permit will be given only after refuse
and debris have been removed from job site and public right of way

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
1	For Issuing Each Permit	10.00	10.00
	Supplemental Fee	4.50	
APPLIANCE CHARGE			
Residential or General Commercial			
120	Receptacle <u>91</u> Switch <u>29</u>	40	48.00
103	Each Light Fixture, Socket, or Exit Light, Smoke Detector or Exhaust Fan	30	30.90
2	EACH OUTLET FOR SPECIAL PURPOSE Dishwasher, Garbage Grinder, Trash Compactor, GFI, Clothes Washer, Dryer, Electric Range, Ovens, Water Heater, Space Heater, Blast Coil Heater, (PER KW), Mercury Lamp, Quartz Lamp, Sodium Lamp, 20AMP Sign Circuit	.70	1.40
2	X-Ray Unit	10.00	20.00
	Area Lighting (First 3,000 Watts)	8.00	
	Each Additional 1,000 Watts	3.00	
MOTORS (1 H.P. AND OVER) TRANSFORMERS, ELEVATORS, WELDERS, GENERATORS, CHILLERS, SIGNS AND A/C UNITS (OVER 5 TONS)			
	First H.P. or Ton For each Unit	3.00	
	First KVA For Each Unit	3.00	
	Each Additional H.P., Ton or KVA up to 50	.50	
	Each Additional H.P., Ton or KVA over 50	.35	
	Temporary power or Pole	6.00	
ELECTRIC SERVICE OR MAIN DISCONNECT			
	Up to 200 AMP	6.00	
	400 AMP And 600 AMP	12.50	
	Over 600 AMP To 1200 AMP	25.00	
	Over 1200 AMP	50.00	
	Each Additional Meter Socket	5.00	
1	Sub Panel, Motor Control Center Disconnect Switch, Transfer Switch (Each)	3.00	3.00
	Swimming Pool (Residential)	20.00	
	Swimming Pool (Semi-Public)	30.00	
	Spas	8.00	
	Recreational Vehicle Spaces (Each)	3.00	

UNITS	DESCRIPTION	FEE	TOTAL
	Busways-Trolley or Plug-in (Ea 100 Ft)	3.00	
	Gas Pumps, Dispensers (Each)	3.00	
	Permanent A/C Unit (5 Tons or Less)	3.00	
	Each Air Handler	1.00	
RESIDENTIAL LOW VOLTAGE INSTALLATIONS			
	Speaker Outlets (Each)	.30	
	Signal or Alarm Outlets (Each)	30	
	Amplifiers	2.00	
	Control Panel	50	
	TV Master System	.30	
	Telephone or Computer Outlet	30	
OTHER INSPECTIONS AND FEES: INCLUDES ISSUANCE FEES WHEN APPLICABLE			
	Inspections outside of normal business hours (minimum charge — three hours)	30.00 per hour	
	Reinspection fee assessed under provisions of TABLE 3-A of the Uniform Building Code = \$30.00 EACH.	30.00 each	
	Inspections for which no fee is specifically indicated (minimum charge — one-half hour)	30.00 per hour	
	Additional plan review required by changes, additions or revisions to approved plans (minimum charge — one-half hour) After work hours — \$30.00 per hour — minimum 1 hour	30.00 per hour	
	Starter Permit	50.00	
CONTRACT PRICE OR COST OF INSTALLATION			
	Commercial —Burglar Alarms		
	—Music Systems		
	—Data Processing		
	—Communication		
	Conduit Only—Contract Price		
	All Misc Electric		

Electrical permit fees may be computed the same as building permit fees by using the cost of installation for valuation amount when such work is not included in the above schedule

2310-2432 08/24/90

RECEIPT

0005

ELEC 113.30

CHEK 113.30

0495A000 11:32

I hereby certify that I have carefully examined and read the above application, that the same is true and correct, and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not.

SIGNED HOMEOWNER, CONTRACTOR

BUILDING DEPT

DATE

Permit Expires 180 Days After Abandonment of Work

PERMIT
FEELESS
STARTER PERMITTOTAL
FEES

PERMIT NO

MUST BE MACHINE VALIDATED

CITY OF LAS VEGAS, NEVADA

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

PERMIT NO. 90-070247

PLUMBING PERMIT

LOG NO. & AREA

2/59

DATE 8-16-90

CONST VAL. \$

ADDRESS OF CONSTRUCTION 888 S. RANCHO RD.

OWNER 888 RANCHO MEDICAL LTD. PARTNERSHIP

CONTRACTOR JAY'S PLUMBING & SERVICE

STATE LICENSE NO 0010181

CITY LICENSE NO C-11-00721-2-003383

LOT(s) BLOCK SUBDIVISION

ZONE

PROPOSED CONSTRUCTION RADIOLOGY
TENANT IMPROVEMENT: SAN. WASTE & VENT/POT. WATER USEPLUMBING
PERMIT NO

Demrite Condo

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
1	For Issuing Each Permit	10 00	10.00
	For Issuing Each Supplemental Permit	4 50	
FIXTURE CHARGE			
6	Bathtub, Shower, Lavatory, Toilet, Urinal	EA 2 00	12.00
1	Floor Drain, Floor Sink, Wash Tray, Sink	EA 2 00	2.00
	Garbage Disposal, Clothes Washer, Dishwasher (residential)	EA 2 00	
	Garbage Disposal (commercial)	EA 8 00	
	Clothes Washer, Dishwasher (commercial)	EA 2 00	
	Clothes Dryer (gas) (venting)	2 00	
	Dental Unit	8 00	
	Drinking Fountain	2 00	
	Refrigerator - Ice Maker, Water Dispenser	2 00	
	Any other water using equipment, Attached Coffee Makers, Ice Makers	2 00	
	Hot Water Heater (Gas or Electric)	EA 2 00	
SEWER SYSTEM			
1	New, Replacement, Modification, or Any Drainage Work	10 00	10.00
	Grease or Sand Trap or Interceptor	2 00	
	Trailer Trap (rental parks)	5 00	
WATER SOFTENERS			
	Non Permanent Type (rental)	2 00	
	Permanent Type (connected to drain)	2 00	
WATER DISTRIBUTION SYSTEM			
	Single Family Dwelling	6 00	
	Multi-Family Dwelling	6 00	
	Plus Each Dwelling Unit	3 00	
1	Commercial Building per floor	3 00	3.00
1	Plus Each Unit (leased space or office)	2 00	2.00
	Hotel or Motel	8 00	
	Plus Each Unit	3 00	
	Trailer Park	30 00	
	Plus Each Space	2 00	
	Irrigation Single Family Dwelling	8 00	
	Irrigation Commercial Fee Based on Building Code Valuation Chart		
	Construction Valuation		

UNITS	DESCRIPTION	FEE	TOTAL
FUEL PIPING SYSTEM			
	Single Family Dwelling	6 00	
	Multi-Family Dwelling	10 00	
	Plus Each Unit	2 00	
	Commercial Building (per floor)	6.00	
	Plus Each Unit (leased space or office)	6 00	
	Medium Pressure System (Plan Check)	12 00	
	Each Gas Appliance (Any Type)	2 00	
	Steam Boilers	5 00	
SOLAR ENERGY SYSTEMS			
	Collectors (including piping) (per collector)	5 00	
	Storage Tanks (each)	5 00	
PIPELINE CONTRACT			
	For Onsite Sewer, Gas or Water Contract Value Fee based on Building Code Permit Valuation Chart		
OTHER INSPECTIONS AND FEES:			
	Inspections outside of normal business hours (minimum charge—three hours)	25 00 per hour	
	Under provisions of Table 3-A of the Uniform Building Code, work which has been inspected once and not approved may be subject to a Reinspection Fee not less than \$30 00 per each inspection during business hours	30 00 each	
	Additional plan review required by changes Additions to or revisions to approved plans (minimum charge two hours)	30 00 per hour	
	Plumbing permit fees may be computed the same as building permit fees by using the cost of installation for valuation amount when such work is not included in the above schedule		
	Construction Valuation		

FOR INSPECTIONS
CALL 799-2071SEWER # 7114-3654
CONNECTION

FIXTURES X 08/17/90

FEE ~~89.00~~

2310-2403

PERMIT
FEE 39.00TOTAL
FEES

RECEIPT

0002

PLBG 39.00

CHEK 39.00

0059A000 10:36

I hereby certify that I have carefully examined and read the above application, that the same is true and correct, and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not

SIGNED JAY'S PLUMBING & SERVICE, INC. CONTRACTOR MASTER CARD NO

BY Registered Master Plumber Spec Contractor or Owner

BUILDING DEPT

DATE 8/17/90

PERMIT NO.

CITY OF LAS VEGAS, NEVADA

LOG NO. & AREA _____ DATE 3/27/89 CONST. VAL. 88-019203DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

PLUMBING PERMIT

ADDRESS OF CONSTRUCTION 888 So. Rancho Drive OWNER Southwest Medical Assoc PHONE 877-8600CONTRACTOR Big Town Plbg. STATE LICENSE NO. 3241A CITY LICENSE NO. 01201

LOT(s) _____ BLOCK _____ SUBDIVISION _____ ZONE _____

PROPOSED CONSTRUCTION Replace underground gas line USE _____PLUMBING
PERMIT NO. _____

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
1	For Issuing Each Permit	10 00	10
	For Issuing Each Supplemental Permit	4 50	
FIXTURE CHARGE			
	Bathtub, Shower, Lavatory, Toilet, Urinal	EA 2 00	
	Floor Drain, Floor Sink, Wash Tray, Sink	EA 2 00	
	Garbage Disposal, Clothes Washer, Dishwasher (residential)	EA 2 00	
	Garbage Disposal (commercial)	EA 8 00	
	Clothes Washer, Dishwasher (commercial)	EA 2 00	
	Clothes Dryer (gas) (venting)	2 00	
	Dental Unit	8 00	
	Drinking Fountain	2 00	
	Refrigerator - Ice Maker, Water Dispenser	2 00	
	Any other water using equipment, Attached Coffee Makers, Ice Makers	2 00	
	Hot Water Heater (Gas or Electric)	EA 2 00	
SEWER SYSTEM			
	New, Replacement, Modification, or Any Drainage Work	10 00	
	Grease or Sand Trap or Interceptor	2 00	
	Trailer Trap (rental parks)	5 00	
WATER SOFTENERS			
	Non Permanent Type (rental)	2 00	
	Permanent Type (connected to drain)	2 00	
WATER DISTRIBUTION SYSTEM			
	Single Family Dwelling	6 00	
	Multi-Family Dwelling	6 00	
	Plus Each Dwelling Unit	3 00	
	Commercial Building per floor	3 00	
	Plus Each Unit (leased space or office)	2 00	
	Hotel or Motel	8 00	
	Plus Each Unit	3 00	
	Trailer Park	30 00	
	Plus Each Space	2 00	
	Irrigation Single Family Dwelling	8 00	
	Irrigation Commercial Fee Based on Building Code Valuation Chart		
	Construction Valuation _____		

UNITS	DESCRIPTION	FEE	TOTAL
FUEL PIPING SYSTEM			
	Single Family Dwelling	6 00	
	Multi-Family Dwelling	10 00	
	Plus Each Unit	2 00	
1	Commercial Building (per floor)	6 00	6-
	Plus Each Unit (leased space or office)	6 00	
	Medium Pressure System (Plan Check)	12 00	
	Each Gas Appliance (Any Type)	2 00	
	Steam Boilers	5 00	
SOLAR ENERGY SYSTEMS			
	Collectors (including piping) (per collector)	5 00	
	Storage Tanks (each)	5 00	
PIPELINE CONTRACT			
	For Onsite Sewer, Gas or Water Contract Value Fee based on Building Code Permit Valuation Chart		
OTHER INSPECTIONS AND FEES:			
	Inspections outside of normal business hours (minimum charge—three hours)	25 00 per hour	
	Under provisions of Table 3-A of the Uniform Building Code, work which has been inspected once and not approved may be subject to a Reinspection Fee not less than \$30 00 per each inspection during business hours	30 00 each	
	Additional plan review required by changes. Additions to or revisions to approved plans (minimum charge two hours)	30 00 per hour	
	Plumbing permit fees may be computed the same as building permit fees by using the cost of installation for valuation amount when such work is not included in the above schedule		
	Construction Valuation _____		

FOR INSPECTIONS
CALL 799-2071SEWER # 7114-3654
CONNECTION

RECEIPT

FIXTURES _____ X _____

FEE _____

2310-2403

PERMIT
FEE _____TOTAL
FEES 16 00

PERMIT NO. _____

MUST BE MACHINE VALIDATED

I hereby certify that I have carefully examined and read the above application, that the same is true and correct, and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not

Deamus K. Burton
SIGNED _____ CONTRACTOR _____ MASTER CARD NO. _____

BY _____ Registered Master Plumber Spec. Contr. or Owner

BUILDING DEPT

DATE 3/27/89

CITY OF LAS VEGAS, NEVADA

PERMIT NO. 1-098764

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

FO



28303

ELECTRICAL PERMIT

LOG NO. & AREA

M-1424

DATE 2/27/91

CONST. VAL. \$

ADDRESS OF
CONSTRUCTION

888 S. RANCHO DRIVE

OWNER

SOUTHWEST MEDICAL, INC.

CONTRACTOR

NEVCO AIR CONDITIONING & SHEET METAL

STATE

LICENSE NO. 24377

CITY

LICENSE NO. C11023112033289

JOHN O'BRYAN

(PRINT NAME OF MASTER ELECTRICIAN)

F-137

MASTER CARD NO

PHONE

362-9878

PROPOSED CONSTRUCTION:

SMOKE DETECTORS & HORNS

USE

ELECTRIC
PERMIT NO.Approval for the work under this permit will be given only after refuse
and debris have been removed from job site and public right of way

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
1	For Issuing Each Permit	10 00	10.00
	Supplemental Fee	4.50	
APPLIANCE CHARGE			
	Residential or General Commercial		
	Receptacle _____ Switch _____	40	
	Each Light Fixture, Socket, or Exit Light, Smoke Detector or Exhaust Fan	30	
	EACH OUTLET FOR SPECIAL PURPOSE Dishwasher, Garbage Grinder, Trash Compactor, G.F.I., Clothes Washer, Dryer, Electric Range, Ovens, Water Heater, Space Heater, Blast Coil Heater, (PER KW), Mercury Lamp, Quartz Lamp, Sodium Lamp, 20AMP Sign Circuit	70	
	X-Ray Unit	10 00	
	Area Lighting (First 3,000 Watts)	8 00	
	Each Additional 1,000 Watts	3 00	
MOTORS (1 H.P. AND OVER) TRANSFORMERS, ELEVATORS, WELDERS, GENERATORS, CHILLERS, SIGNS AND A/C UNITS (OVER 5 TONS)			
	First H.P. or Ton For each Unit	3 00	
	First KVA For Each Unit	3 00	
	Each Additional H.P., Ton or KVA up to 50	50	
	Each Additional H.P., Ton or KVA over 50	35	
	Temporary power or Pole	6 00	
ELECTRIC SERVICE OR MAIN DISCONNECT			
	Up to 200 AMP	6 00	
	400 AMP And 600 AMP	12.50	
	Over 600 AMP To 1200 AMP	25 00	
	Over 1200 AMP	50.00	
	Each Additional Meter Socket	50	
	Sub Panel, Motor Control Center Disconnect Switch, Transfer Switch (Each)	3 00	
	Swimming Pool (Residential)	20 00	
	Swimming Pool (Semi-Public)	30 00	
	Spas	8 00	
	Recreational Vehicle Spaces (Each)	3.00	

UNITS	DESCRIPTION	FEE	TOTAL
	Busways-Trolley or Plug-in (Ea 100 Ft)	3 00	
	Gas Pumps, Dispensers (Each)	3 00	
	Permanent A/C Unit (5 Tons or Less)	3 00	
	Each Air Handler	1 00	
RESIDENTIAL LOW VOLTAGE INSTALLATIONS			
	Speaker Outlets (Each)	30	
	Signal or Alarm Outlets (Each)	30	
	Amplifiers	2 00	
	Control Panel	50	
	TV Master System	30	
	Telephone or Computer Outlet	30	
OTHER INSPECTIONS AND FEES: INCLUDES ISSUANCE FEES WHEN APPLICABLE			
	Inspections outside of normal business hours (minimum charge — three hours)	30 00 per hour	
	Reinspection fee assessed under provisions of TABLE 3-A of the Uniform Building Code = \$30 00 EACH	30 00 each	
	Inspections for which no fee is specifically indicated (minimum charge — one-half hour)	30 00 per hour	
	Additional plan review required by changes, additions or revisions to approved plans (minimum charge — one-half hour) After work hours — \$30 00 per hour — minimum 1 hour	30 00 per hour	
	Starter Permit	50 00	
CONTRACT PRICE OR COST OF INSTALLATION			
	Commercial —Burglar Alarms		
	—Music Systems		
	—Data Processing		
	—Communication		
	Conduit Only—Contract Price		
	All Misc Electric FIRE ALARM	56.00	56.00

Electrical permit fees may be computed
the same as building permit fees by
using the cost of installation for valuation
amount when such work is not included
in the above schedule

2310-2432

02/28/91

RECEIPT

0002

ELEC 66.00

CHEK 66.00

9882A000 09:40

I hereby certify that I have carefully examined and read the above application, that the
same is true and correct, and that the work herein described is to be done in accordance
with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and
the State Laws, whether herein specified or not.

SIGNED HOMEOWNER, CONTRACTOR

BUILDING DEPT

DATE

Permit Expires 180 Days After Abandonment of Work

PERMIT
FEE

10.00

LESS
STARTER PERMITTOTAL
FEES

66.00

PERMIT NO.

MUST BE MACHINE VALIDATED

CITY OF LAS VEGAS, NEVADA

PERMIT NO.

92-131688

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

PLUMBING PERMIT

LOG NO. & AREA M 9383

71176

CONST. VAL. \$

ADDRESS OF CONSTRUCTION 888 So Rancho Dr. OWNER Sizana Heat Services PHONE 458-0906CONTRACTOR LAKE MEAD PLUMBING CO STATE LICENSE NO. 29305 CITY LICENSE NO. 042490

LOT(s) _____ BLOCK _____ SUBDIVISION _____ ZONE _____

PROPOSED CONSTRUCTION REMODEL

USE _____

PLUMBING
PERMIT NO _____

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way

UNITS	DESCRIPTION	FEE	TOTAL
1	PERMIT ISSUANCE		
	For Issuing Each Permit	10 70	10.70
	For Issuing Each Supplemental Permit	4 85	
	FIXTURE CHARGE		
	Bathtub, Shower, Lavatory, Toilet, Urinal	EA 2 15	
2	Floor Drain, Floor Sink, Wash Tray, Sink	EA 2 15	4.30
	Garbage Disposal, Clothes Washer, Dishwasher (residential)	EA 2 15	
	Garbage Disposal (commercial)	EA 8 60	
	Clothes Washer, Dishwasher (commercial)	EA 2 15	
	Clothes Dryer (gas) (venting)	2 15	
	Dental Unit	8 60	
	Drinking Fountain	2 15	
	Refrigerator - Ice Maker, Water Dispenser	2 15	
	Any other water using equipment, Attached Coffee Makers, Ice Makers	2 15	
	Hot Water Heater (Gas or Electric)	EA 2 15	
	SEWER SYSTEM		
	New, Replacement, Modification, or Any Drainage Work	10 70	
	Grease or Sand Trap or Interceptor	2 15	
	Trailer Trap (rental parks)	5 35	
	WATER SOFTENERS		
	Non Permanent Type (rental)	2 15	
	Permanent Type (connected to drain)	2 15	
	WATER DISTRIBUTION SYSTEM		
	Single Family Dwelling	6 45	
	Multi-Family Dwelling	6 45	
	Plus Each Dwelling Unit	3 25	
1	Commercial Building per floor	3 25	3.25
	Plus Each Unit (leased space or office)	2 15	2.15
	Hotel or Motel	8 60	
	Plus Each Unit	3 25	
	Trailer Park	32 10	
	Plus Each Space	2 15	
	Irrigation Single Family Dwelling	8 60	
	Irrigation Commercial Fee Based on Building Code Valuation Chart		
	Construction Valuation _____		

UNITS	DESCRIPTION	FEE	TOTAL
	FUEL PIPING SYSTEM		
	Single Family Dwelling	6 45	
	Multi-Family Dwelling	10 70	
	Plus Each Unit	2 15	
	Commercial Building (per floor)	6 45	
	Plus Each Unit (leased space or office)	6 45	
	Medium Pressure System (Plan Check)	12 85	
	Each Gas Appliance (Any Type)	2 15	
	Steam Boilers	5 60	
	SOLAR ENERGY SYSTEMS		
	Collectors (including piping) (per collector)	5 60	
	Storage Tanks (each)	5 60	
	PIPELINE CONTRACT		
	For Onsite Sewer, Gas or Water Contract Value Fee based on Building Code Permit Valuation Chart		
	OTHER INSPECTIONS AND FEES:		
	Inspections outside of normal business hours (minimum charge—three hours)	25 00 per hour	
	Under provisions of Table 3-A of the Uniform Building Code, work which has been inspected once and not approved may be subject to a Reinspection Fee not less than \$30 00 per each inspection during business hours	30 00 each	
	Additional plan review required by changes Additions to or revisions to approved plans (minimum charge two hours)	30 00 per hour	
	Plumbing permit fees may be computed the same as building permit fees by using the cost of installation for valuation amount when such work is not included in the above schedule		
	Construction Valuation _____		

FOR INSPECTIONS
CALL 799-2071SEWER # 7114-3654
CONNECTION

RECEIPT

0002

PLBG 20.40

CHEK 20.40

7904A000 14:33

FIXTURES _____ X 01/02/92

FEE _____

2310-2403

PERMIT

FEE 20.40TOTAL
FEES _____

PERMIT NO _____

MUST BE MACHINE VALIDATED

I hereby certify that I have carefully examined and read the above application, that the same is true and correct, and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not

SIGNED

CONTRACTOR

MASTER CARD NO 29305

BY

Registered Master Plumber Spec. Contr. or Owner

BUILDING DEPT

DATE 1/2/92

CITY OF LAS VEGAS, NEVADA

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

FOR



27186

PERMIT NO.

91-098625

ELECTRICAL PERMIT

LOG NO. & AREA M-306 DATE 2-26-11 CONST. VAL. \$ADDRESS OF CONSTRUCTION 888 S Rancho Rd OWNER Southwest MedicalCONTRACTOR Holland & Holland STATE LICENSE NO. 021113 CITY LICENSE NO. 021963(PRINT NAME OF MASTER ELECTRICIAN) B. J. Holland MASTER CARD NO. 165 PHONE 362-6812PROPOSED CONSTRUCTION remodel USE:

ELECTRIC PERMIT NO. _____

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
	For Issuing Each Permit	10.00	10.00
	Supplemental Fee	4.50	
APPLIANCE CHARGE			
Residential or General Commercial			
33	Receptacle <u>28</u> Switch <u>5</u>	40	13.20
10	Each Light Fixture, Socket, or Exit Light, Smoke Detector or Exhaust Fan	.30	3.00
	EACH OUTLET FOR SPECIAL PURPOSE Dishwasher, Garbage Grinder, Trash Compactor, GFI, Clothes Washer, Dryer, Electric Range, Ovens, Water Heater, Space Heater, Blast Coil Heater, (PER K.W.), Mercury Lamp, Quartz Lamp, Sodium Lamp, 20AMP Sign Circuit	.70	
	X-Ray Unit	10.00	
	Area Lighting (First 3,000 Watts)	8.00	
	Each Additional 1,000 Watts	3.00	
MOTORS (1 H.P. AND OVER) TRANSFORMERS, ELEVATORS, WELDERS, GENERATORS, CHILLERS, SIGNS AND A/C UNITS (OVER 5 TONS)			
	First H.P. or Ton For each Unit	3.00	
	First KVA For Each Unit	3.00	
	Each Additional H.P., Ton or KVA up to 50	50	
	Each Additional H.P., Ton or KVA over 50	35	
	Temporary power or Pole	6.00	
ELECTRIC SERVICE OR MAIN DISCONNECT			
	Up to 200 AMP	6.00	
	400 AMP And 600 AMP	12.50	
	Over 600 AMP To 1200 AMP	25.00	
	Over 1200 AMP	50.00	
	Each Additional Meter Socket	50	
1	Sub Panel, Motor Control Center Disconnect Switch, Transfer Switch (Each)	3.00	300
	Swimming Pool (Residential)	20.00	
	Swimming Pool (Semi-Public)	30.00	
	Spas	8.00	
	Recreational Vehicle Spaces (Each)	3.00	

UNITS	DESCRIPTION	FEE	TOTAL
	Busways-Trolley or Plug-in (Ea. 100 Ft)	3.00	
	Gas Pumps, Dispensers (Each)	3.00	
2	Permanent A/C Unit (5 Tons or Less)	3.00	600
	Each Air Handler	1.00	
RESIDENTIAL LOW VOLTAGE INSTALLATIONS			
	Speaker Outlets (Each)	30	
	Signal or Alarm Outlets (Each)	30	
	Amplifiers	2.00	
	Control Panel	.50	
	TV Master System	30	
	Telephone or Computer Outlet	30	
OTHER INSPECTIONS AND FEES: INCLUDES ISSUANCE FEES WHEN APPLICABLE			
	Inspections outside of normal business hours (minimum charge — three hours)	30.00 per hour	
	Reinspection fee assessed under provisions of TABLE 3-A of the Uniform Building Code = \$30.00 EACH	30.00 each	
	Inspections for which no fee is specifically indicated (minimum charge — one-half hour)	30.00 per hour	
	Additional plan review required by changes, additions or revisions to approved plans (minimum charge — one-half hour) After work hours — \$30.00 per hour — minimum 1 hour	30.00 per hour	
	Starter Permit	50.00	
CONTRACT PRICE OR COST OF INSTALLATION			
	Commercial — Burglar Alarms		
	— Music Systems		
	— Data Processing		
	— Communication		
	Conduit Only—Contract Price		
	All Misc Electric		

Electrical permit fees may be computed the same as building permit fees by using the cost of installation for valuation amount when such work is not included in the above schedule.

2310-2432 02/27/91

RECEIPT

0006

ELEC 29.20

CHEK 29.20

9791A000 10:15

I hereby certify that I have carefully examined and read the above application; that the same is true and correct; and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not.

SIGNED HOMEOWNER, CONTRACTOR

PERMIT FEE

LESS STARTER PERMIT

TOTAL FEES 29.20

PERMIT NO. _____

MUST BE MACHINE VALIDATED

Permit Expires 180 Days After Abandonment of Work

CITY OF LAS VEGAS, NEVADA

PERMIT NO. 00-076622

68

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

FOR INSPECTIONS, CALL 799-2071

DEVELOPMENT PERMIT

FOR: Commercial and Public Structures.

LOG NO. & AREA 2-159 DATE 7-16-90 CONST. VAL. \$ 100,000ADDRESS OF CONSTRUCTION 888 So RANCHO Dr. OWNER SIERRA HEALTH SERVICES PHONE 877-519CONTRACTOR DUNNITE CONST INC STATE LICENSE NO 0018138 CITY LICENSE NO. 35664LOT(S) Block 32 T20S R61E ZONE E1PROPOSED CONSTRUCTION: INTERIOR Remodel USE: _____ADD'L. PERMITS REQ'D: Air Cond. ☒ Elec. ☒ Plumbing ☒ Signs ☒ Paving ☐ Fence ☐ Fire S.S. ☒ Off-Site P. ☐OCCUPANCY GROUP B2 CONSTRUCTION TYPE V-N SPRINKLEREDMATERIALS OF CONSTRUCTION: Wood Frame ☐ Concrete Block ☐ Reinforced Concrete ☐ Steel Frame ☒SQUARE FEET OF FLOOR AREAS: 1st REMODEL 3000 2nd _____ 3rd _____ Other _____ TOTAL SQ FT 3000ARCHITECT _____ ENGINEER CASH DAN NO. of UNITS _____ NO. of STORIES 1

OTHER INSPECTIONS AND FEES

1. Inspections outside of normal business hours = \$30.00 per hour (minimum charge three hours)
2. Re-inspection fee during normal business hours assessed under provisions of TABLE 3-A of the Uniform Building Code = \$30.00 each
3. Inspections during normal business hours for which no fee is specifically indicated = \$30.00 per hour (minimum charge one half hour)
4. Additional plan review required by changes, additions or revisions to approved plans = \$30.00 per hour (minimum charge two hours)

FOR INSPECTIONS, CALL 799-2071

CONDITIONS OF THE PERMIT:

1. I agree to call the City Building Department for inspections before concrete is poured, before rough wiring, electrical, plumbing, framing is covered. Also for air conditioning, drywall and sheathing inspection
2. I agree that when the job is completed that I will call for final inspection before occupancy
3. I agree to perform all construction in accordance with City Ordinances and Building Codes
4. The Contractor's signature below denotes authority from the owner to sign in his behalf and that the owner is aware of all requirements of this application and permit. Separate permits must be taken out for work outlined above this agreement
5. I have read and understand the contents of this application and permit, I hereby state that the information I have supplied on this application is true and correct

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way

SIGNED _____ CONTRACTOR

BY _____ AGENT/OWNER

LICENSE DEPT _____ DATE 7-23-90

PLANNING DEPT _____ DATE _____

I hereby certify that I have reviewed this application and the proposed plans and have found that the proposed development meets the requirements of the City of Las Vegas Flood Hazard Reduction Ordinance for the issuance of this Development Permit

LAND DEVELOPMENT AND FLOOD CONTROL ENGINEER _____ DATE 7/27/90FIRE DEPARTMENT _____ DATE 7/27/90BUILDING DEPT _____ DATE 7/27/90

SPECIAL CONDITIONS

INTERIOR REMODEL
See Plans

RECEIPT

0006

SEWR 1092.00

COMM 520.00

CHEK 1612.00

8826A000 15:21

SEWER CONNECTION
7114-3654FIXTURES 7 X 156

07/27/90

FEE \$1,092.00PLAN REVIEW FEE PD2310-2401
PERMIT FEE 520.00TOTAL FEES 1,612.00

PERMIT NO. _____

MUST BE MACHINE VALIDATED

Permit Expires 180 Days After Abandonment of Work

LOG NO. & AREA M-306

DATE

CONST. VAL. \$

DEPARTMENT OF BUILDING AND SAFETY

PHONE 386-6251

PLUMBING PERMIT

ADDRESS OF
CONSTRUCTION888 S. RANCH DR

OWNER

SILVER HAZARD SERVICE

PHONE

CONTRACTOR

LAKE MEAD PLUMBING CO

STATE

LICENSE NO

29305

CITY

LICENSE NO

C11-03437-2-042490

LOT(S)

BLOCK

SUBDIVISION

ZONE

PROPOSED CONSTRUCTION

REMODEL

USE

PLUMBING
PERMIT NOApproval for the work under this permit will be given only after refuse
and debris have been removed from job site and public right of way

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
1	For Issuing Each Permit	10 00	10.00
	For Issuing Each Supplemental Permit	4 50	
FIXTURE CHARGE			
47	Bathtub, Shower, Lavatory, Toilet, Urinal	EA 2 00	8.00
	Floor Drain, Floor Sink, Wash Tray, Sink	EA 2 00	14.00
	Garbage Disposal, Clothes Washer, Dishwasher (residential)	EA 2 00	
	Garbage Disposal (commercial)	EA 8 00	
	Clothes Washer, Dishwasher (commercial)	EA 2 00	
	Clothes Dryer (gas) (venting)	2 00	
	Dental Unit	8 00	
	Drinking Fountain	2 00	
	Refrigerator - Ice Maker, Water Dispenser	2 00	
	Any other water using equipment, Attached Coffee Makers, Ice Makers	2 00	
	Hot Water Heater (Gas or Electric)	EA 2 00	
SEWER SYSTEM			
1	New, Replacement, Modification, or Any Drainage Work	10 00	10.00
	Grease or Sand Trap or Interceptor	2 00	
	Trailer Trap (rental parks)	5 00	
WATER SOFTENERS			
	Non Permanent Type (rental)	2 00	
	Permanent Type (connected to drain)	2 00	
WATER DISTRIBUTION SYSTEM			
	Single Family Dwelling	6 00	
	Multi-Family Dwelling	6 00	
	Plus Each Dwelling-Unit	3 00	
1	Commercial Building per floor	3 00	3.00
1	Plus Each Unit (leased space or office)	2 00	2.00
	Hotel or Motel	8 00	
	Plus Each Unit	3 00	
	Trailer Park	30 00	
	Plus Each Space	2 00	
	Irrigation Single Family Dwelling	8 00	
	Irrigation Commercial Fee Based on Building Code Valuation Chart Construction Valuation		

UNITS	DESCRIPTION	FEE	TOTAL
FUEL PIPING SYSTEM			
	Single Family Dwelling	6 00	
	Multi-Family Dwelling	10 00	
	Plus Each Unit	2 00	
	Commercial Building (per floor)	6 00	
	Plus Each Unit (leased space or office)	6 00	
	Medium Pressure System (Plan Check)	12 00	
	Each Gas Appliance (Any Type)	2 00	
	Steam Boilers	5 00	
SOLAR ENERGY SYSTEMS			
	Collectors (including piping) (per collector)	5 00	
	Storage Tanks (each)	5 00	
PIPELINE CONTRACT			
	For Onsite Sewer, Gas or Water Contract Value Fee based on Building Code Permit Valuation Chart		
OTHER INSPECTIONS AND FEES:			
	Inspections outside of normal business hours (minimum charge—three hours)	25 00 per hour	
	Under provisions of Table 3-A of the Uniform Building Code, work which has been inspected once and not approved may be subject to a Reinspection Fee not less than \$30.00 per each inspection during business hours	30 00 each	
	Additional plan review required by changes. Additions to or revisions to approved plans (minimum charge two hours)	30 00 per hour	
	Plumbing permit fees may be computed the same as building permit fees by using the cost of installation for valuation amount when such work is not included in the above schedule		
	Construction Valuation		

FOR INSPECTIONS
CALL 799-2071SEWER # 7114-3654
CONNECTIONFIXTURES X 02/22/91

FEE

2310-2403
PERMIT
FEETOTAL
FEES47.00

RECEIPT

0006

PLBG 47.00

CHEK 47.00

9526A000 11:26

I hereby certify that I have carefully examined and read the above application; that the same is true and correct, and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not

SIGNED

CONTRACTOR

MASTER CARD NO

BY

Registered Master Plumber Spec Contractor or Owner

BUILDING DEPT

DATE

PERMIT NO.

CITY OF LAS VEGAS, NEVADA

PERMIT NO. 1-098191

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

FOR INSPECTIONS, CALL 799-2071

AIR CONDITIONING PERMIT

80

LOG NO. & AREA

DATE

2/21/91

CONST. VAL. \$

ADDRESS OF
CONSTRUCTION

888 S. Rancho

OWNER

Southwest Medical Inc.

PHONE

CONTRACTOR Sahara Air Conditioning

STATE

LICENSE NO. 017859

CITY

LICENSE NO. C11012472019928

LOT(s) BLOCK

SUBDIVISION

ZONE

PROPOSED CONSTRUCTION Reroute ductwork and install two three ton USE

straight cool units

Approval for the work under this permit will be given only after refuse
and debris have been removed from job site and public right of way

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
1	For the issuance of each permit	15 00	15.00
	For issuing each supplemental permit	4 50	
UNIT FEE SCHEDULE			
	For the installation or relocation of each forced-air or gravity-type furnace or burner, including ducts and vents attached to such appliance, up to and including 100,000 Btu/h	9 00	
	For the installation or relocation of each forced-air or gravity-type furnace or burner, including ducts and vents attached to such appliance over 100,000 Btu/h	11 00	
	For the installation or relocation of each floor furnace, including vent	9 00	
	For the installation or relocation of each suspended heater, recessed wall heater or floor-mounted unit heater	9 00	
	For the installation, relocation or replacement of each appliance vent installed and not included in an appliance permit	4 50	
2	For the repair of, alteration of, or addition to each heating appliance, refrigeration unit, cooling unit, absorption unit, or each heating, cooling absorption, or evaporative cooling system, including installation of controls regulated by this code	9 00	18.00
2	For the installation or relocation of each boiler or compressor to and including three tons, or each absorption system to and including 100,000 Btu/h.	9 00	18.00
	For the installation or relocation of each boiler or compressor over three tons to and including 15 tons, or each absorption system over 100,000 Btu/h and including 500,000 Btu/h	16.50	
	For the installation or relocation of each boiler or compressor over 15 tons to and including 30 tons, or each absorption system over 500,000 Btu/h to and including 1,000,000 Btu/h	22 50	
	For the installation or relocation of each boiler or compressor over 30 tons to and including 50 tons, or for each absorption system over 1,000,000 Btu/h to and including 1,750,000 Btu/h	33.50	
	For the installation or relocation of each boiler or refrigeration compressor over 50 tons, or each absorption system over 1,750,000 Btu/h	56 00	

UNITS	DESCRIPTION	FEE	TOTAL
	For each air-handling unit to and including 10,000 cubic feet per minute, including ducts attached thereto. Note: This fee shall not apply to an air-handling unit which is a portion of a factory-assembled appliance, cooling unit, evaporative cooler or absorption unit for which a permit is required elsewhere in this code	6 50	
	For each air-handling unit over 10,000 cfm.	11 00	
	For each evaporative cooler other than portable type	6 50	
1	For each ventilation fan COMMERCIAL RESIDENTIAL	4 50 2 35	4.50
	For each ventilation system which is not a portion of any heating or air-conditioning system authorized by a permit	6 50	
	For the installation of each hood which is served by mechanical exhaust, including the ducts for such hood	6.50	
	For each fire damper installed in an existing system	4 50	
OTHER INSPECTIONS AND FEES:			
	Inspections outside of normal business hours (minimum charge — three hours)	25 00 per hour	
	Reinspection fee assessed under provisions of TABLE 3-A of the Uniform Building Code = \$15 00 EACH	15 00 each	
	Inspections for which no fee is specifically indicated (minimum charge — one-half hour)	30 00 per hour	
	Additional plan review required by changes, additions or revisions to approved plans (minimum charge — two hours)	30 00 per hour	
	Mechanical permit fees may be computed the same as building permit fees by using the cost of installation for valuation amount when such work is not included in the above schedule		
	Gas piping which is directly related and necessary to the repair or replacement of heating, air conditioning, or refrigeration systems not exceeding 500,000 BTUH	6 00	

2310-2435

RECEIPT

0002

A/C 55.50

CHEK 55.50

9485A000 14:25

02/21/91

I hereby certify that I have carefully examined and read the above application; that the same is true and correct, and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not

SIGNED

CONTRACTOR

MASTER CARD NO

BY

Spec. Contr. or Owner

BUILDING DEPT

DATE

PERMIT
FEETOTAL
FEES

55.50

MUST BE MACHINE VALIDATED

Permit Expires 180 Days After Abandonment of Work

CITY OF LAS VEGAS, NEVADA

PERMIT NO.

41-095506

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251030-330-078
FOR INSPECTIONS, CALL 799-2071DEVELOPMENT PERMIT
FOR: Commercial and Public StructuresLOG NO. & AREA m-306DATE 1-15-91CONST. VAL. \$ 600,000ADDRESS OF CONSTRUCTION 888 S. RANCHO DRIVE

St 104

OWNER SIERRA HEALTH SERVICESPHONE 595-2464
458-6579CONTRACTOR DUNRITE CONSTRUCTIONSTATE LICENSE NO. 0018138CITY LICENSE NO. 035664

A POR OF THE S 1/2 OF SEC. 32 T20S R61E

LOT(s) _____ BLOCK _____ SUBDIVISION _____ ZONE C-1PROPOSED CONSTRUCTION: INTERIOR REMODEL

USE: _____

ADD'L. PERMITS REQ'D: Air Cond. ☐ Elec. ☒ Plumbing ☒ Signs ☐ Paving ☐ Fence ☐ Fire S.S. ☒ Off-Site P. ☐OCCUPANCY GROUP B-2 CONSTRUCTION TYPE V-N SPRINKLERMATERIALS OF CONSTRUCTION: Wood Frame ☒ Concrete Block ☐ Reinforced Concrete ☐ Steel Frame ☐SQUARE FEET OF FLOOR AREAS: 1st 1760 2nd — 3rd — Other — TOTAL SQ. FT. 1760

ARCHITECT _____ ENGINEER _____ NO of UNITS _____ NO of STORIES _____

OTHER INSPECTIONS AND FEES

- 1 Inspections outside of normal business hours = \$30.00 per hour (minimum charge three hours)
- 2 Re-inspection fee during normal business hours assessed under provisions of TABLE 3-A of the Uniform Building Code = \$30.00 each
- 3 Inspections during normal business hours for which no fee is specifically indicated = \$30.00 per hour (minimum charge one half hour)
- 4 Additional plan review required by changes, additions or revisions to approved plans = \$30.00 per hour (minimum charge two hours)

FOR INSPECTIONS, CALL 799-2071

CONDITIONS OF THE PERMIT:

- 1 I agree to call the City Building Department for inspections before concrete is poured, before rough wiring, electrical, plumbing, framing is covered. Also for air conditioning, drywall and sheathing inspection
- 2 I agree that when the job is completed that I will call for final inspection before occupancy
- 3 I agree to perform all construction in accordance with City Ordinances and Building Codes
- 4 The Contractor's signature below denotes authority from the owner to sign in his behalf and that the owner is aware of all requirements of this application and permit. Separate permits must be taken out for work outlined above this agreement
- 5 I have read and understand the contents of this application and permit, I hereby state that the information I have supplied on this application is true and correct

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way

SIGNED [Signature] CONTRACTOR

BY _____ AGENT/OWNER

LICENSE DEPT _____ DATE 1/15/91

PLANNING DEPT _____ DATE _____

I hereby certify that I have reviewed this application and the proposed plans and have found that the proposed development meets the requirements of the City of Las Vegas Flood Hazard Reduction Ordinance for the issuance of this Development Permit

LAND DEVELOPMENT AND FLOOD CONTROL ENGINEER _____ DATE _____

FIRE DEPARTMENT _____ DATE 1/28/91

BUILDING DEPT _____ DATE _____

SPECIAL CONDITIONS

INTERIOR
RE-MODEL
ONLY

SEE PLANS

RECEIPT

***0002**
SEWR 624.00
COMM 368.00
CHK 992.00
8053A000 08:33

SEWER CONNECTION
7114-3654FIXTURES 4 X 156.00
01/28/91FEE \$624.00PLAN REVIEW FEE FD2310-2401 PERMIT FEE 368.00TOTAL FEES 992.00

PERMIT NO. _____

MUST BE MACHINE VALIDATED

Permit Expires 180 Days After Abandonment of Work

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

FOR INSPECTIONS, CALL 799-2071

ELECTRICAL PERMIT

LOG NO. & AREA M-306 DATE 2-26-91 CONST. VAL. \$ADDRESS OF CONSTRUCTION 888 S Rancho Rd OWNER Southwest MedicalCONTRACTOR Holland & Holland STATE LICENSE NO 021113 CITY LICENSE NO 021963(PRINT NAME OF MASTER ELECTRICIAN) B. H. Holland MASTER CARD NO 165 PHONE 362-6812PROPOSED CONSTRUCTION: remodel USE:

ELECTRIC PERMIT NO. _____

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
	For Issuing Each Permit	10.00	10.00
	Supplemental Fee	4.50	
APPLIANCE CHARGE			
Residential or General Commercial			
33	Receptacle <u>28</u> Switch <u>5</u>	.40	13.20
10	Each Light Fixture, Socket, or Exit Light, Smoke Detector or Exhaust Fan	30	3.00
	EACH OUTLET FOR SPECIAL PURPOSE Dishwasher, Garbage Grinder, Trash Compactor, G.F.I., Clothes Washer, Dryer, Electric Range, Ovens, Water Heater, Space Heater, Blast Coil Heater, (PER K.W.), Mercury Lamp, Quartz Lamp, Sodium Lamp, 20AMP Sign Circuit	.70	
	X-Ray Unit	10.00	
	Area Lighting (First 3,000 Watts)	8.00	
	Each Additional 1,000 Watts	3.00	
MOTORS (1 H.P. AND OVER) TRANSFORMERS, ELEVATORS, WELDERS, GENERATORS, CHILLERS, SIGNS AND A/C UNITS (OVER 5 TONS)			
	First H.P. or Ton For each Unit	3.00	
	First KVA For Each Unit	3.00	
	Each Additional H.P., Ton or KVA up to 50	50	
	Each Additional H.P., Ton or KVA over 50	35	
	Temporary power or Pole	6.00	
ELECTRIC SERVICE OR MAIN DISCONNECT			
	Up to 200 AMP	6.00	
	400 AMP And 600 AMP	12.50	
	Over 600 AMP To 1200 AMP	25.00	
	Over 1200 AMP	50.00	
	Each Additional Meter Socket	.50	
1	Sub Panel, Motor Control Center Disconnect Switch, Transfer Switch (Each)	3.00	3.00
	Swimming Pool (Residential)	20.00	
	Swimming Pool (Semi-Public)	30.00	
	Spas	8.00	
	Recreational Vehicle Spaces (Each)	3.00	

UNITS	DESCRIPTION	FEE	TOTAL
	Busways-Trolley or Plug-in (Ea 100 Ft)	3.00	
	Gas Pumps, Dispensers (Each)	3.00	
2	Permanent A/C Unit (5 Tons or Less)	3.00	6.00
	Each Air Handler	1.00	
RESIDENTIAL LOW VOLTAGE INSTALLATIONS			
	Speaker Outlets (Each)	30	
	Signal or Alarm Outlets (Each)	30	
	Amplifiers	2.00	
	Control Panel	.50	
	TV Master System	30	
	Telephone or Computer Outlet	.30	
OTHER INSPECTIONS AND FEES: INCLUDES ISSUANCE FEES WHEN APPLICABLE			
	Inspections outside of normal business hours (minimum charge — three hours)	30.00 per hour	
	Reinspection fee assessed under provisions of TABLE 3-A of the Uniform Building Code = \$30.00 EACH	30.00 each	
	Inspections for which no fee is specifically indicated (minimum charge — one-half hour)	30.00 per hour	
	Additional plan review required by changes, additions or revisions to approved plans (minimum charge — one-half hour) After work hours — \$30.00 per hour — minimum 1 hour	30.00 per hour	
	Starter Permit	50.00	
CONTRACT PRICE OR COST OF INSTALLATION			
	Commercial — Burglar Alarms		
	— Music Systems		
	— Data Processing		
	— Communication		
	Conduit Only—Contract Price		
	All Misc. Electric		

Electrical permit fees may be computed the same as building permit fees by using the cost of installation for valuation amount when such work is not included in the above schedule.

2310-2432

02/27/91

RECEIPT

***006**

ELEC 29.20

CHEK 29.20

9791A000 10:15

I hereby certify that I have carefully examined and read the above application, that the same is true and correct, and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not

SIGNED HOMEOWNER, CONTRACTOR

PERMIT FEE

LESS STARTER PERMIT

TOTAL FEES 29.20

PERMIT NO. _____

MUST BE MACHINE VALIDATED

Permit Expires 180 Days After Abandonment of Work

LOG NO. & AREA M-306

26902

CONST. VAL. \$

DEPARTMENT OF BUILDING AND SAFETY

PHONE 386-6251

PLUMBING PERMIT

ADDRESS OF CONSTRUCTION 888 So. Rancho Dr OWNER SIEGA HEALTH SERVICES PHONECONTRACTOR LAKE MEAD PLUMBING CO STATE LICENSE NO. 29305 CITY LICENSE NO. C11-03437-2-042490

LOT(s) BLOCK SUBDIVISION ZONE

PROPOSED CONSTRUCTION REMODEL USE

PLUMBING PERMIT NO.

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
1	For Issuing Each Permit	10 00	10.00
	For Issuing Each Supplemental Permit	4 50	
FIXTURE CHARGE			
4	Bathub, Shower, Lavatory, Toilet, Urinal	EA 2 00	8.00
7	Floor Drain, Floor Sink, Wash Tray, Sink	EA 2 00	14.00
	Garbage Disposal, Clothes Washer, Dishwasher (residential)	EA 2 00	
	Garbage Disposal (commercial)	EA 8 00	
	Clothes Washer, Dishwasher (commercial)	EA 2 00	
	Clothes Dryer (gas) (venting)	2 00	
	Dental Unit	8 00	
	Drinking Fountain	2 00	
	Refrigerator - Ice Maker, Water Dispenser	2 00	
	Any other water using equipment, Attached Coffee Makers, Ice Makers	2 00	
	Hot Water Heater (Gas or Electric)	EA 2 00	
SEWER SYSTEM			
1	New, Replacement, Modification, or Any Drainage Work	10 00	10.00
	Grease or Sand Trap or Interceptor	2 00	
	Trailer Trap (rental parks)	5 00	
WATER SOFTENERS			
	Non Permanent Type (rental)	2 00	
	Permanent Type (connected to drain)	2 00	
WATER DISTRIBUTION SYSTEM			
	Single Family Dwelling	6 00	
	Multi-Family Dwelling	6 00	
	Plus Each Dwelling Unit	3 00	
1	Commercial Building per floor	3 00	3.00
1	Plus Each Unit (leased space or office)	2 00	2.00
	Hotel or Motel	8 00	
	Plus Each Unit	3 00	
	Trailer Park	30 00	
	Plus Each Space	2 00	
	Irrigation Single Family Dwelling	8 00	
	Irrigation Commercial Fee Based on Building Code Valuation Chart		
	Construction Valuation		

UNITS	DESCRIPTION	FEE	TOTAL
FUEL PIPING SYSTEM			
	Single Family Dwelling	6 00	
	Multi-Family Dwelling	10 00	
	Plus Each Unit	2 00	
	Commercial Building (per floor)	6 00	
	Plus Each Unit (leased space or office)	6 00	
	Medium Pressure System (Plan Check)	12 00	
	Each Gas Appliance (Any Type)	2 00	
	Steam Boilers	5 00	
SOLAR ENERGY SYSTEMS			
	Collectors (including piping) (per collector)	5 00	
	Storage Tanks (each)	5 00	
PIPELINE CONTRACT			
	For Onsite Sewer, Gas or Water Contract Value Fee based on Building Code Permit Valuation Chart		
OTHER INSPECTIONS AND FEES:			
	Inspections outside of normal business hours (minimum charge—three hours)	25 00 per hour	
	Under provisions of Table 3-A of the Uniform Building Code, work which has been inspected once and not approved may be subject to a Reinspection Fee not less than \$30 00 per each inspection during business hours	30 00 each	
	Additional plan review required by changes Additions to or revisions to approved plans (minimum charge two hours)	30 00 per hour	
	Plumbing permit fees may be computed the same as building permit fees by using the cost of installation for valuation amount when such work is not included in the above schedule		
	Construction Valuation		

FOR INSPECTIONS
CALL 799-2071SEWER # 7114-3654
CONNECTION

FIXTURES X 02/22/91

FEE

2310-2403

PERMIT
FEETOTAL
FEES 47.00

RECEIPT

***0006**
 PLEB 47.00
 CHEK 47.00
 9526A000 11:26

I hereby certify that I have carefully examined and read the above application, that the same is true and correct; and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not

SIGNED [Signature] 29305
 CONTRACTOR MASTER CARD NO.

BY Registered Master Plumber Spec Contr or Owner

BUILDING DEPT

DATE

PERMIT NO.

CITY OF LAS VEGAS, NEVADA

PERMIT NO. 91-095506

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251DEVELOPMENT PERMIT
FOR: Commercial and Public StructuresLOG NO. & AREA m-306DATE 1-15-91CONST. VAL. \$ 600,000ADDRESS OF CONSTRUCTION 888 S. RANCHO DRIVESta 104

OWNER

SIERRA HEALTH SERVICES

PHONE

595-2464
458-6579CONTRACTOR DUNRITE CONSTRUCTION

STATE LICENSE NO.

0018138

CITY LICENSE NO.

035164

A POR OF THE S 1/2 OF SEC. 32 T20S R61E

LOT(s) _____ BLOCK _____ SUBDIVISION _____

ZONE: C-1PROPOSED CONSTRUCTION INTERIOR REMODEL

USE _____

ADD'L. PERMITS REQ'D.

Air Cond. ☐Elec. ☒Plumbing ☒Signs ☐Paving ☐Fence ☐Fire S.S. ☒Off-Site P. ☐OCCUPANCY GROUP B-2

CONSTRUCTION TYPE

V-N SPRINKLERED

MATERIALS OF CONSTRUCTION:

Wood Frame ☒Concrete Block ☐Reinforced Concrete ☐Steel Frame ☐

SQUARE FEET OF FLOOR AREAS:

1st 17602nd —3rd —Other —TOTAL SQ. FT. 1760

ARCHITECT _____

ENGINEER _____

NO. of UNITS _____

NO of STORIES _____

OTHER INSPECTIONS AND FEES

- 1 Inspections outside of normal business hours = \$30.00 per hour (minimum charge three hours)
- 2 Re-inspection fee during normal business hours assessed under provisions of TABLE 3-A of the Uniform Building Code = \$30.00 each
- 3 Inspections during normal business hours for which no fee is specifically indicated = \$30.00 per hour (minimum charge one half hour)
- 4 Additional plan review required by changes, additions or revisions to approved plans = \$30.00 per hour (minimum charge two hours)

FOR INSPECTIONS, CALL 799-2071

CONDITIONS OF THE PERMIT:

- 1 I agree to call the City Building Department for inspections before concrete is poured, before rough wiring, electrical, plumbing, framing is covered. Also for air conditioning, drywall and sheathing inspection
- 2 I agree that when the job is completed that I will call for final inspection before occupancy
- 3 I agree to perform all construction in accordance with City Ordinances and Building Codes
- 4 The Contractor's signature below denotes authority from the owner to sign in his behalf and that the owner is aware of all requirements of this application and permit. Separate permits must be taken out for work outlined above this agreement.
- 5 I have read and understand the contents of this application and permit, I hereby state that the information I have supplied on this application is true and correct

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way

SPECIAL CONDITIONS

INTERIOR
RE-MODEL
ONLY

SEE - PLANS

SIGNED

CONTRACTOR

BY

AGENT/OWNER

LICENSE DEPT

DATE

PLANNING DEPT

DATE

I hereby certify that I have reviewed this application and the proposed plans and have found that the proposed development meets the requirements of the City of Las Vegas Flood Hazard Reduction Ordinance for the issuance of this Development Permit.

LAND DEVELOPMENT AND FLOOD CONTROL ENGINEER

DATE

FIRE DEPARTMENT

DATE

BUILDING DEPT

DATE

SEWER CONNECTION
7114-3654FIXTURES: 4 X 156.00

01/28/91

FEE

PLAN
REVIEW
FEE2310-2401
PERMIT
FEETOTAL
FEES

RECEIPT

0002

SEWR 624.00

COMM 368.00

CHK 992.00

8053A000 08:33

PERMIT NO. _____

MUST BE MACHINE VALIDATED

Permit Expires 180 Days After Abandonment of Work

CITY OF LAS VEGAS, NEVADA

DEPARTMENT OF BUILDING AND SAFETY
PHONE 386-6251

F



26886

PERMIT NO. 1 - 098191

AIR CONDITIONING PERMIT

LOG NO. & AREA

DATE

2/21/91

CONST. VAL. \$

ADDRESS OF
CONSTRUCTION

888 S. Rancho

OWNER

Southwest Medical Inc.,

PHONE

CONTRACTOR Sahara Air Conditioning

STATE

LICENSE NO. 017859

CITY

LICENSE NO. C11012472019928

LOT(S) BLOCK SUBDIVISION ZONE

PROPOSED CONSTRUCTION Reroute ductwork and install two three ton USE

straight cool units

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
1	For the issuance of each permit.	15 00	15.00
	For issuing each supplemental permit	4 50	
UNIT FEE SCHEDULE			
	For the installation or relocation of each forced-air or gravity-type furnace or burner, including ducts and vents attached to such appliance, up to and including 100,000 Btu/h	9 00	
	For the installation or relocation of each forced-air or gravity-type furnace or burner, including ducts and vents attached to such appliance over 100,000 Btu/h	11.00	
	For the installation or relocation of each floor furnace, including vent.	9 00	
	For the installation or relocation of each suspended heater, recessed wall heater or floor-mounted unit heater	9.00	
	For the installation, relocation or replacement of each appliance vent installed and not included in an appliance permit	4 50	
2	For the repair of, alteration of, or addition to each heating appliance, refrigeration unit, cooling unit, absorption unit, or each heating, cooling absorption, or evaporative cooling system, including installation of controls regulated by this code	9 00	18.00
2	For the installation or relocation of each boiler or compressor to and including three tons, or each absorption system to and including 100,000 Btu/h	9 00	18.00
	For the installation or relocation of each boiler or compressor over three tons to and including 15 tons, or each absorption system over 100,000 Btu/h and including 500,000 Btu/h.	16 50	
	For the installation or relocation of each boiler or compressor over 15 tons to and including 30 tons, or each absorption system over 500,000 Btu/h to and including 1,000,000 Btu/h	22 50	
	For the installation or relocation of each boiler or compressor over 30 tons to and including 50 tons, or for each absorption system over 1,000,000 Btu/h to and including 1,750,000 Btu/h	33 50	
	For the installation or relocation of each boiler or refrigeration compressor over 50 tons, or each absorption system over 1,750,000 Btu/h	56 00	

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way

UNITS	DESCRIPTION	FEE	TOTAL
	For each air-handling unit to and including 10,000 cubic feet per minute, including ducts attached thereto Note: This fee shall not apply to an air-handling unit which is a portion of a factory-assembled appliance, cooling unit, evaporative cooler or absorption unit for which a permit is required elsewhere in this code	6 50	
	For each air-handling unit over 10,000 cfm	11 00	
	For each evaporative cooler other than portable type	6.50	
1	For each ventilation fan COMMERCIAL RESIDENTIAL	4 50 2 35	4.50
	For each ventilation system which is not a portion of any heating or air-conditioning system authorized by a permit	6 50	
	For the installation of each hood which is served by mechanical exhaust, including the ducts for such hood	6 50	
	For each fire damper installed in an existing system	4 50	

OTHER INSPECTIONS AND FEES:

Inspections outside of normal business hours (minimum charge — three hours)	25 00 per hour
Reinspection fee assessed under provisions of TABLE 3-A of the Uniform Building Code = \$15 00 EACH	15 00 each
Inspections for which no fee is specifically indicated (minimum charge — one-half hour)	30 00 per hour
Additional plan review required by changes, additions or revisions to approved plans (minimum charge — two hours)	30 00 per hour
Mechanical permit fees may be computed the same as building permit fees by using the cost of installation for valuation amount when such work is not included in the above schedule	
Gas piping which is directly related and necessary to the repair or replacement of heating, air conditioning, or refrigeration systems not exceeding 500,000 BTU H	6.00

2310-2435

RECEIPT

0002

A/C 55.50

CHECK 55.50

02/21/91

9485A910 14:21

I hereby certify that I have carefully examined and read the above application; that the same is true and correct, and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not.

SIGNED

CONTRACTOR

MASTER CARD NO

BY

Spec Cont'r or Owner

BUILDING DEPT

DATE

PERMIT
FEETOTAL
FEES

55.50

MUST BE MACHINE VALIDATED

Permit Expires 180 Days After Abandonment of Work

"fire alarm"
"after hours" (9:30 a.m.)
595-2464

FOR INSPECTIONS CALL: 229-2071 FOR FURTHER INFORMATION CALL: 383-2888

CITY OF LAS VEGAS
DIVISION OF FIRE SERVICES

[illegible]

8:35
Vince

FOR INSPECTIONS CALL: 229-2071 FOR FURTHER INFORMATION CALL: 383-2888

**CITY OF LAS VEGAS
DIVISION OF FIRE SERVICES**

JOB ADDRESS 888 S. Rancho			PERMIT NO. 2840
LOT NO.	MAP NO.	INSPECTOR	DATE 11-13-90
PROJECT NAME Rancho Medical Center			PHONE 382-1251
INSPECTOR'S SIGNATURE			INSPECTION DATE

4am on Thursday Saturday Brit

Did inspection of new X Ray area and found 1 horn not installed in X ray room and a db reading of 70-72 in small office to the north.

Both pull stations operated correctly

7540 Westcliff

☐ PARTIAL APPROVAL
☐ TEMPORARY APPROVAL

☒ REJECTED-REINSPECTION
REQUIRED

☐ FINAL APPROVAL
☐ STOP ORDER

☐ X-1 UNDER/ABOVEGROUND TANK
☐ X-2 HOOD SYSTEM
☐ X-3 UNDERGROUND FINAL/FLOW
☐ X-4 SPRINKLER SYSTEM/OVERHEAD HYDRO

☐ X-5 FIRE ALARM SYSTEM
☐ X-6 OTHER
☐ X-7 FINAL FIRE

☐ X-8 EXTINGUISHING SYSTEM
☐ X-9 MEDICAL GAS
☐ X-10 LPG
☐ X-11 SUPERVISION/MONITORING

• FOR INSPECTIONS CALL: 799-2071 FOR FURTHER INFORMATION CALL: 383-2888

**CITY OF LAS VEGAS
DIVISION OF FIRE SERVICES**

Approved by
4:00 a.m. Phone Chief Judd

JOB ADDRESS 888 S. Rancho			PERMIT NO.
LOT NO.	MAP NO.	INSPECTOR	DATE
PROJECT NAME Southwest Medical			PHONE
INSPECTOR'S SIGNATURE Joe Legando			INSPECTION DATE 3/28/91

- * ① Emergency lights - don't work
- * ② Provide route # in door
- * ③ Provide fire extinguishers
- * ④ Provide escape route when necessary and lower
hose when necessary
- ⑤ Fire alarm system - o.k.

☐ PARTIAL APPROVAL
☐ TEMPORARY APPROVAL

☒ REJECTED-REINSPECTION
REQUIRED

☐ FINAL APPROVAL
☐ STOP ORDER

☐ X-1 UNDER/ABOVEGROUND TANK
☐ X-2 HOOD SYSTEM
☐ X-3 UNDERGROUND FINAL/FLOW
☐ X-4 SPRINKLER SYSTEM/OVERHEAD HYDRO

☐ X-5 FIRE ALARM SYSTEM
☐ X-6 OTHER
☒ X-7 FINAL FIRE

☐ X-8 EXTINGUISHING SYSTEM
☐ X-9 MEDICAL GAS
☐ X-10 LPG
☐ X-11 SUPERVISION/MONITORING

FOR INSPECTIONS CALL: 799-2071

FOR FURTHER INFORMATION CALL: 383-2888

**CITY OF LAS VEGAS
DIVISION OF FIRE SERVICES**

[illegible]

**CITY OF LAS VEGAS
DIVISION OF FIRE SERVICES**

JOB ADDRESS 888 S. Rancho dr.		PERMIT NO. 95506
LOT NO. #104	MAP NO. 4 11:17a	INSPECTOR TANNER
PROJECT NAME fire - TENANT Remodel		DATE 4/25/91
INSPECTOR'S SIGNATURE		PHONE 458-6579
		INSPECTION DATE 4-26-91
Checked EMERGENCY LITES (2 each) IN TENANT Remodel of Room 104		
WAITING AREA ROOM NEXT TO MAMMOGRAPHY 2 ROOM		
SPARE OFFICE AND WAITTING ROOM		
EMERG. LITES ARE NOT WORKING UNABLE TO LOCATE THE ELECTRICIAN WILL RECALL NEXT WEEK		
☐ PARTIAL APPROVAL ☐ REJECTED-REINSPECTION REQUIRED ☐ FINAL APPROVAL		
☐ TEMPORARY APPROVAL ☐ STOP ORDER		
☐ X-1 UNDER/ABOVEGROUND TANK	☐ X-5 FIRE ALARM SYSTEM	☐ X-8 EXTINGUISHING SYSTEM
☐ X-2 HOOD SYSTEM	☐ X-6 OTHER	☐ X-9 MEDICAL GAS
☐ X-3 UNDERGROUND FINAL/FLOW	☐ X-7 FINAL FIRE	☐ X-10 LPG
☐ X-4 SPRINKLER SYSTEM/OVERHEAD HYDRO		☐ X-11 SUPERVISION/MONITORING
FOR INSPECTIONS CALL: 799-2071 FOR FURTHER INFORMATION CALL: 383-2888		

DIVISION OF FIRE SERVICES

JOB ADDRESS 888 S. Rancho - Radiology			PERMIT NO
LOT NO	MAP NO	INSPECTOR	DATE 11/23/90
PROJECT NAME Southwest Medical			PHONE
INSPECTOR'S SIGNATURE Joe Lopez			INSPECTION DATE 11/23/90 - 4:00 a.m.
Fire Alarm Test			
Did inspection of fire alarm installation			
Found SD de + throughout			
Strokes worked			
Pull stations worked			
Final Approval this date			
☐ PARTIAL APPROVAL ☐ TEMPORARY APPROVAL ☐ REJECTED-REINSPECTION REQUIRED ☒ FINAL APPROVAL ☐ STOP ORDER			
☐ X-1 UNDER/ABOVEGROUND TANK ☐ X-2 HOOD SYSTEM ☐ X-3 UNDERGROUND FINAL/FLOW ☐ X-4 SPRINKLER SYSTEM/OVERHEAD HYDRO ☐ X-5 FIRE ALARM SYSTEM ☐ X-6 OTHER ☐ X-7 FINAL FIRE ☐ X-8 EXTINGUISHING SYSTEM ☐ X-9 MEDICAL GAS ☐ X-10 LPG ☐ X-11 SUPERVISION/MONITORING			
FOR INSPECTIONS CALL: 799-2071 FOR FURTHER INFORMATION CALL: 383-2888			

(JP)

FOR FURTHER INFORMATION CALL: 383-2888

**CITY OF LAS VEGAS
DIVISION OF FIRE SERVICES**

2:15

JOB ADDRESS 888 S-Rancho			PERMIT NO. 2841
LOT NO.	MAP NO.	INSPECTOR	DATE 11-14-90
PROJECT NAME Southwest Medical (new xray area)			PHONE 384-1251
INSPECTOR'S SIGNATURE Joe Lopez			INSPECTION DATE 11/15/90

Brit

Did inspection of 2 Xray rooms for lowering of sprinkler heads where necessary.

Escutcheons still need to be installed on all heads.

7 day temporary C of O given based on the

① Fire alarm test to be done 11/17/90 at 4:00 a.m.

② escutcheon put on all sprinkler heads by time of alarm test.

☐ PARTIAL APPROVAL	☐ REJECTED-REINSPECTION REQUIRED	☐ FINAL APPROVAL
☒ TEMPORARY APPROVAL		☐ STOP ORDER
☐ X-1 UNDER/ABOVEGROUND TANK	☐ X-5 FIRE ALARM SYSTEM	☐ X-8 EXTINGUISHING SYSTEM
☐ X-2 HOOD SYSTEM	☐ X-6 OTHER	☐ X-9 MEDICAL GAS
☐ X-3 UNDERGROUND FINAL/FLOW	☐ X-7 FINAL FIRE	☐ X-10 LPG
☒ X-4 SPRINKLER SYSTEM/OVERHEAD HYDRO		☐ X-11 SUPERVISION/MONITORING

FOR INSPECTIONS CALL: 799-2071 FOR FURTHER INFORMATION CALL: 383-2888

did not leave #

8:45

8:45

**CITY OF LAS VEGAS
DIVISION OF FIRE SERVICES**

JOB ADDRESS 888 Rancho			PERMIT NO.
LOT NO.	MAP NO.	INSPECTOR	DATE
PROJECT NAME Southwest Medical			PHONE
INSPECTOR'S SIGNATURE [Signature]			INSPECTION DATE 3/29/91
① Emergency Lighting - o.k. ② Fire extinguishers provided - just need mounting. ③ Provide suite #'s on door. ④ Fire alarm - o.k. ⑤ Sprinkler system - approved Changes still to be made connecting 2 suites together. Final approval will be given at time of completion.			
☐ PARTIAL APPROVAL ☒ TEMPORARY APPROVAL 30 day ☐ REJECTED-REINSPECTION REQUIRED ☐ X-1 UNDER/ABOVEGROUND TANK ☐ X-2 HOOD SYSTEM ☐ X-3 UNDERGROUND FINAL/FLOW ☐ X-4 SPRINKLER SYSTEM/OVERHEAD HYDRO ☐ FINAL APPROVAL ☐ STOP ORDER ☐ X-5 FIRE ALARM SYSTEM ☐ X-6 OTHER ☐ X-7 FINAL FIRE ☐ X-8 EXTINGUISHING SYSTEM ☐ X-9 MEDICAL GAS ☐ X-10 LPG ☐ X-11 SUPERVISION/MONITORING			
FOR INSPECTIONS CALL: 799-2071 FOR FURTHER INFORMATION CALL: 383-2888			

**CITY OF LAS VEGAS
DIVISION OF FIRE SERVICES**

JOB ADDRESS <u>888 S. Rancho</u>		PERMIT NO. <u>3840-3841</u>
LOT NO.	MAP NO.	DATE <u>11-8-90</u>
PROJECT NAME <u>HPN</u>		PHONE <u>384-1251</u>
INSPECTOR'S SIGNATURE <u>[Signature]</u>		INSPECTION DATE <u>11/8/90</u>
<u>Ham - 11-13-90 inspection</u> <u>Briff</u> <u>fire alarm & sprinkler</u> <u>Sprinkler system - X ray rooms (2)</u> <u>roads blocked by railing for X-ray equipment</u> <u>Fire Alarm system - failed -</u> <u>no activation on pull of pull station</u> <u><u>No</u> approval given for <u>30 day</u></u> <u><u>temp.</u></u>		
☐ PARTIAL APPROVAL ☐ TEMPORARY APPROVAL ☒ REJECTED-REINSPECTION REQUIRED ☐ FINAL APPROVAL ☐ STOP ORDER		
☐ X-1 UNDER/ABOVEGROUND TANK ☐ X-2 HOOD SYSTEM ☐ X-3 UNDERGROUND FINAL FLOW ☒ X-4 SPRINKLER SYSTEM/OVERHEAD HYDRO ☐ X-5 FIRE ALARM SYSTEM ☐ X-6 OTHER ☐ X-7 FINAL FIRE ☐ X-8 EXTINGUISHING SYSTEM ☐ X-9 MEDICAL GAS ☐ X-10 LPG ☐ X-11 SUPERVISION/MONITORING		
FOR INSPECTIONS CALL: 799-2071 FOR FURTHER INFORMATION CALL: 383-2888		

Certificate of Occupancy

City of Las Vegas, Nevada
Department of Building & Safety

This Certificate issued pursuant to the requirements of the Uniform Building Code certifying that at the time of issuance this structure was in compliance with the various ordinances of the City regulating building construction or use. For the following:

Building Permit No. 92-131686

Building Address 888 S. RANCHO Suite No. _____

Type of Construction TENANT IMPROV Occupancy Classification B-2 Area: _____ S.F.

Building Owner's Name: SOUTHWEST MEDICAL

Owner's Address: _____

Tenant's Name: SAME

Description of Use: CAT SCAN ROOM/OFFICE

Prepared By: D. INGRAM Date: 2/11/92

By: Paul K. Williams

John E. Tucker
Building Official

POST IN CONSPICUOUS PLACE

Certificate of Occupancy

City of Las Vegas, Nevada
Department of Building & Safety

This Certificate issued pursuant to the requirements of the Uniform Building Code certifying that at the time of issuance this structure was in compliance with the various ordinances of the City regulating building construction or use. For the following:

Building Permit No. 90-076622

Building Address 888 S. RANCHO DR. Suite No. _____

Type of Construction INTERIOR REMODEL Occupancy Classification B-2 Area: _____ S.F.

Building Owner's Name: SIERRA MEDICAL ASSOC.

Owner's Address: _____

Tenant's Name: SAME

Description of Use: MEDICAL OFFICES

Prepared By: D. INGRAM Date: 11/29/90

By: Michael Traasclah

John E. Tucker
Building Official

POST IN CONSPICUOUS PLACE



DEPARTMENT OF BUILDING & SAFETY
CITY OF LAS VEGAS, NEVADA

FOR INSPECTION CALL 799-2071

Approved Plans Must Be On Job Site During Construction

STREET NO. 888 S Natchez Dr.
L-159
MAP NO. _____
DESCR. OF WORK INTERIOR REMODEL
CONTRACTOR Dunrite Const.
OWNER _____
DATE ISSUED: 7-27-90

Building Permit No. _____
Electric Permit No. 080312
Plumbing Permit No. _____
Air Cond. Permit No. _____
Sewer Connection No. _____

INSPECT	DESCRIPTION	APPROVED	DATE
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING		
☐ B-2	STEM WALL—FORMS & REBAR		
☐ B-3	PRE-SLAB		
☐ P-4	UNDERSLAB PLUMBING	<u>P. 01 CLV</u>	<u>9/11/90</u>
☐ E-1	UNDERGROUND ELECTRICAL		

Pour No Concrete Until Above is App roved

☐ B-4	ROOF SHEATHING		
☐ B-5	FRAMING	<u>BLDG. INSP. 55 CLV</u>	<u>10-8-90</u>
☐ B-6	INSULATION		
☐ P-5	TOP OUT-WATER, GAS, WASTE		
☐ M-1	ROUGH VENT		
☐ E-2	ROUGH ELECTRICAL		
☐ E-3	LOW VOLTAGE ELECTRICAL		

Do Not Sheetrock Until Above is Approved

☐ B-7	DRYWALL NAILING	<u>BLDG. INSP. 68 CLV</u>	<u>10-8-90</u>
☐ B-8	EXTERIOR LATH/STUCCO		
☐ B-9	WALL GROUT & STEEL		
☐ B-12	BUILDING FINAL	<u>BLDG. INSP. 68 CLV</u>	<u>11-16-90</u>
☐ P-6	FINAL GAS TEST		
☐ P-7	FINAL PLUMBING	<u>P. 01 CLV</u>	<u>11/6/90</u>
☐ M-2	HOOD		
☐ M-3	FINAL MECHANICAL	<u>CLV</u>	<u>11/5/90</u>
☐ E-5	FINAL ELECTRICAL	<u>ELEC. INSP. 75 CLV</u>	<u>11-7-90</u>

INSPECT	DESCRIPTION	APPROVED	DATE
☐ P-1	ON SITE SEWER		
☐ P-2	ON SITE WATER		
☐ P-3	BUILDING SEWER (YARD LINES)		
☐ E-4	SIGN INSPECTION		
☐ E-6	TEMP POWER		
☐ B-10	POOL PRE-GUNITE		
☐ B-11	POOL PRE-PLASTER/FINAL		
☐ X-1	KICKER/FLUSH		
☐ X-2	UNDERGROUND HYDRO		
☐ X-3	UNDERGROUND FINAL/FLOW		
☐ X-4	SPRINKLER SYSTEM HYDRO		
☐ X-5	FIRE ALARM		
☐ X-6	OTHER		
☐ X-7	FINAL FIRE		
☐ X-8	HYDRANT		
☐ B-13	CERT. OF OCC.	<u>BLDG. INSP. 68 CLV</u>	<u>11-16-90</u>

Occupancy Approval

Planning Dept. 7-23-90
Quality Cont. N/A
Fire Dept. 10 day Temporary 11/15/90
Bldg. Dept. BLDG. INSP. 68 CLV 11-16-90
BLDG. INSP. 68 CLV Grid Clg 11-16-90

POST THIS CARD
ON FRONT OF BUILDING

BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF
TO BLDG. & SAFETY FOR CERTIFICATE OF OCCUPANCY ISSUANCE (Commercial Only)

FOR TECHNICAL ASSISTANCE CALL: 799-6916



DEPARTMENT OF BUILDING & SAFETY
CITY OF LAS VEGAS, NEVADA

FOR INSPECTION CALL 229-2071

92-131686

Approved Plans Must Be on Job Site During Construction

STREET NO. 888 S. Rancho
MAP NO. M-9383
DESCR. OF WORK T.I.
CONTRACTOR Summit Const.
OWNER _____
DATE ISSUED: 1/2/92

Building Permit No. 92-131686
Electric Permit No. 92-132339
Plumbing Permit No. 92-13-1688
Air Cond. Permit No. 92-13226
Sewer Connection No. _____

INSPECT	DESCRIPTION	APPROVED	DATE
☐ 101	FOOTING, LAYOUT, REBAR, ZONING		
☐ 103	STEM WALL—FORMS—REBAR		
☐ 105	PRE-SLAB		
☐ 111	SIGN FOUNDATION/MOUNTING		
☐ 201	UNDERGROUND ELECTRICAL		
☐ 407	UNDERSLAB PLUMBING		

Pour No Concrete Until Above is Approved

☐ 107	ROOF SHEATHING		
☐ 109	SHEAR		
☐ 120	FRAMING		
☐ 123	INSULATION		
☒ 220	ROUGH ELECTRICAL		
☒ 223	LOW VOLTAGE ELECTRICAL		
☐ 303	ROUGH VENT		
☐ 420	TOP OUT—WATER, GAS, WASTE		

Do Not Sheetrock Until Above is Approved

☐ 125	DRY WALL NAILING		
☐ 127	CEILING GRID		
☐ 129	EXTERIOR LATH/STUCCO		
☐ 131	WALL GROUT & STEEL		
☐ 140	BUILDING FINAL		
☐ 150	OTHER		
☐ 225	SIGN INSPECTION		
☐ 227	CONSTRUCTION POWER		
☐ 229	TEMP POWER		
☐ 231	SERVICE CHANGE		
☐ 235	EMERGENCY ELECTRICAL TEST		
☒ 240	FINAL ELECTRICAL		
☐ 250	OTHER		
☐ 305	HOOD		
☐ 340	FINAL MECHANICAL		
☐ 350	OTHER		
☐ 401	ON SITE SEWER		
☐ 403	ON SITE WATER		

INSPECT	DESCRIPTION	APPROVED	DATE
☐ 405	BUILDING SEWER (YARD LINES)		
☐ 423	FINAL GAS TEST		
☐ 440	FINAL PLUMBING		
☐ 443	KICKER/FLUSH		
☐ 445	UNDERGROUND HYDRO		
☐ 450	OTHER		
☐ 501	UNDER/ABOVE GROUND TANK		
☐ 503	HOOD SYSTEM		
☐ 505	UNDERGROUND FINAL FLOW		
☒ 507	SPRINKLER SYSTEM HYDRO		
☐ 509	FIRE ALARM		
☐ 513	EXTINGUISHING SYSTEM		
☐ 515	MEDICAL GAS		
☐ 517	LIQUID PETROLEUM GAS		
☐ 519	SUPERVISION/MONITORING		
☒ 540	FINAL FIRE		
☐ 550	OTHER		
☐ 640	PLANNING COMPLETE		
☐ 901	POOL PRE-GUNITE		
☐ 910	POOL PRE-PLASTER/FINAL		
☐ 913	TRAILER		
☐ 915	INVESTIGATION		
☒ 940	CERT. OF OCCUPANCY		

Occupancy Approval
Planning Dept. 2nd PL A. Repp 1/29/92
Quality Cont. N/A
Fire Dept. Grand meat 2-7-92
Bldg. Dept. 8th PL BLDG INSP 68 CLV 1-28-92

BRING HARD CARD WITH FIRE QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR CERTIFICATE OF OCCUPANCY ISSUANCE (Commercial Only)

FOR TECHNICAL ASSISTANCE CALL: 229-6916

POST THIS CARD ON FRONT OF BUILDING

DAN CASHDAN


STRUCTURAL ENGINEER

PROJECT SOUTHWEST MEDICAL SIGN
ACTION SIGNS

MADE BY G.N.M. DATE _____ JOB NO. 87-304

CHKD BY _____ DATE _____ SHEET NO. A1 OF 1

ALTERNATE FOUNDATION:



REF: ORIGINAL CALC'S OF 12-18-87

$$P = 882 \#$$

$$h = 5'$$

$$S_1 = (150)(2)(1/3)(4/3) = 533.33$$


$$\text{USE } b = 2'-0" \phi$$

$$A = \frac{(2.34)(882)}{(2)(533)} = 1.93$$

$$d = \frac{1.93}{2} \left(1 + \sqrt{1 + \frac{(4.36)(5)}{1.93}} \right) = 4.35'$$

USE FOOTING 2'-0" ϕ x 4'-4" DEEP

Rw
M5476



11-5-90


DAN CASHDAN

STRUCTURAL ENGINEER

PROJECT SOUTHWEST MEDICAL SIGNACTION SIGNSMADE BY DCDATE 12-18-87JOB NO. 87-304

CHKD BY _____

DATE _____

SHEET NO. 1OF 1

$$p_w = 15 \times 7 \times 1.4 = 14.7 \text{ PSF}$$

$$A \times p_w = P \times Y' = M^{\text{IF}}$$

$$60 \times 14.7 = 882 \times 5 = 4410$$

$$f_b = \frac{4410 \times 12}{6.78} = 7805 \text{ psi}$$

$$F_y = 45000 \times .6 = 27000 \text{ psi}$$

$$U_{22} : \text{ST } 5 \times 5 \times 1/4 \text{ OK}$$

FOOTING :

$$P = 882 \#$$

$$h = 5'$$

$$S_1 = 150 \times 2 \times 4/3 \times d/3 = 133.3d$$

$$\text{TRY} - b = 1.0$$


$$d = 6.0$$

$$S_1 = 800$$

$$A = \frac{2.34 \times 882}{800} = 2.158$$

$$d = \frac{2.158}{2} \left(1 + \sqrt{1 + \frac{4.36 \times 5}{2.158}} \right) = 5.26'$$

$$U_{22} : \text{FOOTING } 1'-0" \phi \times 5'-6" \text{ PREP}$$




DAN CASHDAN

STRUCTURAL ENGINEER

PROJECT SOUTHWEST MEDICAL SIGNACTION SIGNSMADE BY DCDATE 12-18-87JOB NO. 87-304

CHKD BY _____

DATE _____

SHEET NO. 1OF 1

$$p_w = 15 \times 7 \times 1.4 = 14.7 \text{ PSF}$$

$$A \times p_w = P \times \bar{y}' = M$$

$$60 \times 14.7 = 882 \times 5 = 4410$$

$$f_b = \frac{4410 \times 12}{6.78} = 7805 \text{ psi}$$

$$F_y = 45000 \times .6 = 27000 \text{ psi}$$

$$U_{ss} : \text{ST } 5 \times 5 \times \frac{1}{4} \text{ OK}$$

FOOTING :

$$P = 882 \text{ #}$$

$$h = 5'$$

$$S_1 = 150 \times 2 \times \frac{4}{3} \times \frac{d}{3} = 133.3d$$

$$\text{TRY} - b = 1.0$$


$$d = 6.0$$

$$S_1 = 800$$


$$A = \frac{2.34 \times 882}{800} = 2.58$$

$$d = \frac{2.58}{2} \left(1 + \sqrt{1 + \frac{4.36 \times 5}{2.58}} \right) = 5.26'$$

$$U_{ss} : \text{FOOTING } 1'-0" \phi \times 5'-6" \text{ DEEP}$$




APPROVED
CONSTRUCTION
Safety Dept.
Nevada



- INSTALLATION OF
- D/F NON-ILLUM. MONUMENT
 - ARCH. BRZ. B/S - TEKOTE
 - REFLECTIVE SCOTCH-CAL VDC LZS.

APPROVED
 REPLACE EXIST. SIGN
 10-0-90 BY CPE 10/30/90
 COMMUNITY PLANNING & DEVELOPMENT
 City of Las Vegas



Action Signs
 1500 S. WESTERN AVENUE
 LAS VEGAS, NEVADA 89102
 PHONE: (702) 382-1871
 FAX: (702) 598-0545