

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

<input type="checkbox"/> PERMIT NUMBER	91109297	<input type="checkbox"/> INSPECTION NUMBER	
--	----------	--	--

JOB ADDRESS: 3708 N. Rancho

LOT NO.-	BLOCK NO.	SUBDIVISION NAME
----------	-----------	------------------

FIRE DEPT MAP NO	JOB PHONE	CALL-IN DATE	CALL-IN TIME	SCHEDULE DATE
	3636596	6-19-91	10 11:10A.	

INSPECTOR NO.	INSPECTOR NAME
61	

INSPECTION REQUESTED: Rebar & footer

SECOND CALL

- ① Block steel away from forms ~~at least 3" clearance required.~~ 3" clearance required.
- ② Widen footing at columns to provide 6" minimum coverage per plans, including 6" from form.
- ③ Anchor bolts to hook beneath horizontal steel
- ④ Complete anchor bolt setting
- ⑤ Footing along east side must be 17" wide.

<input type="checkbox"/> PARTIAL INSPECTION	<input type="checkbox"/> PARTIAL APPROVAL (P)	PARTIAL DESCRIPTION
---	---	---------------------

<input type="checkbox"/> APPROVED (A)	<input type="checkbox"/> STOP WORK (S)	<input type="checkbox"/> COMMENTS (C)	<input type="checkbox"/> TEMPORARY APPROVAL (T) -- UNTIL	<input type="checkbox"/> HOLD (H)
---------------------------------------	--	---------------------------------------	--	-----------------------------------

<input checked="" type="checkbox"/> REJECTED (R)	REINSPECTION REQUIRED - CALL *799-2071	<input type="checkbox"/> PERMIT REQUIRED
<input type="checkbox"/> REFEE (F)	REINSPECTION FEE REQUIRED - PAY AT CITY HALL 3RD FLOOR - 400 E. STEWART STREET.	

INSPECTOR SIGNATURE: <i>Jeff Case</i>	INSPECTION DATE: 6-20-91
---------------------------------------	--------------------------

<input type="checkbox"/> PROJECT COMPLETE	BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. OF O ISSUANCE (Commercial Only)
---	--

IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7 00 A.M - 7 15 A.M OR 2.45 P.M. - 3:00 P.M AT