

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

☒	PERMIT NUMBER	92-168535	INSPECTION NUMBER	29
JOB ADDRESS				
5729 PEEBLE ROCK DR			106824	
LOT NO.		BLOCK NO.	SUBDIVISION NAME	
14		4	DESERT CREEK PH. II UNIT 1	
FIRE DEPT. MAP NO.	JOB PHONE	CALL-IN DATE	CALL-IN TIME	SCHEDULE DATE
1617-87	658-5042	01/25/93	14:37	01/26/93
INSPECTOR NO.		INSPECTOR NAME		
63/64		RICH CARSON / HARRIS		
INSPECTION REQUESTED		SHEAR (109)		
INSTALL ALL A-B'S @ 32" O.C. WHERE CALLED FOR. INSTALL PAND 42 BY OPTIONAL FIREPLACE INSTALL HD5A @ GARAGE ROOF SHEAR WALL. NAIL OFF SOUTH GARAGE SHEAR WALL TOWARD WEST END.				
☐ PARTIAL INSPECTION		☐ PARTIAL APPROVAL (P)		PARTIAL DESCRIPTION
☒ APPROVED (A)		☐ STOP WORK (S)		
☐ REJECTED (R)		☐ COMMENTS (C)		☐ TEMPORARY APPROVAL (T) - UNTIL
☐ REFEE (F)		☐ HOLD (H)		☐ PERMIT REQUIRED
INSPECTOR SIGNATURE		INSPECTION DATE		
		1/26/93		
☐ PROJECT COMPLETE		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)		
IF YOU HAVE ANY QUESTIONS ON THIS INSPECTION, YOU MAY CALL THE INSPECTOR FROM 7:00 A.M. - 7:15 A.M. OR 2:45 P.M. - 3:00 P.M. AT				229-6769

For Additional Assistance Call * 229-6251. See Reverse Side For Inspection Types.