

BROADWAY LAS VEGAS

D. Gatewood 1:30-79

J. L. HENGSTLER  
DONALD P. SCHULTZ  
HUGH C. WEBER

J. L. HENGSTLER ASSOCIATES, INC.  
CONSULTING ENGINEERS  
1621 BEVERLY BOULEVARD  
LOS ANGELES, CALIFORNIA 90026  
626-0684

DAVID R. PORTILLO  
ROBERT J. LUJAN

May 25, 1977.

City of Las Vegas  
City Hall  
400 East Stewart  
Las Vegas, Nevada 89101

Attention: Mr. Jim Whitehead  
Mechanical Inspector

Subject: Broadway - Las Vegas

Gentlemen:

This is to confirm our telephone conversation regarding duct insulation for the subject store. Since we are using the space between the ceiling and floor above as a return air plenum the supply ducts which run in this plenum are considered to be "within the condition space" and no duct insulation is required.

If this is not your interpretation, please let us know in writing at your earliest convenience.

Very truly yours,

J. L. HENGSTLER ASSOCIATES, INC.

*Hugh C. Weber*

Hugh C. Weber  
Vice President

HCW;ip

