

A. 3321 Beach Port
B. *3325 Beach Port
C. *3329 Beach Port

D. *3333 Beach Port

-2-

*Perimeter wall/see
9305 Dry Dock

Reenie Benbow

3/12/90

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 3233 Boech Fort		PERMIT NO. 020895	
LOT NO.	MAP NO.	INSPECTOR SO	DATE 4-12-89
SUBDIVISION NAME		PHONE	
INSPECTOR SIGNATURE 		INSPECTION DATE 4-12-89	
SQUARE UP BACK SIDE OF FOOTING & REMOVE EXCESS FILL FROM SAME PRIOR TO PLACING CONCRETE			
☐ PARTIAL INSPECTION - DESCRIPTION:			
☒ APPROVED			
☐ PERMIT REQUIRED			
☐ STOP WORK			
☐ REJECTED - CORRECTION NOTICE, REINSPECTION REQUIRED CALL 799-2071			
INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☒ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)
☐ B-4	ROOF SNEATHING	☐ P-4	UNDERSLAB PLUMBING
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING
☐ B-8	EXTERIOR CATH/STUCCO	☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ E-2	ROUGH ELECTRICAL
☐ B-10	FOOT PRE-GUNITE	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	FOOT PRE-PLASTER / FINAL	☐ E-4	SM INSPECTION
☐ B-12	BUILDING FINAL	☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT. OF OCC.	☐ E-6	TEMP POWER
☐ FINAL INSPECTION		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C of O ISSUANCE (Commercial Only)	

FOR TECHNICAL ASSISTANCE - CALL: 799-6916

3/12/90


JOB ADDRESS 3333 Birch Rd	PERMIT NO. 020895				
LOT NO.	MAP NO.	INSPECTOR 60	DATE		
SUBDIVISION NAME	PHONE				
INSPECTOR SIGNATURE [Signature]	INSPECTION DATE 4-13-89				
Peterson Fish Bono Broom					
☐ PARTIAL INSPECTION - DESCRIPTION					
☒ APPROVED ☐ PERMIT REQUIRED ☐ STOP WORK					
☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071					
INSPCT	DESCRIPTION	INSPCT	DESCRIPTION	INSPCT	DESCRIPTION
☒ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL -- FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER:
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/SUCCO			☐ E-1	UNDERGROUND ELECTRICAL
☒ B-9	WALL GROUT (STEEL)	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT. OF OCC.	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER
☐ FINAL INSPECTION		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C.O.C. ISSUANCE (Commercial Only)			

FOR TECHNICAL ASSISTANCE - CALL: 799-6916

Reenie Benbow

3/12/90

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 3333 Benbow Post		PERMIT NO. 020895
LOT NO.	MAP NO.	INSPECTOR 60
SUBDIVISION NAME		PHONE
INSPECTOR SIGNATURE 		INSPECTION DATE 4-20-89
VISUAL INSPECTION OF FINAL RETAINING WALL AS WALL HAS BEEN CAPPED PRIOR TO SEEING GROUT IN CELLS / STEEL WAS OK		
☐ PARTIAL INSPECTION - DESCRIPTION: ON 4-13-89		
☒ APPROVED ☐ PERMIT REQUIRED ☐ STOP WORK		
☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071		
INSPECT	DESCRIPTION	INSPECT
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1 ON SITE SEWER
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2 ON SITE WATER
☐ B-3	PRE-SLAB	☐ P-3 BUILDING SEWER (YARD LINES)
☐ B-4	ROOF SHEATHING	☐ P-4 UNDERSLAB PLUMBING
☐ B-5	FRAMING	☐ P-5 TOP OUT-WATER, GAS, WASTE
☐ B-6	INSULATION	☐ P-6 FINAL GAS TEST
☐ B-7	DRYWALL NAILING	☐ P-7 FINAL PLUMBING
☐ B-8	EXTERIOR LATH/STUCCO	☐ M-1 ROUGH VENT
☐ B-9	WALL GROUT & STEEL	☐ M-2 HOOD
☐ B-10	POOL PRE-GUNITE	☐ M-3 FINAL MECHANICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ X-1 KICKER / FLUSH
☐ B-12	BUILDING FINAL	☐ X-2 UNDERGROUND HYDRO
☐ B-13	CERT. OF OCC.	☐ X-3 UNDERGROUND FINAL FLOW
☒ FINAL INSPECTION		☐ X-4 SPRINKLER SYSTEM HYDRO
		☐ X-5 FIRE ALARM
		☐ X-6 OTHER:
		☐ X-7 FINAL FIRE
		☐ E-1 UNDERGROUND ELECTRICAL
		☐ E-2 ROUGH ELECTRICAL
		☐ E-3 LOW VOLTAGE ELECTRICAL
		☐ E-4 SIGN INSPECTION
		☐ E-5 FINAL ELECTRICAL
		☐ E-6 TEMP POWER

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS
SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

FOR TECHNICAL ASSISTANCE, - CALL: 799-6916

3/12/90

[illegible]

FOR TECHNICAL ASSISTANCE - CALL: 799-6916

3/12/90

JOB ADDRESS 3333 BEACH PORT		PERMIT NO. 0704163	
LOT NO.	MAP NO.	INSPECTOR 6:0	DATE
SUBDIVISION NAME			PHONE
INSPECTOR SIGNATURE 			INSPECTION DATE 4-25-84
<i>Visual Final</i>			
☐ PARTIAL INSPECTION - DESCRIPTION:			
☒ APPROVED ☐ PERMIT REQUIRED ☐ STOP WORK			
☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071			
INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)
☒ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING
☒ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST
☐ B-7	DRY WALL NAILING	☐ P-7	FINAL PLUMBING
☐ B-8	EXTERIOR LATI/STUCCO		
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL
☐ B-12	BUILDING FINAL		
☐ B-13	CERT. OF OCC.	☐ X-1	KICKER / FLUSH
		☐ X-2	UNDERGROUND HYDRO
		☐ X-3	UNDERGROUND FINAL/FLOW
		☐ X-4	SPRINKLER SYSTEM HYDRO
		☐ X-5	FIRE ALARM
		☐ X-6	OTHER:
		☐ X-7	FINAL FIRE
		☐ E-1	UNDERGROUND ELECTRICAL
		☐ E-2	ROUGH ELECTRICAL
		☐ E-3	LOW VOLTAGE ELECTRICAL
		☐ E-4	SIGN INSPECTION
		☐ E-5	FINAL ELECTRICAL
		☐ E-6	TEMP POWER
☐ FINAL INSPECTION		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)	

FOR TECHNICAL ASSISTANCE - CALL: 799-6916