

1245 BLANKENSHIP

SEE APPLICATION

Watewood June 27, 1980

STOP WORK ORDER

Placed on job at: 1245 Blankenship

Contractor / Owner: _____

DATE 3-15-79 TIME 8:00 AM

REASON: UNSAFE ELECTRICAL

Wiring Leading to and At Well

Inspector: J. Garfield

Removal date: 6-23-80 Time: _____

Removal authorized by: R. H. H. H.

10.00 FEE Applicable (yes) (no) Paid (yes) (no)

Remarks: _____

REPLACE WIRING AND
SOLENOID VALVE AND
CALL FOR INSPECTION
YOU MUST HAVE PERM
CALL BUILDING DEPT
IF YOU HAVE ANY
QUESTIONS
DO NOT REENERGIZE