

807 Bridger

Debbi Ingraham 9-6-85

BUILDING DEPARTMENT  
CITY OF LAS VEGAS  
*801 Bridger*  
**CORRECTION NOTICE**

*House Meter*  
Job Located at *801 Bridger*

I have this day inspected this structure and these premises and have found the following violations of City and/or State laws governing same:

① *Water heater shall have old Disconnect removed & replaced with approved Disconnect for water heaters. Shall have licensed contractor permit, in which comply by 8-25-85*

You are hereby notified to correct above violation and call for re-inspection.

Date *8-13-85* *Dee Bontuan*  
Inspector

23.03 Do not remove this tag!