

540 So. Decatur

Debbie Ingraham 10-29-85

BUILDING DEPARTMENT
CITY OF LAS VEGAS

CORRECTION NOTICE

10-11-85 Complete

Job Located at 5405 Decatur

I have this day inspected this structure and these premises and have found the following violations of City and/or State laws governing same:

(1) No exhaust fan in bathroom (No windows)

(2) Oven not vented as per Sec 916 (d) (This is the oven installed outside hood)

(Must comply within 10 working days) 09-08-85

You are hereby notified to correct above violation and call for re-inspection.

Date 09-26 Immaculate Inspector

23.03 Do not remove this tag!