

2436 E. FREMONT

G. Gatewood 11-6-79

**BUILDING DEPARTMENT
CITY OF LAS VEGAS
CORRECTION NOTICE**

File
Job Located at PIZZA HUT
2436 E. FREMONT

I have this day inspected this structure and these premises and have found the following violations of City and/or State laws governing same:

GAS CO. SHUT DOWN EQUIP.
REPAIR AND MAKE
CHANGES AS PER
CHAPTER 20 UNIFORM
MECH CODE:

1. NO MAKE-UP AIR
2. IF YOU USE HOOD TO
VENT PRODUCE OF EXHAUST
YOU MUST HAVE THREE
LOCKING SWITCHES (EXHAUST
FAN TO BURNER)
3. CHECK FAN EXHAUST
FILTER AND CLEAN VENT STACK.

MUST COMPLY BY 11/3/79

You are hereby notified to correct above violation and call for re-inspection.

Date 10/25/79

James B. Hunt
Inspector

23.03

Do not remove this tag!

1-14-80
BUILDING DEPARTMENT
CITY OF LAS VEGAS
CORRECTION NOTICE

11/12/79
GIVE EXTENT 11/12/79
Job Located at PIZZA HUT
2446 E. FREMONT

I have this day inspected this structure and these premises and have found the following violations of City and/or State laws governing same:

REPAIR AND MAKE
CHANGES AS PER
CHAPTER 20 UNIFORM
MECH CODE:

1. NO MAKE-UP AIR
2. IF YOU USE HOOD TO
VENT PRODUCTS OF COMBUSTION
YOU MUST HAVE INTER-
LOCKING SWITCH (EXHAUST
FAN TO BURNER)
3. CHECK FAN EXHAUST
MOTOR AND CLEAN VENT STACK.
MUST COMPLY BY 11/3/79

You are hereby notified to correct
above violation and call for re-inspection.

Date 10/25/79 Joseph B. Hunt
Inspector

23.03 Do not remove this tag!

GAS CO. SHUT-DOWN EQUIP.