

1912 ALEXANDER

RD.

OWNER <u>Wilcolm</u>		ADDRESS <u>1912 Alexander Holmes</u>	
DATE <u>2/1/82</u>		GEN. CONT. <u>Richardson Const</u>	
TYPE OF STRUCTURE <u>Fire Damage Repair</u>		PERMIT NO. <u>7606</u>	
LEGAL DESCRIPTION <u>L-8 B-1 Sunset Manor</u>		FINAL INSPECTION	
LOG #		AREA #	
APPROVED FOR OCCUPANCY & METER			
BUILDING		MECHANICAL	
Investigation		Plumbing Cont.	
Location & Footing		Permit No. Date	
Concrete Slab Floor		Heat & Vent. A/C Cont.	
Fireplace Footing		Permit No. Date	
Chimney Steel		Sewer Cont.	
Vert. Steel Reinf.		Permit No. Date	
Horiz. Steel Reinf.		Rough Soil	
Framing <u>CM 2-5-82</u>		Rough Water	
Ext. Lath		Top-Out	
Ext. Brown		Rough Gas	
Drywall <u>EC 2-9-82</u>		A/C Rough Duct	
Final Building <u>CM 3-15-82</u>		Final Plumber	
Appr. for Occu.		Final Gas	
ELECTRICAL		Final Air Cond.	
Temp. Pels Cdn.		Final Sewer	
Permit No. Date		REMARKS	
Inspection Date			
Electrical Cont. <u>H.S.C.</u>			
Permit No. <u>7645</u> Date <u>2-1-82</u>			
Rough		PLEASE NOTE ADDITIONAL REMARKS ON REVERSE SIDE.	
Final Rough		DIV. OF BLDG. & SAFETY	
Final Electrical <u>205-3-5-82</u>		CITY OF LAS VEGAS	
Temporary Service		REV. 10-79	
		79-3-16	

7604
broader on 2/10/82

Dona Hualy

9-28-82

BUILDING DEPARTMENT
CITY OF LAS VEGAS

CORRECTION NOTICE

45C - Fire Repair

Job Located at

1912 Alexander
Holmes

I have this day inspected this structure
and these premises and have found the following
violations of City and/or State laws governing
same:

All plugs in kitchen
replaced with ground-
type plug. Plugs in
kitchen and bathroom
to be grounded with #12
bare wire to ground
clamp located under
bathroom or kitchen sink on
water pipe. Kitchen must
now be on separate circuit.

By 2-12-82

You are hereby notified to correct
above violation and call for re-inspection.

Date

2-5-82

D. Semenza
Inspector

23.03 Do not remove this tag!