

121 S. CASINO CENTER

Angela Jackson

DEPT. OF BLDG. & SAFETY - CITY OF LAS VEGAS, NEVADA		
OWNER: <u>MIRABELLI (VALET CLEANERS)</u>	ADDRESS: <u>121 North 2nd St.</u>	DATE: <u>10/12/59</u>
GEN. CONT. <u>P & C CONSTR. CO.</u>	TYPE OF STRUCTURE <u>LINE ONE ROOM WITH</u>	
PERMIT NO. <u>34664</u>	LEGAL DESCRIPTION: <u>5/8 SHEETROCK & RELOCATE COUNTER</u>	
LOCATION & FLOOR ELEVATION _____	PLUMBING CONT. _____	TEMP. POLE CONT. _____
FOOTINGS _____	PERMIT NO. _____ DATE _____	PERMIT NO. _____ DATE _____
FOUND. & PIERS _____	HEAT. & VENT. CONT. _____	INSPECTION _____ DATE _____
WALL STEEL _____	PERMIT NO. _____ DATE _____	ELECTRICAL CONT. _____
BOND BEAM STEEL _____	SEWER CONT. _____	PERMIT NO. _____ DATE _____
FRAMING & ROOF SHEATHING _____	ROUGH SOIL _____	OUTLETS _____
STEEL FABRICATION _____	ROUGH WATER _____	MOTORS _____ H.P. _____
CONNECTIONS & PAINTING _____	SEWER OR SEPTIC TANK _____	SLAB _____
LATHING _____	TOP-OUT _____	ROUGH _____
PLASTER _____	ROUGH GAS _____	FINAL ROUGH _____
SCATCH _____	ROUGH DUCT _____	FIXTURE, CONT. _____
BROWN _____	FINAL PLUMBING _____	PERMIT NO. _____ DATE _____
FINAL BLDG. <u>ELL</u> <u>7-14-59</u>	FINAL HEATING _____	FIXTURES _____
GRADING & DRAINAGE _____	FINAL GAS _____	FINAL FIXTURE _____
ON-SITE PARKING _____ SPACES _____		APPROVED FOR METER _____
ENG. APPROVAL OF _____		
OFF-SITE IMPROVEMENTS _____		

APPROVED for OCCUPANCY: _____

INSPECTOR _____

DATE _____

* PLEASE NOTE REMARKS ON REVERSE SIDE

121 North 2nd St. 5/8 SHEETROCK ONE RM., & RELOCATE COUNTER 10/12/59

23.0

Permit Rymaker 3-9-81

DEPARTMENT OF BUILDING & SAFETY
CITY OF LAS VEGAS, NEVADA

KARDEX CARD
SIGN

OWNER Elizehlin McLaughlin
Federal Signs ADDRESS 121 Casino Center DATE 7/13/67
CONTRACTOR Federal Signs PERMIT NO. 38139
LOT _____ BLOCK _____ SUBDIVISION _____

LOCATION _____	ELECT. ROUGH _____
SHOP (WIRING, CONST.) _____	ELECT. FINAL _____
SITE (BLDG., ETC.) _____	
INST. (SERV: STRUCT.) _____	
BILLBOARD _____	
ELECTRIFIED _____	
FINAL <u>Dean Burlingame</u>	

23.07 D ADDRESS 121 Casino Center LOG NO. _____ AREA _____

Department of Building & Safety
City of Las Vegas, Nevada

Special Kاردex
Elec. only, Plbg. only, A.C. only

Owner Otto Westlake Address 121 S. Casino Center Date: 1-9-68
Contractor _____ Permit No. _____
Lot _____ Block _____ Subdivision _____

Electric Only	Plumbing Only	Heat & Vent. A. C. Only
Contractor <u>Denton Ellis</u>	Contractor _____	Contractor <u>Nicosia A.C.</u>
Permit No. <u>29350</u>	Permit No. _____	Permit No. <u>28420</u>
Slab _____	Rough Soil _____	A.C. Rough Duct _____
Rough Elect. _____	Rough Water _____	Ref. Ro. Piping _____
Final Rough _____	Top Out _____	Rough Gas _____
Final Fixture _____	Rough Gas _____	Final Refrig _____
Final Elec. <u>U 1-19-70</u>	Final Plbg. _____	Final Air Cond <u>W/B 2/10</u>
Temp. Service _____	Final Gas _____	Final Gas _____
	Final Sewer _____	
	Final Septic Tank _____	

23.06 D Address _____ Log No. _____ Area _____
121 S. Casino Center h.p. ch

These Kymatos 3-9-81

DEPT. of BLDG & SAFETY - CITY of LAS VEGAS, NEVADA		
OWNER <u>OTTO WESTLAKE</u>	ADDRESS <u>121 South Second St</u>	DATE <u>Aug. 23/66</u>
GEN CONT. <u>Roberts Roof & Floor, Inc.</u>	TYPE OF STRUCTURE <u>reroof</u>	
PERMIT NO. <u>31836</u>	LEGAL DESCRIPTION <u>Lots 17-18 Block II, Clarke I.V. Townsite</u>	
BUILDING	MECHANICAL	ELECTRICAL
LOCATION _____	PLUMBING CONT. _____	TEMP POLE CONT. _____
FIREPLACE FTS. _____	PERMIT NO. _____ DATE _____	PERMIT NO. _____ DATE _____
FOOTINGS _____	HEAT & VENT. AC CONT. _____	INSPECTION _____ DATE _____
FOUNDATION WALL _____	PERMIT NO. _____ DATE _____	ELECTRICAL CONT. _____
FLOOR FRAMING _____	SEWER CONT. _____	PERMIT NO. _____ DATE _____
SLAB _____	PERMIT NO. _____ DATE _____	FIXTURES CONT. _____
CHIMNEY STEEL (FIREPLACE) _____	ROUGH SOIL _____	PERMIT NO. _____ DATE _____
WALL STEEL _____	ROUGH WATER _____	SLAB _____
COLUMN STEEL _____	TOP-OUT _____	ROUGH _____
BEAM STEEL _____	ROUGH GAS _____	FINAL ROUGH _____
FRAMING _____	AC ROUGH DUCT _____	FINAL FIXTURE _____
ROOF SHEATHING _____	REF. ROUGH PIPING _____	FINAL ELECTRICAL _____
INTERIOR _____	FINAL PLUMBING _____	TEMPORARY SERVICE _____
EXTERIOR _____	FINAL GAS _____	MISCELLANEOUS
DRYWALL _____	FINAL AIR COND. _____	GRADING & DRAINAGE _____
LATHING _____	FINAL REFRIG. _____	ON-SITE PARKING SPACES _____ APP. _____
BACKING (SIDING) _____	FINAL SEWER _____	ENG APPROVAL DT _____
PLASTER SCRATCH _____	FINAL SEPTIC TANK _____	OFF-SITE IMPROVEMENTS _____
PLASTER BROWN _____		
URBAN REDEVELOPMENT APPROVAL _____		
FINAL BLDG <u>9-24-66</u>		

APPROVED FOR OCCUPANCY & METER _____ INSPECTOR _____ DATE _____

PLEASE NOTE REMARKS ON REVERSE SIDE 121 South Second St. LOG # _____ AREA # _____ 23.04

7/10/81
CLV-6218

MAYOR BILL BRIARE

COMMISSIONERS
RON LURIE
PAUL J. CHRISTENSEN
ROY WOOFER
AL LEVY

CITY ATTORNEY
GEORGE F. OGILVIE

CITY MANAGER
RUSSELL DORN



CITY of LAS VEGAS

September 14, 1981

CERTIFIED MAIL
RETURN RECEIPT
REQUESTED

Jul

Tigar Bar
121 Casino Center Boulevard South
Las Vegas, Nevada 89101

The following violations were observed on a walk-through inspection of your establishment on September 8, 1981. We consider these violations to be of a serious nature and a threat to life and safety. The Electrical Inspector left a correction notice allowing thirty (30) days for completion; however, due to the serious nature of these violations, we are requiring you to have a licensed electrical contractor obtain a permit and commence work within five (5) days of receipt of this letter.

1. Remove zip cord on rear light. Zip cord not permitted in commercial buildings.
2. Remove all Romex wiring from main service. Romex wiring is not permitted by City Electrical Code.
3. Deadfront is missing on main service. Violation of National Electrical Code.
4. Replace or remove all Romex in the building.
5. Connectors on conduit in back of building loose, missing or disconnected. Repair or replace.
6. Main service grounding electrode conductor required to be replaced. National Electrical Code does not permit splices and also City Code requires #4 solid bare copper.

Continued . . .



7/10/81
Tigar Bar
121 Casino Center Boulevard South
September 14, 1981
Page Two

7. Remove all of the numerous zip cords throughout the building that were observed.
8. Replace switch box covers where missing.
9. Ice machine requires proper heavy duty cord and receptacles or wire direct in conduit.
10. Exposed wiring in dressing room must be corrected.
11. Close up openings in "J" boxes per National Electrical Code.
12. Correct wiring to lights in storage room. Wiring to be in conduit.
13. Light fixtures in liquor display must be removed. Not permitted by National Electrical Code Article 410-3.
14. Stage lighting and overhead spotlights must be wired in conduit and wired per National Electrical Code Article 520.

Should you have any questions concerning the above, please call Robert Wagner, Supervisor of Electrical Inspections, at 386-6251.

DEPARTMENT OF BUILDING & SAFETY

Clay Hymer
CLAY HYMER, DIRECTOR

CH/RW/Lm

cc: Don J. Saylor, Deputy City Manager
Robert Wagner, Supervisor of
Electrical Inspections

CITY OF LAS VEGAS, NEVADA

DEPARTMENT OF BUILDING AND SAFETY-ELECTRICAL APPLICATION & PERMIT

PHONE NO. _____

ADDRESS OF CONSTRUCTION: 121 Casino Center

OWNER'S NAME: Tiger Bar

CIRCLE: Addition; Remodel; New Bldg. TYPE OF BLDG.: SFD APT. COMM. PUBLIC

CONTRACTOR'S NAME: Edison Electric STATE LICENSE # 017841 CITY LICENSE # C-11-20101

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
	For Issuing Each Permit	10.00	14.50
	Supplemental Fee	4.50	
APPLIANCE CHARGE			
	Receptacle _____ Switch _____	.40	
	Each Light Fixture or Socket	.30	
	EACH OUTLET FOR: Dishwasher, Garbage Grinder, Trash Compactor, G.F.L., Clothes Washer, Dryer, Electric Range, Ovens, Smoke Detector, Special Purpose Water Heater, Space Heater, Blast Coil Heater (PER K W.), Mercury Lamp, Quartz Lamp, Sodium Lamp	.70	
	X-Ray Unit	10.00	
	Area Lighting (First 3,000 Watts)	8.00	
	Each Additional 1,000 Watts	3.00	
	Motors (½ H.P. And Over) Transformers Welders, Generators		
	First H.P. For each Unit	3.00	
	First KVA For Each Unit	.50	
	Each Additional H.P. or KVA	.30	
	Temporary Power or Pole	6.00	
	Electric Service (Incl'd First Meter)	6.00	
	Up to 200 AMP		
	400 AMP And 600 AMP	12.50	
	Over 600 AMP To 1200 AMP	25.00	
	Over 1200 AMP	50.00	
	Each Additional Meter Socket	.50	

UNITS	DESCRIPTION	FEE	TOTAL
	Sub Panel (Each)	3.00	
	Swimming Pool (Residential)	20.00	
	Swimming Pool (Semi-Public)	30.00	
	Spas	8.00	
	Recreational Vehicle Spaces (Each)	3.00	
	Busways-Trolley or Plug-in (Ea. 100 Ft.)	3.00	
	All Misc. Electric		
	Permanent A/C Unit (Pkg. Units)	3.00	
	Each Air Handler	1.00	
LOW VOLTAGE INSTALLATIONS			
	Speaker Outlets (Each)	.30	
	Signal or Alarm Outlets (Each)	.30	
	Amplifiers	2.00	
	Control Panel	.50	
	TV Master System	.30	
	Telephone or Computer Outlet	.30	
	Starter Permit		
	Contract Price or Cost of Installation		
	Misc.		
	STARTER PERMIT	15.00	
	BLDG \$ 15.00		
	ELEC \$ 10.00		
	STL \$ 10.00		
	TOTL \$ 10.00		
	CHEK \$ 10.00		
	TOTAL PERMIT FEE \$		

Electrical permit fees may be computed the same as building permit fees by using the cost of installation for valuation amount when such work is not included in the above schedule.

FOR BUILDING DEPARTMENT USE ONLY

Plans submitted: ☐ yes ☐ no

Occupancy type: _____

Type of Construction _____

Received by PAC: _____

Date: _____

Valuation (declared) \$ _____

Review by Plans Check: _____

Date: _____

Fee-calculated \$ _____

Issued by _____

Date: _____

Other Fees (228) \$ _____

Check ☐ Cash ☐

Total Fees \$ _____

CITY - LAS VEGAS

Square Footage

BLDG & SAFETY

BLDG \$ 15.00

ELEC \$ 15.00

STL \$ 15.00

TOTL \$ 15.00

CHEK \$ 15.00

Other inspections and fees:

1. Inspections outside of normal business hours=\$15.00 per hour (minimum charge two hours).
2. Re-inspection fee assessed under provisions of TABLE 3-A of the Uniform Building Code=\$15.00 per hour.
3. Inspections for which no fee is specifically indicated=\$15.00 per hour (minimum charge one half hour).
4. Additional plan review required by changes, additions or revisions to approved plans=\$15.00 per hour (minimum charge one half hour).

Approval for the work under this permit will be given only if all fees and debris have been removed from the site and public right of way.

I hereby certify that I have carefully examined and read the above application; that the same is true and correct; and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not. City Master Card No. _____

SIGNED

Julius Galas
Master (Electrician) (Technician) (Owner)

Date 9/21/81

BUILDING DIVISION

Date 9/21/81

PERMIT NO. 422

PERMIT FEE \$ 25.00

#1721-2402

BLDG & SAFETY

BLDG \$ 15.00

ELEC \$ 15.00

STL \$ 15.00

TOTL \$ 15.00

CHEK \$ 15.00

RECEIPT

9/21/81

Lila Collins - 10-28-81

ELEC. ONLY. PLBG. ONLY. A.C. ONLY		
OWNER <i>Tiger Bar</i>		DATE <i>9-7-81</i>
ADDRESS <i>121 Casino Center</i>		
CONTRACTOR <i>Edison Elect.</i>	PERMIT NO. <i>4298</i>	FINAL INSPECTION
LOT	BLOCK	SUBDIVISION
LOG NO.		AREA
ELECTRIC ONLY		PLUMBING ONLY
Contractor <i>Edison Elect.</i>		Contractor
Permit No. <i>4298</i>		Permit No.
Rough Elec.		Rough Soil
Final Rough		Rough Water
Final Elec. <i>29-10-12-81</i>		Top Out
Temp. Service		Rough Gas
HEAT & VENT. A/C ONLY		Final Plbg.
Contractor		Final Gas
Permit No.		Sewer Final
A/C Rough Duct		<i>Start for permit</i>
Rough Gas		
Final A/C		
Final Gas		

79-3-18 DIV. OF BLDG. & SAFETY
CITY OF LAS VEGAS
REV. 10-78