

So
501 Casino Center

Therese Lynette 3-9-81

DEPT. of BLDG & SAFETY - CITY of LAS VEGAS, NEVADA		DATE 12/16/69
OWNER Jan Ross	ADDRESS 501 South 2d St	TYPE OF STRUCTURE Demolish Duplex
GEN. CONT. Tom Mayberry	PERMIT NO. 50354	LEGAL DESCRIPTION
BUILDING		MECHANICAL
ELECTRICAL		MISCELLANEOUS
LOCATION	PLUMBING CONT.	TEMP. POLE CONT.
FIREPLACE FTS	PERMIT NO. DATE	PERMIT NO. DATE
FOOTINGS	HEAT & VENT. AC CONT.	INSPECTION DATE
FOUNDATION WALL	PERMIT NO. DATE	ELECTRICAL CONT.
FLOOR FRAMING	SEWER CONT.	PERMIT NO. DATE
SLAB	PERMIT NO. DATE	FIXTURES CONT.
CHIMNEY STEEL (FIREPLACE)	ROUGH SOIL	PERMIT NO. DATE
WALL STEEL	ROUGH WATER	SLAB
COLUMN STEEL	TOP-OUT	ROUGH
BEAM STEEL	ROUGH GAS	FINAL ROUGH
FRAMING	AC ROUGH DUCT	FINAL FIXTURE
ROOF SHEATHING	REF. ROUGH PIPING	FINAL ELECTRICAL
INTERIOR	FINAL PLUMBING	TEMPORARY SERVICE
EXTERIOR	FINAL GAS	
DRYWALL	FINAL AIR COND.	
LATHING	FINAL REFRIG.	
BACKING (BROWN)	FINAL SEWER	
PLASTER SCRATCH	FINAL SEPTIC TANK	
PLASTER BROWN		
URBAN REDEVELOPMENT APPROVAL		
FINAL BLDG	DATE 12/16/69	

APPROVED FOR OCCUPANCY & METER INSPECTOR DATE

PLEASE NOTE REMARKS ON REVERSE SIDE LOG # AREA # 23.04

501 So. 2d

Department of Building & Safety
City of Las Vegas, Nevada

Special Kardon
Elec. only, Plbg. only, A.C. only

Owner Jerome Snyder Address 501 S. Casino Center Blvd. Date: 6/27/68

Contractor Permit No.

Lot Block Subdivision

Electric Only	Plumbing Only	Heat & Vent. A. C. Only
Contractor Simpson & Bozarth	Contractor	Contractor
Permit No. 25784	Permit No.	Permit No.
Slab	Rough Soil	A.C. Rough Duct
Rough Elect	Rough Water	Ref. Ro. Piping
Final Rough	Top Out	Rough Gas
Final Fixture	Rough Gas	Final Refrig
Final Elec	Final Plbg.	Final Air Cond
Temp. Service	Final Gas	Final Gas
	Final Sewer	
	Final Septic Tank	

23.06 D

Address 501 S. Casino Center

Log No.

Area

These Ryan 3-9-81

DEPT. of BLDG. & SAFETY - CITY of LAS VEGAS, NEVADA		
OWNER: <u>ANTHONY BARRON</u>	ADDRESS: <u>501 South 2nd St.</u>	DATE: <u>1/27/58</u>
GEN. CONT. <u>PAUL WAGNER CONSTR.</u>	TYPE OF STRUCTURE <u>REMODEL GARAGE</u>	
PERMIT NO. <u>30255</u>	LEGAL DESCRIPTION: <u>Lot 1, Bl. 23, Clark's L.V.T.</u>	
LOCATION & FLOOR ELEVATION	PLUMBING CONT. <u>United</u>	TEMP. POLE CONT.
FOOTINGS	PERMIT NO. <u>27994</u> DATE <u>1-28-58</u>	PERMIT NO. _____ DATE _____
FOUND. & PIERS	HEAT. & VENT. CONT.	INSPECTION _____ DATE _____
WALL STEEL	PERMIT NO. _____ DATE _____	ELECTRICAL CONT. <u>West Service</u>
BOND BEAM STEEL	SEWER CONT.	PERMIT NO. <u>21844</u> DATE <u>1/28/58</u>
FRAMING & ROOF SHEATHING	PERMIT NO. _____ DATE _____	OUTLETS <u>7 in</u>
STEEL FABRICATION	ROUGH SOIL <u>Bailey 1-29-58</u>	MOTORS _____ H.P. _____
CONNECTIONS & PAINTING	ROUGH WATER <u>Bailey 1-29-58</u>	SLAB _____
LATHING	SEWER OR SEPTIC TANK	ROUGH _____
PLASTER	TOR-OUT	FINAL ROUGH <u>go 1/28/58</u>
SCRATCH	ROUGH GAS	FIXTURE CONT.
BROWN	ROUGH DUCT	PERMIT NO. _____ DATE _____
FINAL BLDG. <u>NE Handed 2-20-58</u>	FINAL PLUMBING <u>Bailey 1-29-58</u>	FIXTURES _____
GRADING & DRAINAGE	FINAL HEATING	FINAL FIXTURE _____
ON-SITE PARKING _____ SPACES _____	FINAL GAS	APPROVED FOR METER <u>go 2/24/58</u>
ENG. APPROVAL OF OFF-SITE IMPROVEMENTS		

over APPROVED for OCCUPANCY: _____ INSPECTOR _____ DATE _____
* PLEASE NOTE REMARKS ON REVERSE SIDE
501 South 2nd St. - REMODEL GARAGE 1/27/58 23.04

DEPT. of BLDG. & SAFETY - CITY of LAS VEGAS, NEVADA		
OWNER: <u>A. C. BARRON</u>	ADDRESS: <u>501 S. 2nd</u>	DATE: <u>8/4/58</u>
GEN. CONT. <u>OWNER</u>	TYPE OF STRUCTURE <u>WIRE FENCE - 12' long</u>	
PERMIT NO. <u>31565</u>	LEGAL DESCRIPTION: <u>Lot 1, 2, Blk. 23, C.L.V.T.</u>	
LOCATION & FLOOR ELEVATION	PLUMBING CONT.	TEMP. POLE CONT.
FOOTINGS	PERMIT NO. _____ DATE _____	PERMIT NO. _____ DATE _____
FOUND. & PIERS	HEAT. & VENT. CONT.	INSPECTION _____ DATE _____
WALL STEEL	PERMIT NO. _____ DATE _____	ELECTRICAL CONT.
BOND BEAM STEEL	SEWER CONT.	PERMIT NO. _____ DATE _____
FRAMING & ROOF SHEATHING	PERMIT NO. _____ DATE _____	OUTLETS _____
STEEL FABRICATION	ROUGH SOIL _____	MOTORS _____ H.P. _____
CONNECTIONS & PAINTING	ROUGH WATER _____	SLAB _____
LATHING	SEWER OR SEPTIC TANK	ROUGH _____
PLASTER	TOR-OUT	FINAL ROUGH _____
SCRATCH	ROUGH GAS	FIXTURE CONT.
BROWN	ROUGH DUCT	PERMIT NO. _____ DATE _____
FINAL BLDG. <u>2nd & Rev.</u>	FINAL PLUMBING	FIXTURES _____
GRADING & DRAINAGE	FINAL HEATING	FINAL FIXTURE _____
ON-SITE PARKING _____ SPACES _____	FINAL GAS	APPROVED FOR METER _____
ENG. APPROVAL OF OFF-SITE IMPROVEMENTS		

APPROVED for OCCUPANCY: _____ INSPECTOR _____ DATE _____
* PLEASE NOTE REMARKS ON REVERSE SIDE
501 SOUTH SECOND ST. - WIRELINK FENCE 12' LONG - 8/4/58 23.04

Therese Rynakko 3-9-81

2-4-59 - Stop Tag Removed

PD 10⁰¹ Rest # 30308-

H. Hatfield

PD # 30255

Done Housley

11-29-83

**BUILDING DEPARTMENT
CITY OF LAS VEGAS**

CORRECTION NOTICE

THIS NOTICE FOLLOWS A
VERBAL NOTICE 11-4-83.

Job Located at 501 Casino Ctr. N.

I have this day inspected this structure
and these premises and have found the following
violations of City and/or State laws governing
same:

Exterior wall insulation
must intersect roof or
ceiling insulation in
order to provide a
building "envelope."

You are hereby notified to correct
above violation and call for re-inspection.

Date 11-7-83

R
Inspector

23.03

Do not remove this tag!

Manuel Francisco 6-27-84

BUILDING AND FIRE
INSPECTION COMPLETION FORM

1. Address of Inspection
Central Fire Station
500 N. Casino Center Blvd.
 2. Inspection Date 6/15/84
 3. Reinspection Date _____
 4. Inspection Time 10:00 A.M. and
11:00 A.M.
 5. Inspection Type Hood extinguishing
system (wet) Hose test
 6. Person Contacted Neil Savage
 7. Building Inspector: A ☐ D ☐ W ☐
 8. Fire Inspector: A ☐ D ☐ W ☒
 - FIRE INSP. SIGNATURE Ree Swing
 - BLDG. INSP. SIGNATURE _____
- A - Approved D - Disapproved W - Witnessed