

1130 Casino Center

Therese Rypnack 3-9-81

DEPT. of BLDG & SAFETY—CITY of LAS VEGAS, NEVADA

OWNER Vince Gagley ADDRESS 1130 South Casino Center DATE 1/17/68

GEN. CONT. Lloyd Construction TYPE OF STRUCTURE Sheetrock ceiling

PERMIT NO. 39891 LEGAL DESCRIPTION Lot 21 Block 7, Boulder Add.

BUILDING	MECHANICAL	ELECTRICAL
LOCATION	PLUMBING CONT.	TEMP. POLE CONT.
PREPLACE FTE.	PERMIT NO. DATE	PERMIT NO. DATE
FOOTINGS	HEAT'S VENT. A/C CONT.	INSPECTION DATE
FOUNDATION WALL	PERMIT NO. DATE	ELECTRICAL CONT.
FLOOR FRAMING	SEWER CONT.	PERMIT NO. DATE
SLAB	PERMIT NO. DATE	FIXTURES CONT.
CHIMNEY STEEL (FIREPLACE)	ROUGH SOIL	PERMIT NO. DATE
WALL STEEL	ROUGH WATER	SLAB
COLUMN STEEL	TOP-OUT	ROUGH
BEAM STEEL	ROUGH GAS	FINAL ROUGH
FRAMING	A/C ROUGH DUCT	FINAL FIXTURE
ROOF SHEATHING	REF. ROUGH PIPING	FINAL ELECTRICAL
DRYWALL	FINAL PLUMBING	TEMPORARY SERVICE
LATHING	FINAL GAS	MISCELLANEOUS
BACKING (SIDING)	FINAL AIR COND.	GRADING & DRAINAGE
PLASTER SCRATCH	FINAL REFRIG.	ON-SITE PARKING SPACES
PLASTER BROWN	FINAL SEWER	ENG. APPROVAL OF
URBAN REDEVELOPMENT APPROVAL	FINAL SEPTIC TANK	OFF-SITE IMPROVEMENTS
FINAL BLDG. DATE		

APPROVED FOR OCCUPANCY & METER Final INSPECTOR W/10/24/12-28-70 DATE

PLEASE NOTE REMARKS ON REVERSE SIDE LOG # AREA # 23.04

1130 South Casino Center

DEPT. of BLDG. & SAFETY—CITY of LAS VEGAS, NEVADA

OWNER Jose Rayes ADDRESS 1130 S. Casino Center Blvd DATE 2-11-76

GEN. CONT. A. J. Allotta Bldg Co. TYPE OF STRUCTURE Hang doors, & paneling

PERMIT NO. 605 LEGAL DESCRIPTION L 22 B 7 Boulder Addn

BUILDING	MECHANICAL	ELECTRICAL
Investigation	Plumbing Cont.	Temp. pole cont.
Location & Footing	Permit No. Date	Permit No. Date
Stem Wall	Heat & Vent. A/C Cont.	Inspection Date
Concrete Slab Floor	Permit No. Date	Electrical Cont.
Floor Framing	Sewer Cont.	Permit No. Date
Fireplace Footing	Permit No. Date	Fixtures Cont.
Chimney Steel	ROUGH SOIL	PERMIT NO. DATE
Vert. Steel Reinf.	ROUGH WATER	SLAB
Horiz. Steel Reinf.	TOP-OUT	ROUGH
Roof Sheathing	ROUGH GAS	FINAL ROUGH
Framing	A/C ROUGH DUCT	FINAL FIXTURE
Backing for siding	REF. ROUGH PIPING	FINAL ELECTRICAL
Ext. Lath	FINAL PLUMBING	TEMPORARY SERVICE
Ext. Scratch	FINAL GAS	MISCELLANEOUS
Ext. Brown	FINAL AIR COND.	GRADING & DRAINAGE
Int. Lath	FINAL REFRIG.	ON-SITE PARKING SPACES
Int. Brown	FINAL SEWER	ENG. APPROVAL OF
Drywall	FINAL SEPTIC TANK	OFF-SITE IMPROVEMENTS
Permit No.		
Final Building		
Appr. for Occu.		

INSPECTOR: DATE

APPROVED FOR OCCUPANCY & METER

PLEASE NOTE REMARKS ON REVERSE SIDE 1130 S. Casino Center LOG # AREA #

These Remarks 3-9-81

642-8474

5-11-77

DEPT. of BLDG. & SAFETY - CITY of LAS VEGAS, NEVADA

OWNER Jose Reyes ADDRESS 1130 S. Casino Center DATE XXXXX-

GEN. CONT. A & T Const TYPE OF STRUCTURE Health Club

PERMIT NO. 2666 LEGAL DESCRIPTION L 21 B 22 Boulder Addition

BUILDING	MECHANICAL	ELECTRICAL
Investigation	Plumbing Cont. _____ Date _____	Temp. pole cont. _____ Date _____
Location & Footing	Permit No. _____	Permit No. _____ Date _____
Stem Wall	Heat & Vent. A/C Cont. _____ Date _____	Inspection _____ Date _____
Concrete Slab Floor	Permit No. _____	Electrical Cont. <u>gifford</u> <u>5-14-77</u> Date _____
Floor Framing	Sewer Cont. _____ Date _____	Permit No. <u>1842</u> <u>18542</u> Date _____
Fireplace Footing	Permit No. _____	Fixtures Cont. _____ Date _____
Chimney Steel	Rough Soil _____	Permit No. _____ Date _____
Vert. Steel Reinf.	Rough Water _____	Slab _____
Horiz. Steel Reinf.	Top-Out _____	Rough <u>185-35-77</u>
Roof Sheathing	Rough Gas _____	Final Rough _____
Framing <u>2-9-12-77</u>	A/C Rough Duct _____	Final Fixture _____
Backing for siding	Ref. Rough Piping _____	Final Electrical <u>189-21-77</u>
Ext. Lath	Final Plumbing _____	Temporary Service _____
Ext. Scratch	Final Gas _____	MISCELLANEOUS
Ext. Brown	Final Air Cond. _____	
Int. Lath	Final Refrig. _____	Grading & Drainage _____
Int. Brown	Final Sewer _____	On-Site Parking Spaces _____ App. _____
Drywall <u>2-9-15-77</u>	Final Septic Tank _____	Eng. Approval of _____
Permit No. _____		Off-Site Improvements _____
Final Building _____		
Appr. for Occu. _____		

INSPECTOR: _____ DATE _____

APPROVED FOR OCCUPANCY & METER _____

PLEASE NOTE REMARKS ON REVERSE SIDE 1130 So Casino Center LOG # _____ AREA # _____ M²46

DEPT. of BLDG. & SAFETY - CITY of LAS VEGAS, NEVADA

OWNER Vance A. Gagley ADDRESS 1130 S. Casino Center DATE 3-15-76

GEN. CONT. Loyd Const TYPE OF STRUCTURE Int remodel

PERMIT NO. 1143 LEGAL DESCRIPTION L 22 B 7 Boulder Addd

BUILDING	MECHANICAL	ELECTRICAL
Investigation	Plumbing Cont. _____ Date _____	Temp. pole cont. _____ Date _____
Location & Footing	Permit No. _____	Permit No. _____ Date _____
Stem Wall	Heat & Vent. A/C Cont. _____ Date _____	Inspection _____ Date _____
Concrete Slab Floor	Permit No. _____	Electrical Cont. _____ Date _____
Floor Framing	Sewer Cont. _____ Date _____	Permit No. _____ Date _____
Fireplace Footing	Permit No. _____	Fixtures Cont. _____ Date _____
Chimney Steel	Rough Soil _____	Permit No. _____ Date _____
Vert. Steel Reinf.	Rough Water _____	Slab _____
Horiz. Steel Reinf.	Top-Out _____	Rough _____
Roof Sheathing	Rough Gas _____	Final Rough _____
Framing	A/C Rough Duct _____	Final Fixture _____
Backing for siding	Ref. Rough Piping _____	Final Electrical _____
Ext. Lath	Final Plumbing _____	Temporary Service _____
Ext. Scratch	Final Gas _____	MISCELLANEOUS
Ext. Brown	Final Air Cond. _____	
Int. Lath	Final Refrig. _____	Grading & Drainage _____
Int. Brown	Final Sewer _____	On-Site Parking Spaces _____ App. _____
Drywall	Final Septic Tank _____	Eng. Approval of _____
Permit No. _____		Off-Site Improvements _____
Final Building _____		
Appr. for Occu. _____		

INSPECTOR: _____ DATE _____

APPROVED FOR OCCUPANCY & METER _____

PLEASE NOTE REMARKS ON REVERSE SIDE 1130 S. Casino Center LOG # _____ AREA # _____

W. H. Harris 8-1688

June 27, 1988
Longhorn Hotel
1130 Casino Center
Las Vegas, Nev. 89104
(702) 384-81 6

RE: Building Inspection
To whom it may concern,

The following items have been completed as of 6/25/88.

1. Replacement of defective emergency exit light.
2. Additional smoke detectors installed in hallway over heater air returns.
3. Fire hose inspected and certified by Master Protection Enterprises.
4. Testing, repair, or replacement of existing smoke detectors.
5. Testing, repair, or replacement of door closures.

Work is in progress on the following items.

1. Re-installation of doors in lobby/den room.
2. Remodeling of heater(s) return air duct systems.

Thank you.

James Hall
Pantel Inc.

James Hall

rph/JH

*Received by
John Doley #50
7/6/88
cc Micro Film
cc Central Actions
cc Fire Services
(Memad)*