

1316^S Casino Center

These Remarks 3-9-81

DEPT. of BLDG. & SAFETY - CITY of LAS VEGAS, NEVADA		
OWNER <u>Keith Henry</u>	ADDRESS <u>1316 S. Casino Center</u>	DATE <u>6-13-75</u>
GEN. CONT. <u>Owner</u>	TYPE OF STRUCTURE <u>L-13 B 9 Boulder Admn</u>	Room addn
PERMIT NO. <u>2563</u>	LEGAL DESCRIPTION	
BUILDING	MECHANICAL	ELECTRICAL
Investigation	Plumbing Cont. <u>Owner</u>	Temp. pole cont.
Location & Footing <u>4 B 6 11-75</u>	Permit No. <u>1487</u> Date	Permit No. Date
Stem Wall <u>WES 11-19-75</u>	Heat & Vent. A/C Cont.	Inspection Date
Concrete Slab Floor <u>4 B 6 11-75</u>	Permit No. Date	Electrical Cont. <u>Owner Peter</u>
Floor Framing	Sewer Cont.	Permit No. <u>1226-1396</u> Date <u>7-9-75</u>
Fireplace Footing	Permit No. Date	Fixtures Cont.
Chimney Steel	Rough Soil	Permit No. Date
Vert. Steel Reinf.	Rough Water	Slab
Horiz. Steel Reinf.	Top-Out <u>7-14-75</u>	Rough <u>VP 1-17-75 VP 9-35-75 8-13-75</u>
Roof Sheathing <u>4 B 6 11-75</u>	Rough Gas	Final Rough <u>VP 10-28-75 VP 12-2-75</u>
Framing	A/C Rough Duct	Final Fixture
Backing for siding	Ref. Rough Piping	Final Electrical
Ext. Lath	Final Plumbing	made by <u>P. R. R.</u>
Ext. Scratch	Final Gas	Temp. Dry Service
Ext. Brown	Final Air Cond.	MISCELLANEOUS
Int. Lath	Final Refrig.	Grading & Drainage
Int. Brown	Final Sewer	On-Site Parking Spaces App.
Drywall	Final Septic Tank	Eng. Approval of
Permit No.		Off-Site Improvements
Final Building		
Appr. for Occ.		

INSPECTOR:

DATE

APPROVED FOR OCCUPANCY & METER

PLEASE NOTE REMARKS ON REVERSE SIDE 1316 S. Casino Center LOG # AREA #

DEPARTMENT OF BUILDING & SAFETY
CITY OF LAS VEGAS, NEVADA

KARDEX CARD
FENCE & RETAINING
WALLS

OWNER Keith Henry ADDRESS 1316 S. Casino Center DATE 11-19-76

CONTRACTOR Owner PERMIT NO. 5816

LOT BLOCK SUBDIVISION block fence

Fence (wire, wood, etc.) Walls (masonry, rock, etc.)

Location WES 11-19-76 Location WES 11-19-76

Final Inspection Footing WES 11-19-76

Wall Steel 1st 2d 3d Final Inspection

Retaining Wall (masonry) Retaining Wall (concrete)

Location Footing

Footings Wall Steel 1st 2d 3d

Wall Steel 1st 2d 3d Final Inspection

Bond Beam 1st 2d 3d

Final Inspection

These Kymakos 3-9-81

DEPT. of BLDG. & SAFETY - CITY of LAS VEGAS, NEVADA		
OWNER: <u>H. DOESCHER</u>	ADDRESS: <u>1316 South 2nd St.</u>	DATE: <u>12/23/59</u>
GEN. CONT. <u>OTIS O. BRIANT</u>	TYPE OF STRUCTURE: <u>DUPLEX</u>	
PERMIT NO. <u>35102</u>	LEGAL DESCRIPTION: <u>Lot 13, Bl. 9, Boulder Addn.</u>	
LOCATION & FLOOR ELEVATION	PLUMBING CONT. <u>Support</u>	TEMP. POLE CONT.
FOOTINGS <u>Muller 12-31-59</u>	PERMIT NO. <u>32295</u> DATE <u>1-7-60</u>	PERMIT NO. DATE
FOUND. & PIERS	HEAT. & VENT. CONT.	INSPECTION DATE
WALL STEEL	PERMIT NO. DATE	ELECTRICAL CONT. <u>Support Elec</u>
BOND BEAM STEEL	SEWER CONT. <u>P</u>	PERMIT NO. <u>25723</u> DATE <u>1-22-60</u>
FRAMING & ROOF SHEATHING	ROUGH SOIL <u>Rendon 1-6-60</u>	OUTLETS <u>36</u>
STEEL FABRICATION	ROUGH WATER <u>Rendon 1-6-60</u>	MOTORS H.P.
CONNECTIONS & PAINTING	SEWER OR SEPTIC TANK <u>Rendon 1-6-60</u>	SLAB
LATHING	JOB-OUT	ROUGH <u>rough 1-20-60</u>
PLASTER	ROUGH GAS	FINAL ROUGH
SCRATCH	ROUGH DUCT	FIXTURE CONT. <u>Support Elec</u>
BROWN	FINAL PLUMBING <u>Bailey 3-14-60</u>	PERMIT NO. <u>25723</u> DATE <u>1-22-60</u>
FINAL BLDG. <u>Muller 4-8-60</u>	FINAL HEATING	FIXTURES <u>8</u>
GRADING & DRAINAGE	FINAL GAS	FINAL FIXTURE <u>rough 3-18-60</u>
ON-SITE PARKING SPACES		APPROVED FOR METER <u>Ally 4-8-60</u>
ENG. APPROVAL OF		
OFF-SITE IMPROVEMENTS		

APPROVED for OCCUPANCY:

INSPECTOR

DATE

PLEASE NOTE REMARKS ON REVERSE SIDE

1316 South 2nd St.

DUPLEX 12/23/59

23.04

Department of Building & Safety
City of Las Vegas, Nevada

Special Kardex
Elec. only, Plbg. only, A.C. only

Owner Seldon Babcock Address 1316 So. Casino Center Date: 7/18/69
Contractor Reitz Elec Permit No. 28422
Lot 23.06 D Block 23.06 D Subdivision 23.06 D

Electric Only	Plumbing Only	Heat. & Vent. A. C. Only
Contractor <u>Reitz Elec</u>	Contractor	Contractor
Permit No. <u>28422</u>	Permit No.	Permit No.
Slab	Rough Soil	A.C. Rough Duct
Rough Elect	Rough Water	Ref. Ro. Piping
Final Rough	Top Out	Rough Gas
Final Fixture	Rough Gas	Final Refrig
Final Elec <u>UP 7-24-69</u>	Final Plbg.	Final Air Cond
Temp. Service	Final Gas	Final Gas
	Final Sewer	
	Final Septic Tank	

23.06 D

Address

1316 So. Casino Center

Log No.

Area

Dona Hoesly

3-11-83

**BUILDING DEPARTMENT
CITY OF LAS VEGAS
CORRECTION NOTICE**

1st Notice

Job Located at 1376 Casino Center Dr.

I have this day inspected this structure and these premises and have found the following violations of City and/or State laws governing same:

*TV Antennas Tied To Service
Riser Pipe to Weather Head
with wire.*

*Antennas to be removed
within 24 hrs of 3-7-83.*

Return on 3-8-83.

You are hereby notified to correct above violation and call for re-inspection.

Date 3-7-83

D. Patterson
Inspector

23.03

Do not remove this tag!

F