

. A. 5317 Castle Harbor

Debbie Ingram 3-2-89

City of Las Vegas
**BUILDING DEPARTMENT
CITY OF LAS VEGAS**

Best Client
CORRECTION NOTICE

Job Located at *5317 Castle Harbor*

I have this day inspected this structure and these premises and have found the following violations of City and/or State laws governing same:

A/C not wired

Romex hanging loose in closet

OK. P.W.

You are hereby notified to correct above violation and call for re-inspection.

Date *11-7-88* *Robert Gould*
Inspector

23.03 Do not remove this tag!