

5607 Cavalier Cir

DEPARTMENT OF BUILDING & SAFETY. CITY OF LAS VEGAS

JOB ADDRESS: **5011 TROPICANA** **PR 192**

LOT NO.: **1** MAP NO.: **1** INSPECTOR: **KLK** DATE: **14 AUG 89**

SUBDIVISION NAME: **CLAYTON** INSPECTION DATE: **14 AUG 89**

INSPECTOR SIGNATURE: **KLK**

TAC# 05179

TEMP POLE

☐ PARTIAL INSPECTION - DESCRIPTION:

☐ PERMIT REQUIRED

☐ STOP WORK

☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE	☐ X-6	OTHER:
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING	☐ E-1	UNDERGROUND ELECTRICAL
☐ B-8	EXTERIOR LATH/STUCCO	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☒ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-10	PRE-GUNITE	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-11	PRE-PLASTER / FINAL	☐ X-1	KICKER / FLUSH	☐ E-5	FINAL ELECTRICAL
☐ B-12	BUILDING-FINAL			☒ E-6	TEMP POWER
☐ B-13	CERT. OF OCC.				

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS. SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

FOR ASSISTANCE - CALL: 386-8251