

A. *3204 Centavo

B. *3208 Centavo

C. *3212 Centavo

D. *3216 Centavo

E. *3220 Centavo

-2-

*Perimeter wall/see
8624 Spruce Lake

Reenie Benbow

4/6/90

CITY OF LAS VEGAS, NEVADA

LOG NO. & AREA

M-654

DATE

4/11/89

CONST. VAL. \$

1380.00

DEPARTMENT OF BUILDING AND SAFETY

PHONE 386-6251

BUILDING PERMIT

FOR: Swimming Pool or Spa

ADDRESS OF

CONSTRUCTION

3212 Centavo

OWNER

Brown

PHONE

NO.

303-5024

CONTRACTOR

TANGO POOLS, INC.

STATE

LICENSE NO.

11105

CITY

LICENSE NO.

8515

LOT(S)

12

BLOCK

2

SUBDIVISION

Los Lagos

ZONE

R.O.E.
R-CL

PLUMBING

CONTRACTOR

TANGO POOLS, INC.

ELECTRICAL

CONTRACTOR

R. D. S.

PERMIT NO.

Approval for the work under this permit will be given only after review and plans have been removed from job site and public right of way.

CIRCLE TYPE OF POOL THAT APPLIES:

PRIVATE

SEMI-PUBLIC

PUBLIC

SPA

MATERIALS OF CONSTRUCTION:

REINFORCED GUNITE

REINFORCED CONCRETE

OTHER

SQUARE FEET OF SURFACE POOL

SPA

38

VOLUME IN GALLONS

855

I state that I am familiar with the effective ordinances of the City of Las Vegas, Nevada and the effective Statutes of the State of Nevada covering construction and use of the above type; I agree to perform said construction in conformity therewith. I further agree that issuance of a permit on the above application will not excuse me from conforming with the said Ordinances and Statutes despite any errors on the part of the building inspector or engineer in checking plans and application herewith.

All swimming pools must be fenced before the pool is filled with water. No electrical lines shall cross over a pool. Applicants must have separate plot plans showing location of power pole, proposed or existing fencing and location of swimming pool. I agree to repair any utility line, if damaged during excavation work. I have read and understand the contents of above application. I hereby state that the same are true and correct.

SIGNED

Tango Pools

CONTRACTOR

BY

O. Hamlett

AGENT/OWNER

PLANNING DEPT.

Robert R. Hensley

DATE

4/11/89

BUILDING DEPT.

DATE

4/11/89

DESCRIPTION			FEE	TOTAL
ISSUANCE FEE			10.00	10.00
SEWER CONNECTION FEE (to 30,000 GALLONS)			58.00	58.00
BUILDING PERMIT - POOL & OR SPA:				
PLUMBING PERMIT-	PRIVATE POOL OR SPA	PREFORMED SPA	10.00	
		OTHERWISE	20.00	20.00
	PUBLIC OR SEMI-PUBLIC POOL OR SPA	PREFORMED SPA	20.00	
		OTHERWISE	30.00	04/11
FUEL PIPING FOR POOL HEATER			6.00	6.00
ELECTRICAL PERMIT	SPA		8.00	8.00
	SWIMMING POOL	RESIDENTIAL	20.00	
		PUBLIC-SEMI-PUBLIC	30.00	
	ELECTRICAL SERVICE CHANGE		6.00	
MISC.				
TOTAL FEES				102.00

RECEIPT

0006

POOL 10.00
SEWR 58.00
PLBG 26.00
ELEC 8.00
CHEK 102.00
4173A000 13:54

PERMIT NO.

MUST BE MACHINE VALIDATED

Reenie Benbow

4/6/90

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 3212 Centara		PERMIT NO. 21017
LOT NO.	MAP NO.	INSPECTOR 51
SUBDIVISION NAME		PHONE
INSPECTOR SIGNATURE G. Shoemaker		INSPECTION DATE 4-26
① NO Rough Gas INSP. ② Rough Gas Required 18" below Grade		
☐ PARTIAL INSPECTION - DESCRIPTION:		
☒ APPROVED ☐ PERMIT REQUIRED ☐ STOP WORK		
☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071		
INSPECT	DESCRIPTION	INSPECT DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1 ON SITE SEWER
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2 ON SITE WATER
☐ B-3	PRE-SLAB	☐ P-3 BUILDING SEWER (YARD LINES)
☐ B-4	ROOF SHEATHING	☐ P-4 UNDERSLAB PLUMBING
☐ B-5	FRAMING	☐ P-5 TOP OUT-WATER, GAS, WASTE
☐ B-6	INSULATION	☐ P-6 FINAL GAS TEST
☐ B-7	DRYWALL NAILING	☐ P-7 FINAL PLUMBING
☐ B-8	EXTERIOR LATH/STUCCO	☐ E-1 UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ E-2 ROUGH ELECTRICAL
☒ B-10	POOL PRE-GUNITE	☐ E-3 LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ E-4 SIGN INSPECTION
☐ B-12	BUILDING FINAL	☐ E-5 FINAL ELECTRICAL
☐ B-13	CERT. OF OCC.	☐ E-6 TEMP POWER
☐ FINAL INSPECTION		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)

FOR TECHNICAL ASSISTANCE - CALL: 799-6916

Reenie Benbow.

4/6/90

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 3212 Centavo		PERMIT NO. 21017	
LOT NO.	MAP NO.	INSPECTOR #51	DATE
SUBDIVISION NAME		PHONE	
INSPECTOR SIGNATURE G. Shoemaker		INSPECTION DATE 6-7	
① SPK OK - Plaster ② Gas line 12" below grade required 18" 2nd notice on Gas line			
☐ PARTIAL INSPECTION - DESCRIPTION:			
☐ APPROVED ☐ PERMIT REQUIRED ☐ STOP WORK			
☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071			
INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING
☐ B-8	EXTERIOR LATH/STUCCO	☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL	☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT. OF OCC.	☐ E-6	TEMP POWER
☐ X-1	KICKER / FLUSH		
☐ FINAL INSPECTION		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of Q. ISSUANCE (Commercial Only)	

FOR TECHNICAL ASSISTANCE - CALL: 799-6916

4/6/90

JOB ADDRESS 3212 Centaro		PERMIT NO. 21017	
LOT NO.	MAP NO.	INSPECTOR #57	DATE
SUBDIVISION NAME			PHONE
INSPECTOR SIGNATURE G. Shoemaker			INSPECTION DATE 6-13
Gas tag 993			
☐ PARTIAL INSPECTION - DESCRIPTION:			
☒ APPROVED ☐ PERMIT REQUIRED ☐ STOP WORK			
☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071			
INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER
☐ B-2	STEM WALL -> FORMS & REBAR	☐ P-2	ON SITE WATER
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING
☐ B-8	EXTERIOR LATH/STUCCO		
☐ B-9	WALL, GROUT & STEEL	☐ M-1	ROUGH VENT
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD
☒ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL
☐ B-12	BUILDING FINAL		
☐ B-13	CERT. OF OCC.	☐ X-1	KICKER / FLUSH
		☐ X-2	UNDERGROUND HYDRO
		☐ X-3	UNDERGROUND FINAL/FLOW
		☐ X-4	SPRINKLER SYSTEM HYDRO
		☐ X-5	FIRE ALARM
		☐ X-6	OTHER:
		☐ X-7	FINAL FIRE
		☐ E-1	UNDERGROUND ELETRICAL
		☐ E-2	ROUGH ELECTRICAL
		☐ E-3	LOW VOLTAGE ELECTRICAL
		☐ E-4	SIGN INSPECTION
		☐ E-5	FINAL ELECTRICAL
		☐ E-6	TEMP POWER
☐ FINAL INSPECTION		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)	

FOR ASSISTANCE CALL: 386-6251

Peenie Benbow

4/6/90

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 3212 CENTAVO		PERMIT NO. 31557	
LOT NO.	MAP NO.	INSPECTOR GF	DATE
SUBDIVISION NAME Los Lunas		PHONE	
INSPECTOR SIGNATURE (Signature)		INSPECTION DATE 11-14-89	
(DURA-KOOL) PATIO - COVER "VISUAL" FINAL, NO PREVIOUS INSP. EVER CALLED FOR			
☐ PARTIAL INSPECTION - DESCRIPTION:			
☒ APPROVED ☐ PERMIT REQUIRED ☐ STOP WORK			
☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071			
INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING
☐ B-8	EXTERIOR LATH/STUCCO		
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL
☐ B-12	BUILDING FINAL		
☐ B-13	CERT. OF OCC.	☐ X-1	KICKER / FLUSH
		☐ X-2	UNDERGROUND HYDRO
		☐ X-3	UNDERGROUND FINAL/FLOW
		☐ X-4	SPRINKLER SYSTEM HYDRO
		☐ X-5	FIRE ALARM
		☐ X-6	OTHER:
		☐ X-7	FINAL FIRE
		☐ E-1	UNDERGROUND ELECTRICAL
		☐ E-2	ROUGH ELECTRICAL
		☐ E-3	LOW VOLTAGE ELECTRICAL
		☐ E-4	SIGN INSPECTION
		☐ E-5	FINAL ELECTRICAL
		☐ E-6	TEMP POWER
☐ FINAL INSPECTION		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)	

FOR ASSISTANCE CALL: 386-6251