

620 HARRISON

L. Collins 3-26-82

DEPT. of BLDG. & SAFETY - CITY of LAS VEGAS, NEVADA		
OWNER: <u>CAL HENRY</u>	ADDRESS: <u>620 Harrison</u>	DATE: <u>5-13-57</u>
GEN. CONT. <u>OWNER</u>	TYPE OF STRUCTURE: <u>REPLACE SHEETROCK, damaged by fire.</u>	
PERMIT NO. <u>28853</u>	LEGAL DESCRIPTION: <u>Lot 1, Bl. 24, H.F.M. Sub.</u>	
LOCATION & FLOOR ELEVATION _____	PLUMBING CONT. _____	TEMP POLE CONT. _____
FOOTINGS _____	PERMIT NO. _____ DATE _____	PERMIT NO. _____ DATE _____
FOUND. & PIERS _____	HEAT. & VENT. CONT. _____	INSPECTION _____ DATE _____
WALL STEEL _____	PERMIT NO. _____ DATE _____	ELECTRICAL CONT. <u>Master</u>
BOND BEAM STEEL _____	SEWER CONT. _____	PERMIT NO. <u>20731</u> DATE <u>5/14/57</u>
FRAMING & ROOF SHEATHING _____	ROUGH SOIL _____	OUTLETS <u>17</u>
STEEL FABRICATION _____	ROUGH WATER _____	MOTORS _____ H.P. _____
CONNECTIONS & PAINTING _____	SEWER OR SEPTIC TANK _____	SLAB <u>Brick</u> <u>5-13-57</u>
LATHING _____	TOP-OUT _____	ROUGH <u>Master</u>
PLASTER _____	ROUGH GAS _____	FINAL ROUGH <u>Master</u>
SCRATCH _____	ROUGH DUCT _____	FIXTURE CONT. _____
BROWN _____	FINAL PLUMBING _____	PERMIT NO. _____ DATE _____
FINAL BLDG. <u>Edw</u> <u>6/4/57</u>	FINAL HEATING _____	FIXTURES <u>3</u>
GRADING & DRAINAGE _____	FINAL GAS _____	FINAL FIXTURE _____
ON-SITE PARKING _____ SPACES _____		APPROVED FOR METER: <u>Brick</u> <u>6/4/57</u>
ENG. APPROVAL OF _____		
OFF-SITE IMPROVEMENTS _____		

APPROVED for OCCUPANCY: _____

INSPECTOR _____

DATE _____

* PLEASE NOTE REMARKS ON REVERSE SIDE
620 Harrison Ave.-

REPLACE SHEETROCK-fire damage

5/13/57

23.04

BUILDING DEPARTMENT
CITY OF LAS VEGAS

CORRECTION NOTICE

Job Located at 120 HARRISON

I have this day inspected this structure
and these premises and have found the following
violations of City and/or State laws governing
same:

- #1. SERVICE PANEL AND METER
SOCKET MUST BE FASTENED
TO HOUSE
- #2. GROUNDING CONDUCTOR MUST
BE REPAIRED.

You are hereby notified to correct
above violation and call for re-inspection. BY 9 JAN, 87

Date 29 DEC 86 W. Ingram #71
Inspector

23.03 Do not remove this tag!