

1064 HART AVE.

*See Application*

Sharon P. ... June 21, 1977

BUILDING DEPARTMENT  
CITY OF LAS VEGAS

CORRECTION NOTICE

write 2nd notice 6/19/77  
Job Located at 1027 Hart

I have this day inspected this structure and these premises and have found the following violations of City and/or State laws governing same:

- 1) Service drop to low 8' 7" to grade 230-24 (b) 1975 N.E.C.
- 2) Cover on fuse panel missing 38A-13 1975 N.E.C.
- 3) Cover on adjacent panel not secured to box 38A-13 1975 N.E.C.

10 days to make corrections!

You are hereby notified to correct above violation and call for re-inspection.

Date 6/19/77 Inspector [Signature]

23.03 Do not remove this tag!

2ND NOTICE

Job Located at 1027 HART

I have this day inspected this structure and these premises and have found the following violations of City and/or State laws governing same:

- 1) Service drop to low 8' 7" to grade 230-24 (b) 1975 N.E.C.
- 2) Cover on fuse panel missing 38A-13 1975 N.E.C.
- 3) Cover on adjacent panel not secured to box 38A-13 1975 N.E.C.

10 days to make corrections

You are hereby notified to correct above violation and call for re-inspection.

Date 6/19/77 Inspector [Signature]

23.03 Do not remove this tag!

BUILDING DEPARTMENT  
CITY OF LAS VEGAS

CORRECTION NOTICE

Job Located at 1027 Hart

I have this day inspected this structure and these premises and have found the following violations of City and/or State laws governing same:

- 1) Service drop to low 8' 7" to grade 230-24 (b) 1975 N.E.C.
- 2) Cover on fuse panel missing 38A-13 1975 N.E.C.
- 3) Cover on adjacent panel not secured to box 38A-13 1975 N.E.C.

10 days to make corrections!

You are hereby notified to correct above violation and call for re-inspection.

Date 6/21/77 Inspector [Signature]

23.03 Do not remove this tag!

CITY OF LAS VEGAS

CORRECTION NOTICE

2ND NOTICE

Job Located at 1027 HART

I have this day inspected this structure and these premises and have found the following violations of City and/or State laws governing same:

- 1) Service drop to low 8' 7" to grade 230-24 (b) 1975 N.E.C.
- 2) Cover on fuse panel missing 38A-13 1975 N.E.C.
- 3) Cover on adjacent panel not secured to box 38A-13 1975 N.E.C.

10 days to make corrections

You are hereby notified to correct above violation and call for re-inspection.

Date 6/19/77 Inspector [Signature]

23.03 Do not remove this tag!

Sharon Perera June 21, 1977

**BUILDING DEPARTMENT  
CITY OF LAS VEGAS  
CORRECTION NOTICE**

Job Located at 1101 N. Hampton

I have this day inspected this structure and these premises and have found the following violations of City and/or State laws governing same:

1. Service loop to  
meter - 8" to grade  
2. 21 (b) 1975 D.F.C.  
3. 3rd and final notice  
failure to comply with  
electrical violations by  
July 15, 1977 will result  
in a Court citation being  
issued on that date.

You are hereby notified to correct above violation and call for re-inspection.

Date 7/1/77 [Signature]  
Inspector

23.03 Do not remove this tag!

**BUILDING DEPARTMENT  
CITY OF LAS VEGAS  
CORRECTION NOTICE**

Job Located at 1069 Hart

I have this day inspected this structure and these premises and have found the following violations of City and/or State laws governing same:

1. Service loop to  
meter - 8" to grade  
2. 21 (b) 1975 D.F.C.  
3. 3rd and final notice  
failure to comply with  
electrical violations by  
July 15, 1977 will result  
in a Court citation being  
issued on that date.

You are hereby notified to correct above violation and call for re-inspection.

Date 7/1/77 [Signature]  
Inspector

23.03 Do not remove this tag!