



LIGHTING PLAN
REFLECTED CEILING VIEW 1/4" = 1'-0"

LEGEND
THIS SHEET

- 2'x4' FLUORESCENT LIGHT FIXTURE
- 1'x4' FLUORESCENT LIGHT FIXTURE
- 2'x2' FLUORESCENT LIGHT FIXTURE
- EXIT LIGHT FIXTURE
- DIRECTIONAL EXIT LIGHT FIXTURE
- SWITCH
- 3-WAY SWITCH
- JUNCTION BOX - 4 SQUARE
- CONCEALED CONDUIT IN WALLS OR CEILING - CONDUCTORS AS INDICATED
- EXISTING FLUORESCENT STRIP FIXTURE
- EXISTING JUNCTION BOX
- EXISTING CEILING MOUNTED RECEPTACLE
- EXISTING SWITCH
- EXISTING SURFACE MOUNTED CONDUIT
- SEE FIXTURE SCHEDULE
- "
- "
- "
- "

GENERAL NOTES

1. ALL CONDUIT SHALL BE 1/2" UNLESS INDICATED OTHERWISE.
2. EQUIPMENT GROUND SHALL BE INSTALLED IN ALL CONDUIT.
3. GROUNDING IN BOXES SHALL BE MADE BY GREEN HEX HEAD MACHINE SCREW.
4. COLOR CODING OF CONDUCTORS SHALL BE AS FOLLOWS:

120/208 VOLT		277/480 VOLT
BLACK	AØ	BROWN
RED	BØ	ORANGE
BLUE	CØ	YELLOW
WHITE	NEUT.	WHITE
GREEN	GROUND	GREEN
5. CONDUCTORS SHALL BE #12 THIN UNLESS INDICATED OTHERWISE.
6. INSTALL PULL STRING IN TELEPHONE CONDUIT.

EQUIPMENT SCHEDULE

DESIGNATION	MANUFACTURER	CATALOG NUMBER	REMARKS
①	GENERAL ELECTRIC	CR101Y1	HEATER # CR123H873A ENCLOSURE # CR101X5, CR101X6
②	GENERAL ELECTRIC	CR120E11002	S.P.N.O. - 115 VAC COIL
③	NOTIFIER	BNG-1 SERIES 34	PULL STATION @ + 60" HORN @ + 7'-0"

FIXTURE SCHEDULE

DESIGNATION	MANUFACTURER	CATALOG NUMBER	VOLTAGE	LAMPS	REMARKS
①	BENJAMIN LIGHTING	AGA - 7244 - 4	277	CW	
②	BENJAMIN LIGHTING	AGA - 2244 - 4	277	CW	
③	BENJAMIN LIGHTING	AGA - 7224 - 2	277	CW	
④	PRESCOLITE	ER6	277	CW	CEILING MOUNT
⑤	PRESCOLITE	ER6 R	277	CW	CEILING MOUNT

Date _____

Revisions _____

Scale (s) AS SHOWN Scale (t) AS SHOWN W.U. 21G3

Fid. bk. no. _____ Date JULY 1982

Design by M. GOODMAN Drawn by N. GOMEZ / P. LEE

CITY ENGINEER DATE 8-23-82

Department of Public Services Engineering Design Division

LIGHTING PLAN
EQUIPMENT AND FIXTURE SCHEDULES

CAFETERIA REMODELING

Drawing no. 521-115B 5/8