



1. ALL UNDERGROUND PIPING SHALL BE PRESSURE TESTED TO 150 P.S.I. BEFORE COMPLETING BACKFILL.

<i>Temp. King</i> R.P.E #1118 TUREGUN AND ASSOCIATES ENGINEERING-PLANNING-MANAGEMENT CONSULT. 2120 INDUSTRIAL RD. LY. 89102				
CITY OF LAS VEGAS PUMP & STATION				
SCALE	DES.	DATE	CHG	OF
HOPE AS SHOWN DWN.		REV.	2	3
VERT	CHK.	REV.		

66070 (NOT BUILT)

22-13-22