

CHARLESTON RAINBOW UNIT N° 9-B

CHARLESTON RAINBOW UNIT N° 9-B

ALTA DRIVE

PALMIST DE

ANTELOPE WAY

CHARLESTON RAINBOW UNIT 9-C

GENERAL NOTES:

- 1) All construction and materials to meet City of Las Vegas Specifications.
- 2) All streetlight power sources to be placed underground.
- 3) All wires in conduit to be 600V 2 120/240V 3 wires, 2 insulated, 1 bare.
- 4) Luminaires to be high voltage 6.6 series, P.V.C. conduit to be placed as shown per special trench detail, 18" minimum depth, 24" min. depth across streets.

NOTE:

See telephone Co. dwgs. and power Co. dwgs. for power and telephone locations and details.

APPROVALS

[Signature] 7-17-70
Nevada Power Company date

[Signature]
City of Las Vegas Electrician date

[Signature] 7-21-70
Las Vegas City Engineer date

[Signature] 7-2-70
City of Las Vegas Field Engineer date

LEGEND AND ESTIMATE OF QUANTITIES

- 400 watt mercury vapor luminaire 15 each
- N° 3 1/2 Pull Box 3 each
- 175 watt mercury vapor luminaire 13 each
- 11 gage light standard 22 each
- 1 1/4" conduit, schedule 40



9-1-70	Extended Conduit on Hemlock	7-1-70
Date	Revision	Appd.
VTM nevada 2209 Paradise Rd. Las Vegas, Nevada		
MASTER STREETLIGHT PLAN CHARLESTON RAINBOW UNIT 9-A		Sheet 11 of 14
Submitted by: <i>[Signature]</i> Checked by: <i>[Signature]</i> Date: 7-22-70		RC-ET-1014

207 Y-1055-9A