

GENERAL NOTES:

- The locations of ends of all conduits in structures or terminating at curbs shall be marked by a "+" at least 3" high cut into the face of curb, gutter, or wall, directly above conduit.
- All conduit to have 24" minimum cover in all areas.
- All conduits for future use shall be cleaned, blown-out with compressed air and provided with a #9 AWG galvanized iron pull wire 2 feet of pull wire shall be doubled back into conduit at each termination and the end of the conduit shall be capped.
- All conduits at limits of construction shall be stubbed, capped and located for future extension of conduit runs and "AsBuilt" marked prints returned to the Electrical Engineer.
- When indicated on the plans, City forces to disconnect all existing high voltage lighting circuits and the contractor is to remove and deliver to City Yards all electrical material under the direction of the City Electrician.
- Photo cell relay control to be similar to Fisher Pierce model #6620-A, 120 volt, 60 cycle D.P.S.T. or approved equal.
- Multiple street lighting relay with photo-electric receptacle to be similar to Westinghouse RCOC type NRUC Spec # 6338 two pole N.O. 60 amp, 120/240 v A.C. with 120 A.C. coil and with holes A & B for 1 1/2" conduit or approved equal.

STREET LIGHTING SPECIFICATIONS

UNDERGROUND 120/240 VOLT SINGLE PHASE THREE WIRE MULTIPLE SYSTEM

Street lighting standards shall be as shown by Drawing No. 400.1 page 40 of Uniform Standard Drawings and must conform to Sections 400 and 405 and any other applicable sections of the Uniform Standard Specifications.

In 80' R/W streets there shall be 2 poles on diagonal corners.

In 100' R/W streets there shall be one pole at each corner.

Mercury Vapor Luminaires to be used on 51' R/W and 60' R/W streets, except at intersections, shall be 175 watt, 120/240 volt I.E.S. distribution type 3, with integral constant wattage ballast, similar to Line Material catalog #M44A2 or approved equal.

Mercury Vapor Luminaires to be used on 51' R/W and 60' R/W streets at intersecting minor streets shall be 250 watt 120/240 volt I.E.S. distribution type 2 with integral constant wattage ballast similar to General Electric Type M-250R, Catalog #C706G012 or approved equal.

Mercury Vapor Luminaires to be used on 80' R/W streets and over, shall be 400 watt 120/240 volt, I.E.S. distribution type 3 with integral constant wattage ballast similar to General Electric Type M-400, Catalog #C704G002 or approved equal.

175 watt Mercury Vapor Lamps shall be ASA Code #H37-5KC/W.

250 watt Mercury Vapor Lamps shall be ASA Code #H33-1GL/W.

400 watt Mercury Vapor Lamps shall be ASA Code #H33-1GL/W.

Spacing of standards shall be 180 feet maximum on 51' R/W and 60' R/W streets on one side to provide 0.43 F.C.

Spacing of standards shall be 180 feet maximum on 80' R/W streets on both sides, staggered to provide 0.9 F.C.

Spacing of standards on 100' R/W streets or more shall be 120 feet maximum on both sides and staggered to provide 1.4 to 2.0 F.C.

Standards used on 51' R/W and 60' R/W streets to be set within utility easement back of property line.

Standards used on 80' R/W streets and over to be set 18" back of curb.

Integral Conductor and Duct shall be two 600 Volt insulated conductors and one neutral conductor of the size specified in the applicable plans pre-assembled in a loose fitting flexible polyethylene duct and buried in the ground.

At the discretion of the Field Engineer, Sch. 40 Rigid Non-Metallic Conduit (PVC) or approved equal complying with Article 347 of the National Electrical Code may be used for underground applications.

Fuse Holders and Connectors shall be installed in the bases of all lighting standards, the fuse holders shall be water tight construction and shall be separable (pull-a-part) to provide a disconnecting means for circuit repairs.

Base covers for lighting standards are not to be installed before breakout caps are placed and inspected. All material used in underground wiring, in breakout caps and under base covers to be inspected before installation.

Foundations shall be constructed and located to line and grade as directed by the Field Engineer.

Lighting Standard and Mast Arm Cable to luminaire shall be two conductor #10 stranded 500 Volt copper cable. Each conductor shall be plasticized polyvinyl chloride insulated, with an outer jacket of black polyethylene.

The Contractor shall be responsible for avoiding damage to property, either public or private and in the event of such damage, shall make satisfactory repairs at his own expense.

The Contractor shall furnish complete service to transformers and control systems, if required.

The Service Point standard is to be installed at the approved location shown on plans and to conform to drawing #401.1 page 44 of the Uniform Standards Drawings.

In the selection of 175, 250 and 400 Watt Mercury Vapor Luminaires to be used in a particular development one approved manufacturer shall be specified.

These specifications shall become effective on all city of Las Vegas Multiple Street Lighting Designs approved on or after Jan. 1, 1968.

These specifications shall be superseded by any revised specifications in existence at the time of installation.

LEGEND AND ESTIMATE OF QUANTITIES

|   |                                  |                   |
|---|----------------------------------|-------------------|
| ○ | 250 WATT MERCURY VAPOR LUMINAIRE | 2 EA.             |
| ○ | 175 WATT MERCURY VAPOR LUMINAIRE | 6 EA.             |
| ○ | 11 GAGE LIGHT STANDARD           | 8 EA.             |
| — | 1 1/4" P.V.C. SCH. 40 CONDUIT    | 1265 L.F. (TOTAL) |
| — | DOUBLE UNDERGROUND               | 280 L.F.          |

General Notes

- All construction & materials to meet City of Las Vegas specs.
- All street light power source to be placed underground.
- All wires in conduit to be 600V #2 120/240V 3wires - 2 ins - 1 bare
- Luminaires to be high voltage G.G. series. P.V.C. conduit to be placed in 6" trench behind curb, 24" min. depth, 24" min. depth across streets.
- ST. LIGHTS ON MARCIA (ONLY) TO BE HIGH VOLTAGE UNDERGROUND. UNIFORM STD. DWGS. & SPECS. TO APPLY.
- ALL STREET STANDARDS TO BE LOCATED 18" BACK OF CURB.

APPROVALS

*Walter K. Johnson* 1-2-68  
Nevada Power Co. Date

*L. J. Bennett* 4-29-69  
Las Vegas City Electrician Date

City of Las Vegas Engineer Date

*J. D. Decker* 1-2-68  
Las Vegas Field Engr. Date

VOORHEIS-TRINDLE CO. OF NEVADA  
2209 PARADISE ROAD LAS VEGAS, NEVADA.

COLLEGE PARK UNIT No 32

MASTER STREET LIGHT PLAN

|          |                                                    |
|----------|----------------------------------------------------|
| 12-12-69 | Revised Service Point on Meyer from North to South |
| 1-10-68  | DELETED LOT 43 FR. BLK. 8 & LOT 31 FR. BLK. 9      |
| 1-8-68   | ADDED LOT 43 TO BLK. 8 & LOT 31 TO BLK. 9          |
| DATE     | REVISIONS                                          |

Submitted by: *Walter K. Johnson* 12/19/67  
Victor G. Kromatbauer R.C.E. 1511 Date

SHEET 10  
OF 10