



VICINITY MAP

General Notes:

1. All work to conform to Las Vegas Valley Water District (L.V.V.W.D.) Standard Specifications 3-1 STANDARD PLATES.
2. All except as modified herein shall be done in strict accordance with Clark County Standard Specifications
3. Notice to be given the L.V.V.W.D. Engineering Dept. 48 hours prior to actual construction.
4. Contractor to provide thrust blocks as required.
5. Service saddles or tapped collars will be required on all services.
6. All lines to be pressure tested to 200 psi.
7. All Flanged fittings to be coated with E.C. 244 and wrapped with 6 mil. thick polyethylene, 2 layers.
8. All valve boxes shall have conc. collars at surface of paved areas.
9. No other utility lines may be placed in same trench with water line.
10. Parallel sewer and water lines shall have a minimum of 10 foot horizontal separation and 3 foot vertical separation.
11. Deflection angle shall not exceed 5° per 13 foot section of pipe for pipe sizes smaller than 10" and shall not exceed 3° for sizes 10" and larger.
12. All water valves shall be operated under the direction of the L.V.V.W.D.
13. All water lines to be flushed to a velocity of 10' per second.
14. Contractor to furnish and install meter boxes to L.V.V.W.D. Specifications.

Approved By:

M. Wall 11/5/75
 Las Vegas Valley Water Dist. Date

Lawrence Hunter 12/2/75
 City of Las Vegas Engineer Date

J. D. Becken 12-9-75
 City of Las Vegas Field Engineer Date

George J. ... 12-3-1975
 City of Las Vegas Fire Chief Date

[Signature] 11/24/75
 District Health Dept. Date

Legend & Quantity Estimate

6" A.C.P.	1551 LF
3/4" water service	37 Ea.
① 6" Gate Valve FL x RT.	3 Ea.
② 6" x 6" x 6" Tee	1 Ea.
③ 6" Cap w/ Blowoff	1 Ea.
④ 3rd Fire Hydrant Assembly	3 Ea.

Submitted By:

Charley E. Johnson 10/21/75
 Charley E. Johnson Date
 P.E. # 3005

CONSULTING ENGINEERS • PLANNERS 2291 PARADISE ROAD LAS VEGAS, NEVADA 89105 (702) 731-8227				
Charleston Rainbow Unit No 12C MASTER WATER PLAN				
SCALE:	WO. NO. 1066-12C	DATE 10/21/75	SHEET	OF
HORIZ: 1" = 40'	DES. REV.	REV.	6	7
VERT: N.A.	CHK. REV.	REV.		

