

CHARLESTON VILLAGE GREEN NO. 2

Δ PORTION OF SECTION 31, TOWNSHIP 20 SOUTH, RANGE 62 EAST, M.D.B. & M.

NOTES FOR WATER LINE CONSTRUCTION

1. All work to conform to Las Vegas Valley Water District Standard Specification 2-1.
2. All work, except as modified herein, shall be done in accordance with Clark County Standard Specifications.
3. Notice to be given Engineering Department of the Las Vegas Valley Water District 48 hours prior to actual construction.
4. Service saddles or tapped collars will be required on all services.
5. Contractor to provide thrust blocks as required.
6. All lines to be pressure tested to 200 psi.
7. All flanged fittings to be coated with EC-244, and wrapped with 10-mil thick polyethylene.
8. Parallel sewer and water lines shall have a minimum of 10 feet horizontal separation and 3 foot minimum vertical separation on all water lines.
9. All valves shall have concrete collars at surface of paved areas.
10. No other utility lines may be placed in same trench with water lines.



VICINITY MAP
NO SCALE

INDEX OF SHEETS:

- 1 TITLE SHEET
- 2 GRADING PLAN
- 3 WATER PLAN
- 4 SEWER PLAN
- 5 LIGHTING PLAN

BENCH MARK:


CITY OF LAS VEGAS BOLT & PLATE IN TOP OF CURB AT NW CORNER OF LAMB BLVD. & CHARLESTON BLVD.
ELEVATION 1752.97'

REVISIONS
DATE NO. DESCRIPTION
1 12-1-73
2 12-1-73
3 12-1-73
4 12-1-73
5 12-1-73

PREPARED BY
JEROME WHITE

DATE OCT 1973
DESIGN
DRAWN
CHECK
SCALE

BAUGHMAN, HAUGHT & TURNER
CIVIL ENGINEERS
MINING ENGINEERS
LAND SURVEYORS
LAS VEGAS, NEVADA
2225 WEST CHARLESTON BOULEVARD
NO. 810-8711



TITLE SHEET
SECTION 31
TOWNSHIP 20 SOUTH, RANGE 62 EAST, M.D.B. & M.
CITY OF LAS VEGAS, COUNTY OF CLACK, STATE OF NEVADA

APPROVALS

[Signature]
CITY OF LAS VEGAS ENGINEER DATE 11-17-73

[Signature]
CITY OF LAS VEGAS ELECTRICAL ENGR DATE 11-17-73

[Signature]
CITY OF LAS VEGAS ELEC. COORDINATOR DATE 11-17-73

[Signature]
CITY OF LAS VEGAS FIRE DEPT. DATE 12-20-73

[Signature]
LAS VEGAS VALLEY WATER DIST. DATE

[Signature]
NEVADA POWER COMPANY DATE 12-21-73

NOTE: UTILITY INFORMATION WAS DERIVED FROM DATA FURNISHED BY UTILITY COMPANIES. CONTRACTOR MUST CONFIRM LOCATION OF UTILITIES BEFORE COMMENCING EXCAVATION.

