



**DROP INLET NOTE**  
 WHERE 10 FEET PARALLEL SEPARATION IS NOT PRACTICABLE:  
 CAST-IN-PLACE MONOLITHIC POUR WITH WATERSTOP BETWEEN SLAB AND WALLS. BASE, WALLS AND TOP TO BE CONSTRUCTED WITH WATERSTOPS, CENTER BULB, OR FLAT STRIP (VINYLEX, GREENSTREAK PLASTIC PRODUCTS OR APPROVED EQUAL).

**APPROVED FOR CONSTRUCTION**  
 LAS VEGAS VALLEY WATER DISTRICT ENGINEERING SERVICES MANAGER  
 PROJECT NO. 123547 DATE: 10/20/16

REV	DATE	DESCRIPTION
1	10/13/2016	ISSUED FOR PERMITS
2	10/13/2016	ISSUED FOR PERMITS
3	10/13/2016	ISSUED FOR PERMITS
4	10/13/2016	ISSUED FOR PERMITS
5	10/13/2016	ISSUED FOR PERMITS

**PROJECT NO. 62024-222**  
**G. C. WALLACE COMPANIES**  
 ENGINEERS | PLANNERS | SURVEYORS  
 1555 S. RAINBOW BLVD., LAS VEGAS, NV 89146  
 T: 702.804.2000 F: 702.804.2299 GCWALLACE.COM

**LAS VEGAS**  
 F:\Projects\600\62024-222\DWG\Production\24CB22+00.LA14.dwg  
 Matthew Burge

**THE HOWARD HUGHES COMPANY, LLC**  
 VILLAGE 24 - CROSSBRIDGE DRIVE UNIT 2  
 IMPROVEMENT PLANS

**OFFSITE GRADING AND CROSSBRIDGE DRIVE  
 DRAINAGE CORRIDOR CROSSING DETAILS 1**

DRAWING  
 10116535  
**40**  
 11/16/16  
 40 OF 53 SHTS

**SID NO. 612 PROJECT 9A, 9B AND 10A**  
 PROJ.#:123547 AGR#: 115478 QS:137-33-SE XC 11081

06/24/16.dwg 07/20/16