



**A** FIRE ALARM PLAN  
SCALE 1/8" = 1'-0"



87250



**GENERAL NOTES**

- 1 CONTRACTOR SHALL REFER TO THE SPECIFICATIONS FOR ACCEPTABLE MANUFACTURERS OF FIRE ALARM SYSTEM TO MEET CITY AND LOCAL FIRE DEPARTMENT REQUIREMENTS
- 1 FIRE ALARM CABLE ROUTING, CONDUIT ROUTING, CABLE AND ALARM DEVICES ARE DIAGRAMMATIC CONTRACTOR SHALL FOLLOW AND COMPLY WITH DRAWINGS FURNISHED BY FIRE ALARM CONTRACTOR

**ELECTRICAL PLAN KEYNOTES**

- ① 2#12 - 3/4" C
- ② 4#12 - 3/4" C
- ③ FIRE ALARM SMOKE DETECTOR (SEE SPECIFICATIONS FOR ACCEPTABLE MANUFACTURERS)
- ④ FIRE ALARM STROBE WITH HORN (SEE SPECIFICATIONS FOR ACCEPTABLE MANUFACTURERS)
- ⑤ FIRE ALARM PULL STATION (SEE SPECIFICATIONS FOR ACCEPTABLE MANUFACTURERS)



REVISIONS

△	11-15-04
---	----------

CONSULTANT

**JVC**  
ARCHITECTS

**atelier**

2290 Galleria Blvd.  
Las Vegas, NV 89103  
PH: 702.871.2416  
FAX: 702.871.2630

© JVC ASSOCIATES, INC. 2004

**CITY OF LAS VEGAS  
RECORDS ARCHIVAL  
MATERIALS STORAGE FACILITY  
BUFFALO & PEAK  
LAS VEGAS, NEVADA**

STAMP

--

OWNER: CITY OF LAS VEGAS  
DEPARTMENT OF PUBLIC WORKS  
ARCHITECTURAL SERVICES

400 EAST STEWART AVENUE  
LAS VEGAS, NEVADA 89103  
PHONE: (702) 229-6535  
FAX: (702) 386-3232  
TDD: (702) 386-9108

DRAWN	DJP
CHECK	SMH
FILE	
DATE	03.29.04
SCALE	
SHEET	
REV NO	
	04.15341.03
CLV DWG NO	
	521-288
SHT NO	

**E3.04**

CHANGES OR INSTRUMENTS OF SERVICE ARE THE PROPERTY OF THE DESIGN PROFESSIONAL. WHOSE STAMP OF CERTIFICATION APPEARS ON THE DRAWINGS AND SPECIFICATIONS REMAINS THE CLEAR AND UNALTERED COPY OF THE ORIGINAL AND SPECIFICATIONS REMAINS THE CLEAR AND UNALTERED COPY OF THE ORIGINAL. ANY OTHER PRODUCT IS A C. 822 280