



MATCH LINE 'A' - SEE SHEET 2



MATCH LINE 'B' - SEE SHEET 2



T,R,S: 1960-25  
APN: 12526409018



VICINITY MAP  
(NOT TO SCALE)

EVERY EFFORT HAS BEEN MADE TO IDENTIFY ALL NVE FACILITIES. THE CUSTOMER SHALL CONFIRM THE EXISTENCE AND LOCATION OF THESE FACILITIES.

AVOID HITTING OVERHEAD POWER LINES. IT'S COSTLY.

CALL BEFORE YOU DO OVERHEAD

CALL 1-702-402-2929

Call before you Dig  
Avoid cutting underground utility lines. It's costly.

**CALL 811**

OR  
1-800-227-2600  
AND CLARK COUNTY TRAFFIC OPERATIONS  
1-702-455-6000

REVISIONS

| NO. | DESCRIPTION | DATE | G.A. |
|-----|-------------|------|------|
| 1   |             |      |      |
| 2   |             |      |      |
| 3   |             |      |      |
| 4   |             |      |      |
| 5   |             |      |      |
| 6   |             |      |      |
| 7   |             |      |      |
| 8   |             |      |      |
| 9   |             |      |      |
| 10  |             |      |      |

MAINTENANCE

PURPOSE OF PROJECT  
REPLACE A FAULTY 1/0 BETWEEN  
PRU758 & DD654

EXHIBIT 'A'

NVEnergy INFORMATION:  
COORDINATOR: STAIT-GARDNER, IAN  
PHONE: (702)402-6857  
DESIGNER: PINDELL - TRC D.F. ---  
DCA: N/A  
INSPECTOR: 402-3008  
STAND BY: 402-4114, 402-4117, 402-4118, 402-4450  
DISTRICT: LAS VEGAS NORTH  
JPA INFORMATION:  
JPA ADMIN PHONE: N/A JPA#: N/A  
CUSTOMER INFORMATION:  
APPLICANT: NVE  
ENGINEER: N/A  
CONTACT: STAIT-GARDNER, IAN (702)402-6857  
APPROVAL DATE: \_\_\_\_\_  
GOVERNMENT INFORMATION:  
AGENCY: CITY OF LAS VEGAS  
APPROVAL DATE: \_\_\_\_\_

FOR EACH SERVICE POINT (POINT OF DELIVERY), ENERGY FOR EACH TENANT SPACE WILL BE MEASURED THROUGH ONE WATTHOUR METER. ENERGY FOR ALL NON-TENANT SPACE WILL BE MEASURED THROUGH ONE WATTHOUR METER. CONTACT NVE METER OPERATIONS FOR MULTIPLE RATE CLASS INSTALLATIONS.



PRI RETRENCH 6432  
ALISHIA CT  
ANN RD & TORREY PINES DR

PROJ. ID: 3001747700 SCALE: 1" = 30'  
SHEET # 1 OF 3 DATE: 01/18/2019

MAINTENANCE PROJECTS REQUIRE THE USE OF SCHEDULE 40 FOR ALL 2", 3", & 4" CONDUIT. D.B. 60 IS REQUIRED FOR ALL 6" CONDUIT. IF COILABLE CONDUIT IS USED, IT MUST BE H.D.P.E. WITHOUT RE-GROUND MATERIALS.

CITY OF LAS VEGAS  
PERMIT REQUIRED\*

CONTACT CLV LAND DEVELOPMENT (228-6371)  
CLV CONSTRUCTION SERVICES MUST BE NOTIFIED 24 HOURS PRIOR TO COMMENCING CONSTRUCTION (228-6337)

HANSEN DATE


\*NVE INSPECTOR MUST BE NOTIFIED BY FAX 48 HOURS PRIOR TO COMMENCING CONSTRUCTION & WILL VERIFY CITY PERMIT FOR WORK DONE IN STREETS OR SIDEWALK. FAX PERMIT TO:  
LAS VEGAS NORTH (RYAN CENTER): 402-4354  
LAS VEGAS SOUTH (BELTWAY CENTER): 402-6864

NOTE: ALL THE ABOVE GROUND UTILITY APPURTENANCES SHALL CONFORM TO THE REQUIREMENTS OF CLV UNIFIED DEVELOPMENT CODE TITLE 19.06 AND 19.08


APPROVED FOR CONSTRUCTION

THIS APPROVAL IS FOR WORK IN CLV R/W & EASEMENT ONLY. OBTAINING PERMISSIONS OR EASEMENTS FOR WORK SHOWN ON PRIVATE PROPERTY IS THE RESPONSIBILITY OF THE UTILITY.


APPROVAL 619-01045 100V/9855-PH/L DATE 7/19/19



MATCH LINE 'B' - SEE SHEET 1



| RTC NOTES:                                                                                    |                                                                                     |
|-----------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------|
| BACKFILL AND RIGHT OF WAY RESTORATION SHALL CONFORM TO CLARK COUNTY UNIFORM STANDARD DRAWINGS |                                                                                     |
| 1                                                                                             | 500.1 0 TO 5 YEARS PAVEMENT RESTORATION LONGITUDINAL CUT                            |
| 2                                                                                             | 500.2 0 TO 5 YEARS PAVEMENT RESTORATION TRANSVERSE CUT                              |
| 3                                                                                             | 500.3 OVER 5 YEARS PAVEMENT RESTORATION LONGITUDINAL CUT, GREATER THAN 60' R.O.W    |
| 4                                                                                             | 500.4 OVER 5 YRS PAVEMENT RESTORATION LONGITUDINAL CUT, 60' R.O.W OR LESS           |
| 5                                                                                             | 500.5 OVER 5 YRS PAVEMENT RESTORATION TRANSVERSE ALL R.O.W WIDTHS                   |
| 6                                                                                             | 501 TYPICAL UNDERGROUND UTILITY LOCATIONS IN RESIDENTIAL STREETS 60' OR LESS R.O.W. |
| 7                                                                                             | 501.1 TYPICAL UTILITY UNDERGROUND LOCATIONS IN STREETS WITH GREATER THAN 60' R.O.W. |
| 8                                                                                             | 503 METHOD B FOR RIGID AND FLEXIBLE PIPE TRENCH BACKFILL - PAVED AREAS              |
| 9                                                                                             | 503.1 METHOD A FOR FLEXIBLE PIPE TRENCH BACKFILL - PAVED AREAS                      |
| 10                                                                                            | 503.2 METHOD A FOR RIGID PIPE TRENCH BACKFILL - PAVED AREAS                         |
| 11                                                                                            | BACKFILL IN UNPAVED AREA AS REQUIRED BY LOCAL CODE OR AS APPROVED BY AGENCY.        |
| 12                                                                                            | 234 SIDEWALK                                                                        |



T,R,S: 1960-25  
APN: 12526409018

NET METERING

!!!! CAUTION !!!!  
ENERGIZED CABLES...  
CALL BEFORE YOU DIG

MATCH LINE 'A' - SEE SHEET 1

### RETRENCH

EXIST. NEW NVE WORK AND SERVICES TO CONSIST OF:  
--- 1/0 TRIPLEX, 15 KV AL PRIMARY CABLE IN 4" PLASTIC CONDUIT.  
--- 1/0, 15 KV AL PRIMARY CABLE IN 2" PLASTIC CONDUIT.  
--- INSTALL NEW CABLE IN EXISTING VACANT CONDUIT.

EX. 500 500 500 MCM TRIPLEX SECONDARY CABLE, CABLE IN CONDUIT (CONDUIT BY CONTRACTOR).  
EX. 350 350 350 MCM TRIPLEX SECONDARY CABLE, CABLE IN CONDUIT.  
EX. 4/0 4/0 4/0 AWG TRIPLEX SECONDARY CABLE, CABLE IN CONDUIT.  
EX. 2/0 2/0 2/0 AWG TRIPLEX SECONDARY CABLE, CABLE IN CONDUIT.

CONDUIT LOCATING DEVICE 18" ABOVE STUBOUT.  
~ SINGLE PHASE PRIMARY POLE RISER PER NVE U.G. STD. OEP-105.  
~ THREE PHASE PRIMARY POLE RISER PER NVE U.G. STD. OEP-106.  
~ SECONDARY RISER PER NVE U.G. STD. SSP-2.

SINGLE PHASE RESIDENTIAL PADMOUNTED TRANSFORMER WITH SIZE AS NOTED, 7200-120/240V, PER NVE U.G. STD. UT-113.  
(2) SINGLE PHASE RESIDENTIAL COMMERCIAL TRANSFORMERS WITH SIZE AS NOTED, 7200-120/240V, CONNECT OPEN WYE-OPEN DELTA FOR THREE PHASE 120-240V SERVICE, PER NVE U.G. STD. UT-115, WHERE APPLICABLE.

TERMINATION OF ALL MODULES, MAKES, SPLICES AND FINAL CONNECTIONS.

NVE TO PROVIDE 6" TO (3)2" REDUCERS.  
NVE TO PROVIDE 4" TO (1)2" REDUCERS.

NVE TO COIL PRIMARY CABLE IN PULLBOX FOR FUTURE SPLICES, WHERE APPLICABLE.

NVE TO CUT EXISTING CONDUIT AND TERMINATE PRIMARY CABLES ON THE LOAD BREAK MODULE, WHERE APPLICABLE.

100 FEET OUTSIDE RESIDENTIAL DEVELOPMENT MARKER. DCA TO PAY CONDUIT AND RISER COSTS INSIDE OF MARKER. CUSTOMER RESPONSIBLE FOR COSTS OUTSIDE MARKER.

CUSTOMER RESPONSIBILITY [ DCA RESPONSIBILITY

### CONTRACTOR TO FURNISH AND INSTALL:

ALL TRENCHING & BACKFILL, MEETING APPLICABLE NVE STANDARD (RT-7, RT-8, OR RT-12).

3" PLASTIC CONDUIT, PER NVE U.G. STD. RC-1 AND RC-2.  
3" PLASTIC CONDUIT BENDS (90°, 45°) WITH 36" MIN. RADIUS. (IF CONDUIT LENGTH IS UNDER 100')

3" RGS BENDS (90°, 45°) WITH 36" MINIMUM RADIUS, TAPED OR PVC COATED. (IF CONDUIT LENGTH IS OVER 100')

IF THE CUSTOMER CHOOSES TO INSTALL A STREET CROSSING, NVE REQUIRES A 4" CONDUIT PER SECONDARY CABLE, AND A 2" CONDUIT PER 1/0 CABLE.

2" DB120 PLASTIC CONDUIT (INCLUDING SWEEPS OR RISERS FOR HANDHOLES, TRANSFORMERS, PULLBOXES, ETC.).

2" SCH.40 PLASTIC CONDUIT BENDS (90°, 45°) WITH 48" MINIMUM RADIUS (IF CONDUIT LENGTH IS UNDER 500').

2" FIBERGLASS CONDUIT BENDS (90°, 45°) WITH 36" MINIMUM RADIUS (IF CONDUIT LENGTH IS OVER 500').

COUPLING FOR 2", 4", OR 6" CONDUITS (AS APPLICABLE).

ALL SERVICE CONDUIT - 2" MINIMUM DB60 PVC GRAY (RISER: RGS REQUIRED) WITH 5/32" POLYPROPYLENE PULL LINE WITH A MIN. BREAKING STRENGTH OF 1250 lbs.

17" X 30" HANDHOLE, PER NVE U.G. STD. RS-1 (WITH 8" COLLAR WHERE APPLICABLE).

2'-6" X 4' X 4' SPLICE PULLBOX PER NVE U.G. STD. RS-80.

3' X 7' X 4' PULLBOX PER NVE U.G. STD. RS-82.

PAD FOR (1) SINGLE PHASE RESIDENTIAL TRANSFORMER, PER NVE U.G. STD. RS-13 AND RS-5.

PAD FOR (2) SINGLE PHASE RESIDENTIAL TRANSFORMERS, PER NVE U.G. STD. RS-14 AND RS-5.

PAD FOR (1) SINGLE PHASE COMMERCIAL TRANSFORMER, PER NVE U.G. STD. RS-19 AND RS-5.

VEHICLE PROTECTIVE BARRIERS PER NVE U.G. STD. RS-6, WHERE APPLICABLE.

**CONSTRUCTION/INSPECTION REQUIREMENTS**  
WORK MUST CONFORM TO NVE ELECTRIC SERVICE STANDARDS, AVAILABLE AT: [www.nveenergy.com/business/newconstruction/newconstruction5/servicestandards.cfm](http://www.nveenergy.com/business/newconstruction/newconstruction5/servicestandards.cfm)  
NVE INSPECTOR MUST BE PRESENT TO INSPECT TRENCHING (SCHEDULE AT LEAST 72 HOURS IN ADVANCE) AT EACH OF THE FOLLOWING STAGES:  
1. BOTTOM SAND AND CONDUIT INSTALLED  
2. TOP SAND INSTALLED  
3. BACKFILL INSTALLED  
CONDUIT MUST BE MANOEUVRED PRIOR TO RELEASE (COORDINATE WITH INSPECTOR).  
NVE STAND BY CREW IS REQUIRED WHEN WORKING AT AN ENERGIZED VAULT OR TRANSFORMER. CALL STAND BY NUMBER (SEE TITLE BLOCK) TO SCHEDULE.  
NVE ELECTRICAL INSTALLATION WILL NOT BE SCHEDULED UNTIL AFTER THE NVE INSPECTOR HAS COMPLETED THE OPTICAL RELEASE.  
METER(S) WILL NOT BE SET UNTIL ALL OF THE FOLLOWING ARE COMPLETE:  
• [INSTRUMENT-RATED ONLY] METERING EQUIPMENT HAS BEEN SUBMITTED TO NVE METERING ENGINEER AND APPROVED. (submit@nveenergy.com)  
• APPLICATION FOR METER SET HAS BEEN SUBMITTED TO NVE'S NEW DEVELOPMENT CENTER. FORM AVAILABLE AT: [www.nveenergy.com/business/newconstruction/meter\\_set.pdf](http://www.nveenergy.com/business/newconstruction/meter_set.pdf)  
• THE LOCAL BUILDING AUTHORITY HAS INSPECTED AND APPROVED THE METERING EQUIPMENT.  
• METERING EQUIPMENT IS ACCESSIBLE AND CLEARLY IDENTIFIED WITH PERMANENT MARKINGS, ADDRESSES, SUITE NUMBERS, AND STREET SIGNS ARE POSTED IN PERMANENT LOCATIONS (SEE RPT-4)  
TRACK PROJECT STATUS ONLINE WITH NVE'S DEVELOPER DASHBOARD: [www.nveenergy.com/business/newconstruction/newconstruction5/developerdashboard.cfm](http://www.nveenergy.com/business/newconstruction/newconstruction5/developerdashboard.cfm)

**CITY OF LAS VEGAS  
PERMIT REQUIRED\***  
CONTACT CLV LAND DEVELOPMENT (228-6371)  
CLV CONSTRUCTION SERVICES MUST BE NOTIFIED 24 HOURS PRIOR TO COMMENCING CONSTRUCTION (228-6337)  
HANSER DATE  
\*NVE INSPECTOR MUST BE NOTIFIED BY FAX 48 HOURS PRIOR TO COMMENCING CONSTRUCTION & WILL VERIFY CITY PERMIT FOR WORK DONE IN STREETS OR SIDEWALK. FAX PERMIT TO: LAS VEGAS NORTH (RYAN CENTER) 402-4264 LAS VEGAS SOUTH (BETTY CENTER) 402-6864


**MAINTENANCE PROJECTS REQUIRE THE USE OF SCHEDULE 40 FOR ALL 2", 3", & 4" CONDUIT. D.B. 60 IS REQUIRED FOR ALL 6" CONDUIT. IF COILABLE CONDUIT IS USED, IT MUST BE H.D.P.E. WITHOUT RE-GROUND MATERIALS.**

NOTE: ALL THE ABOVE GROUND UTILITY APPURTENANCES SHALL CONFORM TO THE REQUIREMENTS OF CLV UNIFIED DEVELOPMENT CODE TITLE 19.06 AND 19.08

### APPROVED FOR CONSTRUCTION

THIS APPROVAL IS FOR WORK IN CLV R/W & EASEMENT ONLY. OBTAINING PERMISSIONS OR EASEMENTS FOR WORK SHOWN ON PRIVATE PROPERTY IS THE RESPONSIBILITY OF THE UTILITY.

APPROVAL DATE



VICINITY MAP  
(NOT TO SCALE)

EVERY EFFORT HAS BEEN MADE TO IDENTIFY ALL NVE FACILITIES. THE CUSTOMER SHALL CONFIRM THE EXISTENCE AND LOCATION OF THESE FACILITIES.

AVOID HITTING OVERHEAD POWER LINES. IT'S COSTLY.

CALL BEFORE YOU DO OVERHEAD

Call before you Dig  
Avoid cutting underground utility lines. It's costly.

**CALL 811**

OR  
1-800-227-2600  
AND CLARK COUNTY TRAFFIC OPERATIONS  
1-702-455-6000

### REVISIONS

| NO. | DESCRIPTION | DATE | G.A. |
|-----|-------------|------|------|
| 1   |             |      |      |
| 2   |             |      |      |
| 3   |             |      |      |
| 4   |             |      |      |
| 5   |             |      |      |
| 6   |             |      |      |
| 7   |             |      |      |
| 8   |             |      |      |
| 9   |             |      |      |
| 10  |             |      |      |
| 11  |             |      |      |
| 12  |             |      |      |

### MAINTENANCE

**PURPOSE OF PROJECT**  
REPLACE A FAULTY 1/0 BETWEEN  
PRU758 & DD654

### EXHIBIT 'A'


**NVEnergy INFORMATION:**  
COORDINATOR: STAIT-GARDNER, IAN  
PHONE: (702)402-6857  
DESIGNER: PINDELL - TRC D.F. ---  
DCA: N/A  
INSPECTOR: 402-3008  
STAND BY: 402-4114, 402-4117, 402-4118, 402-4450  
DISTRICT: LAS VEGAS NORTH  
**JPA INFORMATION:**  
JPA ADMIN PHONE: N/A JPA#: N/A  
**CUSTOMER INFORMATION:**  
APPLICANT: NVE  
ENGINEER: N/A  
CONTACT: STAIT-GARDNER, IAN (702)402-6857  
APPROVAL DATE: \_\_\_\_\_  
**GOVERNMENT INFORMATION:**  
AGENCY: CITY OF LAS VEGAS  
APPROVAL DATE: \_\_\_\_\_

FOR EACH SERVICE POINT (POINT OF DELIVERY), ENERGY FOR EACH TENANT SPACE WILL BE MEASURED THROUGH ONE WATTHOUR METER. ENERGY FOR ALL NON-TENANT SPACE WILL BE MEASURED THROUGH ONE WATTHOUR METER. CONTACT NVE METER OPERATIONS FOR MULTIPLE RATE CLASS INSTALLATIONS.




**PRI RETRENCH 6432**  
**ALISHIA CT**  
**ANN RD & TORREY PINES DR**


PROJ. ID: 3001747700 SCALE: 1" = 30'  
SHEET # 2 OF 3 DATE: 01/18/2019




TRENCH DETAIL  
(1)3" & (1)2" POWER CONDUIT (I.D.)  
SECTION "A"




TRENCH DETAIL  
1-2" CONDUIT  
SECTION "B"




TRENCH DETAIL  
SECTION "C"




TRENCH DETAIL  
1-2" CONDUIT  
SECTION "D"




TRENCH DETAIL  
1-2" CONDUIT  
SECTION "E"




TRENCH DETAIL  
2-2" CONDUITS  
SECTION "F"



TRENCH DETAIL  
(1)3" & (2)2" POWER CONDUIT (I.D.)  
SECTION "G"



TRENCH DETAIL  
1-2" CONDUIT  
SECTION "H"



TRENCH DETAIL  
(1)3" & (2)2" POWER CONDUIT (I.D.)  
SECTION "I"

## GENERAL NOTES:

ANY NOTES LOCATED IN DRAWING AREA TAKE PRECEDENCE OVER STANDARD NOTES.

ALL WORK SHALL BE ACCOMPLISHED IN STRICT ACCORDANCE WITH THE SPECIFICATIONS SET FORTH IN THE ELECTRIC SERVICE REQUIREMENTS HANDBOOK, AS CURRENTLY ADOPTED BY NVE. THE CONTRACTOR SHALL SECURE COPIES OF THE AFOREMENTIONED CONSTRUCTION SPECIFICATIONS ON HIS OR HER OWN BEHALF.

REFER TO A CURRENT NV ENERGY ELECTRIC SERVICE REQUIREMENTS HANDBOOK FOR FURTHER CLARIFICATION OF NVE STANDARDS.

THE APPLICANT SHALL INFORM THE INSPECTOR AT LEAST 48 HOURS BEFORE COMMENCING ANY ITEM OF CONSTRUCTION OR INSTALLATION OF MATERIAL TO ENABLE PROPER INSPECTION OF MATERIALS AND WORKMANSHIP. MAIN TRENCH WIRE PULLS TO BE SCHEDULED 72 HOURS IN ADVANCE OF INSTALLATION. APPLICANT'S PROJECT WILL NOT BE SCHEDULED UNTIL FINAL APPROVAL FROM NVE UNDERGROUND & ELECTRICAL INSPECTORS.

SYMBOLS ARE NOT TO SCALE AND DO NOT NECESSARILY REPRESENT ACTUAL LOCATIONS OF FACILITIES.

THIS DRAWING ILLUSTRATES DATA COLLECTED FROM VARIOUS SOURCES AND MAY NOT REPRESENT A SURVEY OF THE PREMISES.

APPLICANT SHALL FIELD DETERMINE POSITION AND DEPTH OF EXISTING UTILITY EQUIPMENT PRIOR TO COMMENCING CONSTRUCTION.

USE CAUTION PRIOR TO EXCAVATION. CHECK TO ENSURE ADDITIONAL DEPTH IS NOT REQUIRED TO ACCOMMODATE GAS AND/OR WATER FACILITIES AND DRAINAGE CHANNELS.

CALL NV ENERGY UNDERGROUND INSPECTORS 48 HOURS PRIOR TO START OF CONSTRUCTION FOR TRENCH INSPECTION BEFORE COVERING TRENCH.

ALL NVE CABLE TO BE INSTALLED BEHIND CURB, UNLESS OTHERWISE STATED.

APPLICANT IS RESPONSIBLE FOR STAKING OF PROPERTY CORNERS & ELEVATIONS.

ALL HANDHOLES AND PULLBOXES SHALL BE INSTALLED TO FINISHED GRADE OR 6" ABOVE IF GRADE IS NOT ESTABLISHED.

WHEN INSTALLING CONDUIT IN FIELD, USE APPROPRIATE BENDS TO COMPLETE THE INSTALLATION.

DEFLECTION OF CONDUIT BENDS AND CONDUIT NOT TO EXCEED NVE STANDARDS.

EXISTING CONDUIT INSTALLED BY PREVIOUS CONTRACTOR / DEVELOPER. NVE DOES NOT GUARANTEE LOCATION, LENGTH, OR ACCESSIBILITY OF STUB OUT. IF UTILIZING ANY PORTION OF EXISTING CONDUIT, IT MUST BE MANDRELLED PRIOR TO FINAL RELEASE.

PREVIOUSLY MANDRELLED CONDUIT WHICH HAS BEEN IN THE GROUND FOR OVER 6 MONTHS MUST BE RE-MANDRELLED PRIOR TO FINAL RELEASE.

NO COVERED PARKING IN FRONT OF EQUIPMENT.

ALL CONSTRUCTION AND MATERIALS SHALL BE IN ACCORDANCE WITH THE "UNIFORM STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION OFF-SITE IMPROVEMENTS, CLARK COUNTY AREA NEVADA", LATEST ISSUE; THE "UNIFORM STANDARD DRAWINGS FOR PUBLIC WORKS CONSTRUCTION, CLARK COUNTY AREA NEVADA", LATEST ISSUE; AND OTHER APPLICABLE APPROVED STANDARDS ISSUED BY THE CONTROLLING AGENCY; ALL LOCAL CITY CODES AND ORDINANCES APPLICABLE.

**CONSTRUCTION/INSPECTION REQUIREMENTS**  
WORK MUST CONFORM TO NVE ELECTRIC SERVICE STANDARDS, AVAILABLE AT:  
[www.nvenergy.com/business/newconstruction/newconstruction5/servicestandards.cfm](http://www.nvenergy.com/business/newconstruction/newconstruction5/servicestandards.cfm)  
NVE INSPECTOR MUST BE PRESENT TO INSPECT TRENCHING (SCHEDULE AT LEAST 72 HOURS IN ADVANCE) AT EACH OF THE FOLLOWING STAGES:  
1. BOTTOM SAND AND CONDUIT INSTALLED  
2. TOP SAND INSTALLED  
3. BACKFILL INSTALLED  
CONDUIT MUST BE MANDRELLED PRIOR TO RELEASE (COORDINATE WITH INSPECTOR).  
NVE STAND BY CREW IS REQUIRED WHEN WORKING AT AN ENERGIZED VAULT OR TRANSFORMER. CALL STAND BY NUMBER (SEE TITLE BLOCK) TO SCHEDULE.  
NVE ELECTRICAL INSTALLATION WILL NOT BE SCHEDULED UNTIL AFTER THE NVE INSPECTOR HAS COMPLETED THE OFFICIAL RELEASE.  
METER(S) WILL NOT BE SET UNTIL ALL OF THE FOLLOWING ARE COMPLETE:  
• INSTRUMENT-BASED ONLY METERING EQUIPMENT HAS BEEN SUBMITTED TO NVE METERING ENGINEER AND APPROVED. ([submitnls\\_meters@nvenergy.com](mailto:submitnls_meters@nvenergy.com))  
• APPLICATION FOR METER SET HAS BEEN SUBMITTED TO NVE'S NEW DEVELOPMENT CENTER. FORM AVAILABLE AT:  
[www.nvenergy.com/brochures\\_orch/new\\_construction/meter\\_set.pdf](http://www.nvenergy.com/brochures_orch/new_construction/meter_set.pdf)  
• THE LOCAL BUILDING AUTHORITY HAS INSPECTED AND APPROVED THE METERING EQUIPMENT.  
• METERING EQUIPMENT IS ACCESSIBLE AND CLEARLY IDENTIFIED WITH PERMANENT MARKINGS, ADDRESSES, SUITE NUMBERS, AND STREET SIGNS ARE POSTED IN PERMANENT LOCATIONS (SEE RPI-6).  
TRACK PROJECT STATUS ONLINE WITH NVE'S DEVELOPER DASHBOARD:  
[www.nvenergy.com/business/newconstruction/newconstruction5/developerdashboard.cfm](http://www.nvenergy.com/business/newconstruction/newconstruction5/developerdashboard.cfm)

MAINTENANCE PROJECTS REQUIRE THE USE OF SCHEDULE 40 FOR ALL 2", 3", & 4" CONDUIT. D.B. 60 IS REQUIRED FOR ALL 6" CONDUIT. IF COLLABLE CONDUIT IS USED, IT MUST BE H.D.P.E. WITHOUT RE-GROUND MATERIALS.

NOTE: PRIOR TO THE START OF TRENCHING CALL ALI MOHAMED AT 702-912-9409 OR RICK BEAN AT 702-378-1377 TO ARRANGE A FIELD MEETING.

## RETRENCH

EXIST. NEW NVE WORK AND SERVICES TO CONSIST OF:

1/0 TRIPLEX, 15 KV AL PRIMARY CABLE IN 4" PLASTIC CONDUIT.  
1/0, 15 KV AL PRIMARY CABLE IN 2" PLASTIC CONDUIT.  
INSTALL NEW CABLE IN EXISTING VACANT CONDUIT.

500 MCM TRIPLEX SECONDARY CABLE IN 4" PLASTIC CONDUIT (CONDUIT BY CONTRACTOR).  
350 MCM TRIPLEX SECONDARY CABLE, CABLE IN CONDUIT.  
4/0 AWG TRIPLEX SECONDARY CABLE, CABLE IN CONDUIT.  
2/0 AWG TRIPLEX SECONDARY CABLE, CABLE IN CONDUIT.

CONDUIT LOCATING DEVICE 18" ABOVE STUBOUT.  
SINGLE PHASE PRIMARY POLE RISER PER NVE U.G. STD. OEP-105.  
THREE PHASE PRIMARY POLE RISER PER NVE U.G. STD. OEP-106.  
SECONDARY RISER PER NVE U.G. STD. SSP-2.

SINGLE PHASE RESIDENTIAL PADMOUNTED TRANSFORMER WITH SIZE AS NOTED, 7200-120/240V, PER NVE U.G. STD. UT-113.  
(2) SINGLE PHASE RESIDENTIAL COMMERCIAL TRANSFORMERS WITH SIZE AS NOTED, 7200-120/240V, CONNECT OPEN WYE-OPEN DELTA FOR THREE PHASE 120-240V SERVICE, PER NVE U.G. STD. UT-115, WHERE APPLICABLE.

TERMINATION OF ALL MODULES, MAKES, SPLICES AND FINAL CONNECTIONS.

NVE TO PROVIDE 6" TO (3)2" REDUCERS.

NVE TO PROVIDE 4" TO (1)2" REDUCERS.

NVE TO COIL PRIMARY CABLE IN PULLBOX FOR FUTURE SPLICES, WHERE APPLICABLE.

NVE TO CUT EXISTING CONDUIT AND TERMINATE PRIMARY CABLES ON THE LOAD BREAK MODULE, WHERE APPLICABLE.

100 FEET OUTSIDE RESIDENTIAL DEVELOPMENT MARKER. DCA TO PAY CONDUIT AND RISER COSTS INSIDE OF MARKER. CUSTOMER RESPONSIBLE FOR COSTS OUTSIDE MARKER.

CUSTOMER RESPONSIBILITY [ DCA RESPONSIBILITY

EXIST. NEW CONTRACTOR TO FURNISH AND INSTALL:

ALL TRENCHING & BACKFILL, MEETING APPLICABLE NVE STANDARD (RT-7, RT-8, OR RT-12).

3" PLASTIC CONDUIT, PER NVE U.G. STD. RC-1 AND RC-2.  
3" PLASTIC CONDUIT BENDS (90°, 45°) WITH 36" MIN. RADIUS. (IF CONDUIT LENGTH IS UNDER 100')

3" RGS BENDS (90°, 45°) WITH 36" MINIMUM RADIUS, TAPED OR PVC COATED. (IF CONDUIT LENGTH IS OVER 100')

IF THE CUSTOMER CHOOSES TO INSTALL A STREET CROSSING, NVE REQUIRES A 4" CONDUIT PER SECONDARY CABLE, AND A 2" CONDUIT PER 1/0 CABLE.

2" DB120 PLASTIC CONDUIT (INCLUDING SWEEPS OR RISERS FOR HANDHOLES, TRANSFORMERS, PULLBOXES, ETC.).

2" SCH.40 PLASTIC CONDUIT BENDS (90°, 45°) WITH 48" MINIMUM RADIUS (IF CONDUIT LENGTH IS UNDER 500').

2" FIBERGLASS CONDUIT BENDS (90°, 45°) WITH 36" MINIMUM RADIUS (IF CONDUIT LENGTH IS OVER 500').

COUPLING FOR 2", 4", OR 6" CONDUITS (AS APPLICABLE).

ALL SERVICE CONDUIT - 2" MINIMUM DB60 PVC GRAY (RISER: RGS REQUIRED) WITH 5/32" POLYPROPYLENE PULL LINE WITH A MIN. BREAKING STRENGTH OF 1250 lbs.

17" X 30" HANDHOLE, PER NVE U.G. STD. RS-1 (WITH 8" COLLAR WHERE APPLICABLE).

2'-6" X 4' X 4' SPLICE PULLBOX PER NVE U.G. STD. RS-80.

3' X 7' X 4' PULLBOX PER NVE U.G. STD. RS-82.

PAD FOR (1) SINGLE PHASE RESIDENTIAL TRANSFORMER, PER NVE U.G. STD. RS-13 AND RS-5.

PAD FOR (2) SINGLE PHASE RESIDENTIAL TRANSFORMERS, PER NVE U.G. STD. RS-14 AND RS-5.

PAD FOR (1) SINGLE PHASE COMMERCIAL TRANSFORMER, PER NVE U.G. STD. RS-19 AND RS-5.

VEHICLE PROTECTIVE BARRIERS PER NVE U.G. STD. RS-6, WHERE APPLICABLE.

## CITY OF LAS VEGAS PERMIT REQUIRED\*

CONTACT CLV LAND DEVELOPMENT (229-6371)  
CLV CONSTRUCTION SERVICES MUST BE NOTIFIED 24 HOURS PRIOR TO COMMENCING CONSTRUCTION (229-6377)

HANSEN DATE


\*NVE INSPECTOR MUST BE NOTIFIED BY FAX 48 HOURS PRIOR TO COMMENCING CONSTRUCTION & WILL VERIFY CITY PERMIT FOR WORK DONE IN STREETS OR SIDEWALK. FAX PERMIT TO:  
LAS VEGAS NORTH (RYAN CENTER): 402-4354  
LAS VEGAS SOUTH (BETWAY CENTER): 402-6864

NOTE: ALL THE ABOVE GROUND UTILITY APPURTENANCES SHALL CONFORM TO THE REQUIREMENTS OF CLV UNIFIED DEVELOPMENT CODE TITLE 19.06 AND 19.08

APPROVED FOR CONSTRUCTION

THIS APPROVAL IS FOR WORK IN CLV R/W & EASEMENT ONLY. OBTAINING PERMISSIONS OR EASEMENTS FOR WORK SHOWN ON PRIVATE PROPERTY IS THE RESPONSIBILITY OF THE UTILITY.

APPROVAL DATE



VICINITY MAP  
(NOT TO SCALE)

EVERY EFFORT HAS BEEN MADE TO IDENTIFY ALL NVE FACILITIES. THE CUSTOMER SHALL CONFIRM THE EXISTENCE AND LOCATION OF THESE FACILITIES.

AVOID HITTING OVERHEAD POWER LINES. IT'S COSTLY.  
CALL BEFORE YOU DO OVERHEAD

Call before you Dig  
Avoid cutting underground utility lines. It's costly.

CALL 811 OR 1-800-227-2600

AND CLARK COUNTY TRAFFIC OPERATIONS 1-702-455-6000

## REVISIONS

| NO. | DESCRIPTION | DATE | G.A. |
|-----|-------------|------|------|
| 1   |             |      |      |
| 2   |             |      |      |
| 3   |             |      |      |
| 4   |             |      |      |
| 5   |             |      |      |
| 6   |             |      |      |
| 7   |             |      |      |
| 8   |             |      |      |
| 9   |             |      |      |
| 10  |             |      |      |
| 11  |             |      |      |
| 12  |             |      |      |
| 13  |             |      |      |
| 14  |             |      |      |
| 15  |             |      |      |
| 16  |             |      |      |
| 17  |             |      |      |
| 18  |             |      |      |
| 19  |             |      |      |
| 20  |             |      |      |
| 21  |             |      |      |
| 22  |             |      |      |
| 23  |             |      |      |
| 24  |             |      |      |
| 25  |             |      |      |
| 26  |             |      |      |
| 27  |             |      |      |
| 28  |             |      |      |
| 29  |             |      |      |
| 30  |             |      |      |
| 31  |             |      |      |
| 32  |             |      |      |
| 33  |             |      |      |
| 34  |             |      |      |
| 35  |             |      |      |
| 36  |             |      |      |
| 37  |             |      |      |
| 38  |             |      |      |
| 39  |             |      |      |
| 40  |             |      |      |
| 41  |             |      |      |
| 42  |             |      |      |
| 43  |             |      |      |
| 44  |             |      |      |
| 45  |             |      |      |
| 46  |             |      |      |
| 47  |             |      |      |
| 48  |             |      |      |
| 49  |             |      |      |
| 50  |             |      |      |
| 51  |             |      |      |
| 52  |             |      |      |
| 53  |             |      |      |
| 54  |             |      |      |
| 55  |             |      |      |
| 56  |             |      |      |
| 57  |             |      |      |
| 58  |             |      |      |
| 59  |             |      |      |
| 60  |             |      |      |
| 61  |             |      |      |
| 62  |             |      |      |
| 63  |             |      |      |
| 64  |             |      |      |
| 65  |             |      |      |
| 66  |             |      |      |
| 67  |             |      |      |
| 68  |             |      |      |
| 69  |             |      |      |
| 70  |             |      |      |
| 71  |             |      |      |
| 72  |             |      |      |
| 73  |             |      |      |
| 74  |             |      |      |
| 75  |             |      |      |
| 76  |             |      |      |
| 77  |             |      |      |
| 78  |             |      |      |
| 79  |             |      |      |
| 80  |             |      |      |
| 81  |             |      |      |
| 82  |             |      |      |
| 83  |             |      |      |
| 84  |             |      |      |
| 85  |             |      |      |
| 86  |             |      |      |
| 87  |             |      |      |
| 88  |             |      |      |
| 89  |             |      |      |
| 90  |             |      |      |
| 91  |             |      |      |
| 92  |             |      |      |
| 93  |             |      |      |
| 94  |             |      |      |
| 95  |             |      |      |
| 96  |             |      |      |
| 97  |             |      |      |
| 98  |             |      |      |
| 99  |             |      |      |
| 100 |             |      |      |

## MAINTENANCE

PURPOSE OF PROJECT  
REPLACE A FAULTY 1/0 BETWEEN  
PRU758 & DD654

## EXHIBIT 'A'

NVEnergy INFORMATION:  
COORDINATOR: STAIT-GARDNER, IAN  
PHONE: (702)402-6857  
DESIGNER: PINDELL - TRC D.F. ---  
DCA: N/A  
INSPECTOR: 402-3008  
STAND BY: 402-4114,402-4117,402-4118,402-4450  
DISTRICT: LAS VEGAS NORTH

JPA INFORMATION:  
JPA ADMIN PHONE: N/A JPA#: N/A

CUSTOMER INFORMATION:  
APPLICANT: NVE  
ENGINEER: N/A  
CONTACT: STAIT-GARDNER, IAN (702)402-6857

APPROVAL DATE:  
GOVERNMENT INFORMATION:  
AGENCY: CITY OF LAS VEGAS

APPROVAL DATE:  
FOR EACH SERVICE POINT (POINT OF DELIVERY), ENERGY FOR EACH TENANT SPACE WILL BE MEASURED THROUGH ONE WATT/OUR METER. ENERGY FOR ALL NON-TENANT SPACE WILL BE MEASURED THROUGH ONE WATT/OUR METER. CONTACT NVE METER OPERATIONS FOR MULTIPLE RATE CLASS INSTALLATIONS.

NVEnergy.

PRI RETRENCH 6432  
ALISHIA CT  
ANN RD & TORREY PINES DR

PROJ. ID: 3001747700 SCALE: 1" = 30'  
SHEET # 3 OF 3 DATE: 01/18/2019