

2200 Mc Williams

Lot 16 Blk 1 Greater Las Vegas Addn#1 Zone R1

Theresa Kynalka 10-9-80

CITY OF LAS VEGAS, NEVADA

LOG NO. & AREA

CONST. VAL. \$ 3000.00

DEPARTMENT OF PUBLIC SERVICES
DIVISION OF BUILDING AND SAFETY

APPLICATION & BUILDING PERMIT - for:
Dwellings, Duplexes, Misc. Residential Const.

ADDRESS OF CONSTRUCTION: 2200 E. McWilliams

OWNER: James Weaver

LOT(s) 16 BLOCK 1 SUBDIVISION Center Las Vegas Addition #1 ZONE: R-1

Existing structure on lot: Dwelling ☒ Accessory Bldgs. ☐ Vacant Lot ☐ Other ☐

PROPOSED CONSTRUCTION: Ins. Vinyl Siding

USE:

MATERIALS OF CONSTRUCTION: Wood Frame ☐ Concrete Block ☐ Reinforced Concrete ☐ Steel Frame ☐

SQUARE FEET OF FLOOR AREAS: 1st 2nd 3rd Other TOTAL SQ. FT.


FIRE ZONE: Occupancy Group CONST. TYPE:

ARCHITECT: ENGINEER: NO. of UNITS NO. of STORIES

Plans Submitted: Yes ☐ No ☐ Calculations Submitted: Yes ☐ No ☐ Sewer Fee Req'd: Yes ☐ No ☐

CONTRACTOR Dura-Kool Alum. Prod. Inc. STATE LICENSE # 11488-A CITY LICENSE # 10254

ADD'L. PERMITS REQ'D.: Air Cond. ☐ Elec. ☐ Plumbing ☐ Signs ☐ Paving ☐ Fence ☐ Public Walks ☐ Curb-gutters ☐
Incinerators ☐ Fire Sprinkling System ☐



CONDITIONS OF THE PERMIT:

1. I agree to call the City Building Department for inspections before concrete is poured, before rough wiring, electrical, plumbing, framing is covered. Also for Air conditioning, drywall and weathering inspection.
2. I agree that when the job is completed, that I will call for final inspection before occupancy.
3. I agree to perform all construction in accordance with City Ordinances and Building Codes.
4. The Contractor's signature below denotes authority from the owner to sign in his behalf and that the owner is aware of all requirements of this application and permit. Separate permits must be taken out for work outlined above this agreement.
5. I have read and understand the contents of this application and permit. I hereby state that the information I have supplied on this application is true and correct.

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way.

SIGNED: Dura-Kool Alum. Prod. Inc. Contractor

BY: Betty Cohen Agent or Owner
Betty Cohen Sec-Treas

PLANNING DEPT.: [Signature] Date: 30 Oct 80

PUBLIC WORKS DEPT.: [Signature] Date: 10-3-80

BUILDING DIVISION: [Signature] Date: 10/3/80

PERMIT NO.: 5584-1 PERMIT FEE: \$ 18.00

1721-2401

RECEIPT

MUST BE MACHINE VALIDATED

Don H. H. H.

9-17-52

OWNER <u>First Securities Co. of Nevada</u>		ADDRESS <u>2200 Mc Williams Ave</u>	
CONTRACTOR <u>Rame</u>		DATE <u>8-30-55</u>	
PERMIT NO. <u>23366</u>		<u>216 N. W. 2nd St. Addn #1</u>	
FOUNDATION <u>See 9/14</u>		PLUMBING CONTR. <u>United</u>	
STEEL	INSR _____ DATE _____	PERMIT <u>21348</u>	DATE <u>9-8</u>
FOOTINGS	_____	NO. FIXTURES <u>8</u>	_____
WALLS	_____	ROUGH	INSR <u>24</u> DATE <u>4-29</u>
PIERS	_____	WATER TEST	INSR <u>25</u> DATE <u>4-29</u>
FIREPLACE	_____	ROUGH INSR <u>24</u>	DATE <u>4-29</u> NO. <u>3</u>
FORMS	_____	GAS	FINAL INSR <u>25</u> DATE <u>4-29</u> OUTLETS
STEEL	INSR _____ DATE _____	WATER HTR. & VENT. INSR	DATE <u>4-29</u>
WALL	_____	SEWER	INSR <u>25</u> DATE <u>4-29</u>
BOND BEAM	_____	CONTR. <u>Rame</u>	_____
COLUMNS	_____	PERMIT NO. _____	DATE _____
CHIMNEY	_____	PROPERTY LINE	_____
FRAMING	INSR <u>24</u> DATE <u>4-29</u>	SEPTIC TANK	INSR _____ DATE _____
ROOF SHEATHING	<u>24</u> <u>11-16</u>	CONTR. _____	_____
ROOF	_____	PERMIT NO. _____	DATE _____
LATH	INSR _____ DATE _____	HTR. & VENT. INSR	DATE _____
INTERIOR	<u>WH</u> <u>12-20</u>	CONTR. <u>Brown & Hise</u>	_____
EXTERIOR	<u>24</u> <u>11-29</u>	PERMIT NO. <u>21532</u>	DATE <u>4-21</u>
PLASTER	INSR _____ DATE _____	ROUGH INSR	DATE _____
SCRATCH	_____	HT. FINAL INSR	DATE _____
BROWN	<u>WH</u> <u>12-20</u>	VENT. ROUGH INSR	DATE _____
FINAL BLDG	INSR <u>24</u> DATE <u>2-10</u>	VENT. FINAL INSR	DATE _____
		FINAL PLOD. INSR <u>BN</u>	DATE <u>1-31</u>
		ELECT. CONTR. <u>Builders</u>	_____
		PERMIT <u>17599</u>	DATE <u>1-19</u>
		TEMP. POWER INSR	DATE _____
		TEMP. LIGHT INSR	DATE _____
		LIGHT OUTLETS	_____
		SWITCHES	_____
		115 V RECEPTACLES	_____
		230 V RECEPTACLES	_____
		RANGES	_____
		WATER HTRS.	_____
		COOLERS	_____
		MOTOR H.R.	_____
		FESTOON LIGHTING	_____
		SPACE HEATERS	_____
		FIXTURES	_____
		NEON SIGNS	_____
		TEMPORARY SERVICE	_____
		FINAL ELECT. <u>1-19</u>	_____

JOB COMPLETED

DATE

SIGNED

Don H. H. H.

2200 Mc Williams Ave.

29.29

Donna Hotala : 9-27-82

OWNER <u>James Weaver</u>		ADDRESS <u>2200 E McWilliams</u>	
DATE <u>10-3-80</u>		GEN. CONT. <u>Dura Kool Alum</u>	
TYPE OF STRUCTURE <u>Ins. Vinyl Siding</u>		PERMIT NO. <u>5584-1</u>	
LEGAL DESCRIPTION <u>L-16 B-1 Greater Las Vegas Addn Tr #1</u>		FINAL INSPECTION LOG # <u> </u> AREA # <u> </u>	
APPROVED FOR OCCUPANCY & METER			
BUILDING		MECHANICAL	
Investigation		Plumbing Cont.	
Location & Footing		Permit No. <u> </u> Date <u> </u>	
Concrete Slab Floor		Heat & Vent. A/C Cont. <u> </u>	
Fireplace Footing		Permit No. <u> </u> Date <u> </u>	
Chimney, Steel		Sewer Cont.	
Vert. Steel Reinf.		Permit No. <u> </u> Date <u> </u>	
Horiz. Steel Reinf.		Rough Soil <u> </u>	
Framing		Rough Water <u> </u>	
Ext. Lath		Top-Out	
Ext. Brown		Rough Gas <u> </u>	
Drywall		A/C Rough Duct <u> </u>	
Final Building <u>KD 0-2380</u>		Final Plumbing <u> </u>	
Appr. for Occu. <u> </u>		Final Gas <u> </u>	
ELECTRICAL		Final Air Cond. <u> </u>	
Temp. Pole Cont. <u> </u>		Final Sewer <u> </u>	
Permit No. <u> </u> Date <u> </u>		REMARKS <u> </u>	
Inspection <u> </u> Date <u> </u>		<u> </u>	
Electrical Cont. <u> </u>		<u> </u>	
Permit No. <u> </u> Date <u> </u>		<u> </u>	
Rough <u> </u>		PLEASE NOTE ADDITIONAL REMARKS ON REVERSE SIDE.	
Final Rough <u> </u>		DIV. OF BLDG. & SAFETY	
Final Electrical <u> </u>		CITY OF LAS VEGAS	
Temporary Service <u> </u>		REV 10-78	
		79-3-16	

Mariame Francis

6-14-84

CITY OF LAS VEGAS, NEVADA

LOG NO. & AREA

DATE

CONST. VAL. \$

DEPARTMENT OF BUILDING AND SAFETY

PHONE 386-6251

ELECTRICAL PERMIT

ADDRESS OF CONSTRUCTION 2200 E. McWilliams

OWNER James Weaver

CONTRACTOR All Electric, Inc.

STATE LICENSE NO 10423

CITY LICENSE NO 036-2-02635

LOT(s) BLOCK SUBDIVISION

ZONE

PROPOSED CONSTRUCTION

USE SFD

ELECTRIC PERMIT NO 1388

Approval for the work under this permit will be given only after refuse and debris have been removed from job site and public right of way.

UNITS	DESCRIPTION	FEE	TOTAL
PERMIT ISSUANCE			
	For Issuing Each Permit	10.00	10.00
	Supplemental Fee	1.50	
APPLIANCE CHARGE			
	Receptacle Switch	.40	
	Each Light Fixture or Socket	.30	
	EACH OUTLET FOR:	.70	
	Dishwasher, Garbage Grinder, Trash Compactor, G.F.L., Clothes Washer, Dryer, Electric Range, Ovens, Smoke Detector, Special Purpose, Water Heater, Space Heater, Blast Coil Heater (PER K.W.), Mercury Lamp, Quartz Lamp, Sodium Lamp		
	X-Ray Unit	10.00	
	Area Lighting (First 3,000 Watts)	8.00	
	Each Additional 1,000 Watts	3.00	
	Motors (1/2 H.P. And Over) Transformers Welders, Generators		
	First H.P. For each Unit	3.00	
	First KVA For Each Unit	.50	
	Each Additional H.P. or KVA	.30	
	Temporary power or Pole	6.00	
	Electric Service (Incl'd First Meter)	6.00	6.00
	Up to 200 AMP		
	400 AMP And 600 AMP	12.50	
	Over 600 AMP To 1200 AMP	25.00	
	Over 1200 AMP	50.00	
	Each Additional Meter Socket	.50	
	Sub Panel (Each)	3.00	
	Swimming Pool (Residential)	20.00	
	Swimming Pool (Semi-Public)	30.00	
	Spas	8.00	
	Recreational Vehicle Spaces (Each)	3.00	
	Busways-Trolley or Plug-in (Ea. 100 Ft.)	3.00	

UNITS	DESCRIPTION	FEE	TOTAL
	Gasoline Dispenser	2.00	
	All Misc. Electric		
	Permanent A/C Unit (Pkg. Units)	3.00	3.00
	Each Air Handler	1.00	
LOW VOLTAGE INSTALLATIONS			
	Speaker Outlets (Each)	.30	
	Signal or Alarm Outlets (Each)	.30	
	Amplifiers	2.00	
	Control Panel	.50	
	TV Master System	.30	
	Telephone or Computer Outlet	.30	
	Starter Permit		
	Contract Price or Cost of Installation		
OTHER INSPECTIONS AND FEES:			
	Inspections outside of normal business-hours (minimum charge — three hours)	25.00 per hour	
	Reinspection fee assessed under provisions of TABLE 5-A of the Uniform Building Code = \$25.00 EACH	25.00 each	
	Inspections for which no fee is specifically indicated (minimum charge — one-half hour)	15.00 per hour	
	Additional plan review required by charges, additions or revisions to approved plans (minimum charge — one-half hour)	15.00 per hour	
	Misc.		
CONDUIT ONLY			

Electrical permit fee may be computed the same as building permit fees, by using the cost of installation for valuation amount when such work is not included in the above schedule.

RECEIPT

0.00

19.00

2310-2402

TOTAL

19.00

CHARGE

19.00

06-06-84

1388 8010001 1111 708143

I hereby certify that I have carefully examined and read the above application; that the same is true and correct; and that the work herein described is to be done in accordance with all the provisions of the applicable Ordinances of the City of Las Vegas, Nevada and the State Laws, whether herein specified or not.

SIGNED *R. Earl*

CONTRACTOR

MASTER CARD NO 121

PERMIT FEE

19.00

BY

BUILDING DEPT.

3/83

DATE

TOTAL FEES

19.00

Permit Expires 180 Days After Abandonment of Work

MUST BE MACHINE VALIDATED

Marionne Francis 7-9-84

ELEC. ONLY PLBG. ONLY, A.C. ONLY			
OWNER		DATE	
James Weaver		6-6-84	
ADDRESS			
2200 E. McWilliams			
CONTRACTOR		PERMIT NO.	FINAL INSPECTION
LOT	BLOCK	SUBDIVISION	
LOG NO.		AREA	
ELECTRIC ONLY		PLUMBING ONLY	
Contractor		Contractor	
All Elec. Inc.			
Permit No.		Permit No.	
1388			
Rough Elec.		Rough Soil	
Final Rough		Rough Water	
Final Elec.		Top Out	
157-057-684			
Temp. Service		Rough Gas	
HEAT & VENT. A/C ONLY		Final Plbg.	
Contractor		Final Gas	
Permit No.		Sewer Final	
A/C Rough Duct			
Rough Gas			
Final A/C			
Final Gas			
79-2-15 (R11-81) DEPT. OF BLDG. & SAFETY CITY OF LAS VEGAS			

**BUILDING DEPARTMENT
CITY OF LAS VEGAS**

CORRECTION NOTICE

all elect. OK Dave

Job located at 2200 E. McWilliams

I have this day inspected this structure and these premises and have found the following violations of City and/or State laws governing same:

- ① GND. Wires in Main Service not connected
- ② Water gnd not effectively attached to water system
- ③ time delay, 50 A. fuses needed in A/C
- ④ gnd wire needed in box at A/C
- ⑤ Tighten all connections
- ⑥ G.P.I. required on new outdoor recept.

You are hereby notified to correct above violation and call for re-inspection.

By 7-9-84

Date

7/2/84

Inspector

#173

23.03

Do not remove this tag!