

5615 Paseo Recallo

*Nikki Ingraham 8-11-85*

[Empty box]

**BUILDING DEPARTMENT  
CITY OF LAS VEGAS  
CORRECTION NOTICE**

*ATTN: HOME OWNER*

Job Located at *5115 Pine Bluff*

I have this day inspected this structure and these premises and have found the following violations of City and/or State laws governing same:

- #1. SEPARATE DISCONNECTS ARE REQ. FOR THE HOT PANE AND HEAT STRIPS - BOTH TO BE FUSED FOR NAME PLATE RATING.*
  - #2. RELEASED LIGHTS IN L.R. RIGGING ARE REQ. TO BE IMMEDIATELY PROTECTED*
- OK 12 Aug 85*

You are hereby notified to correct above violation and call for re-inspection.

*9 AUG 85*  
Date *5 AUG 85* *N.R.B. #71*  
Inspector

23.03 } Do not remove this tag!