

A. 2900 Sterling Slvr

B. 2904 Sterling Slvr

C. 2908 Sterlina Slvr

D. 2912 Sterling Slvr

E. 2916 Sterling Slvr

Judy Miller - 5-25

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

JOB ADDRESS 2410 S. RIVINGTON AVE		PERMIT NO.	
LOT NO.	MAP NO.	INSPECTOR	DATE
SUBDIVISION NAME			
INSPECTOR SIGNATURE		INSPECTION DATE	
		1 NOV 89	
TAC # 11273			
TEMP POLE			
☐ PARTIAL INSPECTION - DESCRIPTION:			
☒ APPROVED ☐ PERMIT REQUIRED ☐ STOP WORK			
☐ REJECTED - CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071			
INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERSLAB PLUMBING
☐ B-5	FRAMING	☐ P-5	TOP OUT-WATER, GAS, WASTE
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING
☐ B-8	EXTERIOR LATH/STUCCO	☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ E-2	ROUGH ELECTRICAL
☐ B-10	PRE-GUNITE	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	PRE-PLASTER / FINAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL	☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT. OF OCC.	☐ E-6	TEMP POWER
☐ FINAL INSPECTION		BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. of O. ISSUANCE (Commercial Only)	

FOR ASSISTANCE - CALL: 388-6251

Reenie Benbow

1-19-90

DEPARTMENT OF BUILDING & SAFETY CITY OF LAS VEGAS

SUBMITTER'S NAME Stirling Springs		PERMIT NO. 38614	
LOT NO.	PARCEL NO. 7-10-576	INSPECTOR 69	DATE 1-5
SUBMITTER'S ADDRESS Stirling Springs		PHONE	
INSPECTOR'S SIGNATURE Ed N. L.		INSPECTION DATE 1-8-90	

STAIR

- ① NAIL PA STRAP AND SHEAR RIGHT REAR CORNER
- ② ADD CRIPPLE @ TOP L/R WIND.
- ③ REPAIR WALL @ STAIRS HAS 2X6 LET-IN
- ④ STRAP J.P. CORNERS
- ⑤ BACK SHEAR BOUNDARY AND NAIL @ BATH #2
- ⑥ FIRE STOP @ LIA A/C CHASE

☒ PARTIAL INSPECTION - DESCRIPTION:

☒ APPROVED ☐ PERMIT REQUIRED ☐ STOP WORK

☒ REJECTED CORRECTION NOTICE - REINSPECTION REQUIRED CALL 799-2071

INSPECT	DESCRIPTION	INSPECT	DESCRIPTION	INSPECT	DESCRIPTION
☐ B-1	FOOTING, LAYOUT, REBAR, ZONING	☐ P-1	ON SITE SEWER	☐ X-2	UNDERGROUND HYDRO
☐ B-2	STEM WALL - FORMS & REBAR	☐ P-2	ON SITE WATER	☐ X-3	UNDERGROUND FINAL/FLOW
☐ B-3	PRE-SLAB	☐ P-3	BUILDING SEWER (YARD LINES)	☐ X-4	SPRINKLER SYSTEM HYDRO
☐ B-4	ROOF SHEATHING	☐ P-4	UNDERGROUND PLUMBING	☐ X-5	FIRE ALARM
☐ B-5	FRAMING	☐ P-5	TOP OUT WATER, GAS, WASTE	☐ X-6	OTHER:
☐ B-6	INSULATION	☐ P-6	FINAL GAS TEST	☐ X-7	FINAL FIRE
☐ B-7	DRYWALL NAILING	☐ P-7	FINAL PLUMBING		
☐ B-8	EXTERIOR LATH/STUCCO			☐ E-1	UNDERGROUND ELECTRICAL
☐ B-9	WALL GROUT & STEEL	☐ M-1	ROUGH VENT	☐ E-2	ROUGH ELECTRICAL
☐ B-10	POOL PRE-GUNITE	☐ M-2	HOOD	☐ E-3	LOW VOLTAGE ELECTRICAL
☐ B-11	POOL PRE-PLASTER / FINAL	☐ M-3	FINAL MECHANICAL	☐ E-4	SIGN INSPECTION
☐ B-12	BUILDING FINAL			☐ E-5	FINAL ELECTRICAL
☐ B-13	CERT. OF OCC.	☐ X-1	KICKER / FLUSH	☐ E-6	TEMP POWER

☐ FINAL INSPECTION

BRING HARD CARD WITH FIRE, QUALITY CONTROL & PLANNING APPROVALS SIGNED OFF TO BLDG & SAFETY FOR C. OF ISSUANCE (Commercial Only)

FOR ASSISTANCE - CALL: 386-9251