

1251 L V B S0

none

CITY OF LAS VEGAS, NEVADA

LOG NO. & AREA

CONST. VAL. \$ 300.00

DEPARTMENT OF BUILDING & SAFETY

APPLICATION & BUILDING PERMIT — for:
Commercial or Public Structures.ADDRESS OF
CONSTRUCTION:

1251 LUBS

OWNER:

MR. VANESSON

LOT(s)

BLOCK

SUBDIVISION

ZONE:

Existing structure on lot: Dwelling ☐Accessory bldgs. ☐Vacant lot ☐Commercial Bldg. ☒Other ☐

PROPOSED CONSTRUCTION:

Re-roofing

USE:

MATERIALS OF CONSTRUCTION:

Wood Frame ☐Concrete Block ☐Reinforced Concrete ☐Steel Frame ☐

SQUARE FEET OF FLOOR AREAS: 1st

2nd

3rd

Other

TOTAL SQ. FT.

FIRE ZONE: 1 2 3

Occupancy Group

A

B

C

D

E

F

G

H

I

J-1-2-3-4-5

CONST. TYPE: I II III IV V

ARCHITECT:

None

ENGINEER:

None

NO. of UNITS

NO. of STORIES

Plans Submitted: Yes ☐ No ☒Calculations Submitted: Yes ☐ No ☒Sewer Fee Req'd. Yes ☐ No ☒

CONTRACTOR:

Dean Roofing Co.

STATE

LICENSE #

6436

CITY

LICENSE #

ADD'L. PERMITS REQ'D: Air Cond. ☐Elec. ☐Plumbing ☐Signs ☐Paving ☐Fence ☐Public Walks ☐Curb-gutters ☐Incinerators ☐Fire Sprinkling System ☐

CONDITIONS OF THE PERMIT:

1. I agree to call the City Building Department for inspections before concrete is poured, before rough wiring, electrical, plumbing, framing is covered. Also for Air conditioning, sheet-rock and sheathing inspection.
2. I agree that when the job is completed that I will call for final inspection before occupancy.
3. I agree to perform all construction in accordance with City Ordinances and Building Codes.
4. The Contractor's signature below denotes authority from the owner to sign in his behalf and that the owner is aware of all requirements of this application and permit. Separate permits must be taken out for work outlined above this agreement.
5. I have read and understand the contents of this application and permit. I hereby state that the information I have supplied on this application is true and correct.

SIGNED:

Dean Roofing Co. Inc.

Contractor

BY:

James Dean

Agent or Owner

CLARK COUNTY HEALTH DEPT.

Date

LAS VEGAS FIRE DEPARTMENT

Date

PLANNING DEPT:

Date:

ENGINEERING DEPT:

Date:

BUILDING DEPT:

Date:

3-8-68

#12850

PERMIT NO:

40692

PERMIT FEE \$

4.00

RECEIPT

5792 \$800.00 - 8

CITY OF LAS VEGAS

DEPT. OF

BUILDING & SAFETY

MUST BE MACHINE VALIDATED

3-8-68

Donna Whisby

3-12-82

DEPT. of BLDG & SAFETY - CITY of LAS VEGAS, NEVADA			DATE
OWNER <u>Jamison</u>		ADDRESS <u>1251 L. V. Blvd S</u>	<u>3/8/68</u>
GEN. CONT. <u>Dean Roofing</u>		TYPE OF STRUCTURE <u>Reroofing</u>	
PERMIT NO. <u>40692</u>		LEGAL DESCRIPTION	
BUILDING		MECHANICAL	
LOCATION		PLUMBING CONT.	TEMP. POLE CONT.
FIREPLACE FTS.		PERMIT NO. _____ DATE _____	PERMIT NO. _____ DATE _____
FOOTINGS		HEAT & VENT. AC CONT.	INSPECTION _____ DATE _____
FOUNDATION WALL		PERMIT NO. _____ DATE _____	ELECTRICAL CONT.
FLOOR FRAMING		SEWER CONT.	PERMIT NO. _____ DATE _____
SLAB		PERMIT NO. _____ DATE _____	FIXTURES CONT.
CHIMNEY STEEL (FIREPLACE)		ROUGH SOL.	PERMIT NO. _____ DATE _____
WALL STEEL		ROUGH WATER	SLAB
COLUMN STEEL		TOP-OUT	ROUGH
BEAM STEEL		ROUGH GAS	FINAL ROUGH
FRAMING		AC ROUGH DUCT	FINAL FIXTURE
ROOF SHEATHING		REF. ROUGH PIPING	FINAL ELECTRICAL
INTERIOR		FINAL PLUMBING	TEMPORARY SERVICE
EXTERIOR		FINAL GAS	
DRYWALL		FINAL AIR COND.	
LATHING		FINAL REFRIG.	
BACKING (STONS)		FINAL SEWER	
PLASTER		FINAL SEPTIC TANK	
SCRATCH			
BROWN			
URBAN REDEVELOPMENT APPROVAL			
FINAL BLDG			
DATE	<u>3-29-68</u>		

APPROVED FOR OCCUPANCY, METER
PLEASE NOTE REMARKS ON REVERSE SIDE

1251 L. V. Blvd. S.

LOG: #

AREA: #

23.04

Done by 11-9-82

BUILDING DEPARTMENT
CITY OF LAS VEGAS
ATTN OWNER
CORRECTION NOTICE

NOTE: ALL ELEC WORK SHALL BE DONE BY A LICENSED ELEC. CONTR. WITH A PERMIT

2nd NOTICE 12:30 PM
10-27-82
CORR. COMPL. 11-5-82 L.V.G.
Job Located at 1251 L.V. BLVD SO.

I have this day inspected this structure and these premises and have found the following violations of City and/or State laws governing same:

- 1. DUPLEX OUTLET BY COFFEE MAKER WIRED OFF OF LIGHT SW CIRCUIT USING SURFACE MOUNTED SO/SJ CORD.

(NOTE) ALL WIRING IN A COMMERCIAL BLDG SHALL BE U.L. APPROVED WIRE + CONDUIT (OUTLETS CANNOT BE OFF OF LIGHTING

RE-INSP 10-26-82

You are hereby notified to correct above violation and call for re-inspection OR BEFORE ON CALL

Date 10-20-82 L.V. Gordy
Inspector

23.03 Do not remove this tag!