



REVISIONS
AS-BUILT 5-30-03

CONSULTANT
JMA ARCHITECTURE

JMA ARCHITECTURE
1111 CENTRAL EXPRESS BLVD
SUITE 200
LAS VEGAS, NV 89102
TEL: (702) 398-3333
FAX: (702) 398-3332

East Las Vegas Community Center
Eastern and Stewart



OWNER: CITY OF LAS VEGAS
DEPARTMENT OF PUBLIC WORKS
ARCHITECTURAL SERVICES
400 EAST STEWART AVENUE
LAS VEGAS, NEVADA 89101
PHONE: (702) 226-6538
FAX: (702) 398-3332
TELE: (702) 398-3332

DATE: DAN M.
REV: LVCC
DATE: AUGUST 2, 2001
SCALE: 1/4" = 1' - 0"

PROJECT NO: 521-268
FOODSERVICE EQUIPMENT
PLUMBING ROUGH-INS

FS-4

PLUMBING CONNECTION SCHEDULE

- P-1 FLOOR SINK, HALF-GRATE, 2" INDIRECT WASTE FROM ITEM 1, SINK, THREE COMPARTMENT, AT 1'-10"-AFF.
- P-1b 1/2" COLD WATER, STUB OUT WALL AT 1'-4"-AFF AND BRANCH TO CONNECTION AT ITEM 1, SINK, THREE COMPARTMENT, AT 3'-0 1/2"-AFF.
- P-1c 1/2" 140°-HOT WATER, 20-GPH, STUB OUT WALL AT 1'-4"-AFF AND BRANCH TO CONNECTION AT ITEM 1, SINK, THREE COMPARTMENT, AT 3'-0 1/2"-AFF.
- P-4 FLOOR SINK, HALF-GRATE, 2" INDIRECT WASTE FROM ITEM 4, DISHTABLE, SOILED, AT 2'-4"-AFF.
- P-5 1/2" COLD WATER, STUB OUT WALL AT 2'-0"-AFF AND BRANCH TO CONNECTION AT ITEM 5, PRE-RINSE ASSEMBLY, AT 2'-4"-AFF.
- P-5b 1/2" HOT WATER, 20-GPH, STUB UP 4" AND BRANCH TO CONNECTION AT ITEM 5, PRE-RINSE ASSEMBLY, AT 2'-4"-AFF.
- P-6 1/2" HOT WATER, 68-GPH, 140, STUB OUT WALL AT 1'-0"-AFF AND BRANCH TO CONNECTION AT ITEM 6, DISHWASHER, DOOR-TYPE, AT 10 1/2"-AFF.
- P-6b 1/2" HOT WATER, 74-GPH, 180; STUB OUT WALL AT 1'-0"-AFF AND BRANCH TO CONNECTION AT ITEM 6, DISHWASHER, DOOR-TYPE, AT 10 1/2"-AFF.
- P-10 1-1/2" DIRECT WASTE HUB, STUB OUT WALL AT 1'-5", BRANCH TO CONNECTION AT 10, HAND SINK W/RIGHT SPLASH GUARD, AT 2'-3"-AFF.
- P-10b 1/2" COLD WATER, STUB OUT WALL AT 1'-4"-AFF AND BRANCH TO CONNECTION AT ITEM 10, HAND SINK W/RIGHT SPLASH GUARD, AT 3'-0"-AFF.
- P-10c 1/2" 140°-HOT WATER, 5-GPH, STUB OUT WALL AT 1'-4"-AFF AND BRANCH TO CONNECTION AT ITEM 10, HAND SINK W/RIGHT SPLASH GUARD, AT 3'-0"-AFF.
- P-11 1-1/2" DIRECT WASTE HUB, STUB OUT WALL AT 1'-9", BRANCH TO CONNECTION AT 11, HAND SINK W/ LEFT SPLASH GUARD, AT 2'-3"-AFF.
- P-11b 1/2" 140°-HOT WATER, 5-GPH, STUB OUT WALL AT 1'-4"-AFF AND BRANCH TO CONNECTION AT ITEM 11, HAND SINK W/ LEFT SPLASH GUARD, AT 3'-0"-AFF.
- P-11c 1/2" COLD WATER, STUB OUT WALL AT 1'-4"-AFF AND BRANCH TO CONNECTION AT ITEM 11, HAND SINK W/ LEFT SPLASH GUARD, AT 3'-0"-AFF.
- P-19 FLOOR SINK, HALF-GRATE, 3/4" INDIRECT WASTE FROM ITEM 16, EVAPORATOR COIL, AT 5'-3"-AFF., ALSO SERVES ITEM NO. 29, NO. 30 & NO. 31
- P-19b 1/2" REFRIGERANT LIQUID LINE, 6400-BTUH, STUB AT CEILING AND BRANCH TO CONNECTION AT ITEM 19, EVAPORATOR COIL, MED-TEMP, AT 6'-0"-AFF.
- P-19c 5/8" REFRIGERANT SUCTION LINE, STUB UP 4" AND BRANCH TO CONNECTION AT ITEM 19, EVAPORATOR COIL, MED-TEMP, AT 6'-0"-AFF.
- P-20 5/8" REFRIGERANT SUCTION LINE, STUB UP 4" AND BRANCH TO CONNECTION AT ITEM 20, REFRIGERATION SYSTEM, REMOTE, AT 6'-AFF.
- P-20b 3/8" REFRIGERANT LIQUID LINE, 8470-BTUH, STUB UP 4" AND BRANCH TO CONNECTION AT ITEM 20, REFRIGERATION SYSTEM, REMOTE, AT 8'-AFF.
- P-30 CONNECTION TO ICE MAKER.
- P-31 3/8" COLD WATER, STUB OUT WALL AT 4'-3"-AFF AND BRANCH TO CONNECTION AT ITEM 31, ICE MAKER, CUBE, AT 4'-7 3/4"-AFF.
- P-32 1/2" 140°-HOT WATER, 10-GPH, STUB OUT WALL AT 1'-4"-AFF AND BRANCH TO CONNECTION AT ITEM 32, WORK TABLE, W/SINK & DRAWER, AT 3'-0"-AFF.
- P-32b 1/2" COLD WATER, STUB OUT WALL AT 1'-4"-AFF AND BRANCH TO CONNECTION AT ITEM 32, WORK TABLE, W/SINK & DRAWER, AT 3'-0"-AFF.
- P-32c FLOOR SINK, HALF-GRATE, 1-1/2" INDIRECT WASTE FROM ITEM 32, WORK TABLE, W/SINK & DRAWER, AT 2'-4"-AFF.
- P-44 3/4" GAS SUPPLY, 44-MBTUH, STUB OUT WALL AT 1'-9"-AFF AND BRANCH TO CONNECTION AT ITEM 44, OVEN, CONVECTION, GAS-FIRED, AT 2'-1 1/2"-AFF.
- P-44b 3/4" GAS SUPPLY, 44-MBTUH, STUB OUT WALL AT 4'-4"-AFF AND BRANCH TO CONNECTION AT ITEM 44, OVEN, CONVECTION, GAS-FIRED, AT 4'-8 1/4"-AFF.
- P-46 3/4" GAS SUPPLY, 242-MBTUH, STUB OUT WALL AT 1'-0"-AFF AND BRANCH TO CONNECTION AT ITEM 46, RANGE, MEDIUM DUTY GAS, AT 2'-7"-AFF.
- P-47 1/2" GAS SUPPLY, 30-MBTUH, STUB OUT WALL AT 5'-10"-AFF AND BRANCH TO CONNECTION AT ITEM 47, CHEESEMELTER, WALL-MOUNT, AT 6'-2 3/4"-AFF.
- P-48 1/2" GAS SUPPLY, 120-MBTUH, STUB OUT WALL AT 1'-0"-AFF AND BRANCH TO CONNECTION AT ITEM 48, FRYER, GAS-FIRED, AT 10 1/2"-AFF.
- P-50 FLOOR SINK, HALF-GRATE, 1-1/4" INDIRECT WASTE FROM ITEM 50, STEAMER, CONVECTION, AT 3'-3 3/4"-AFF.
- P-50b 1/4" COLD WATER, STUB OUT WALL AT 4'-0"-AFF AND BRANCH TO CONNECTION AT ITEM 50, STEAMER, CONVECTION, AT 3'-3"-AFF.
- P-50c 1/4" COLD WATER, STUB OUT WALL AT 1'-4"-AFF AND BRANCH TO CONNECTION AT ITEM 50, STEAMER, CONVECTION, AT 3'-3"-AFF.
- P-60 1/2" 140°-HOT WATER, 10-GPH, STUB OUT WALL AT 1'-4"-AFF AND BRANCH TO CONNECTION AT ITEM 60, COUNTER, SERVICE STATION, AT 2'-10"-AFF.
- P-60b 1/2" COLD WATER, STUB OUT WALL AT 1'-4"-AFF AND BRANCH TO CONNECTION AT ITEM 60, COUNTER, SERVICE STATION, AT 2'-10"-AFF.
- P-60c FLOOR SINK, HALF-GRATE, 1-1/2" INDIRECT WASTE FROM ITEM 60, COUNTER, SERVICE STATION, AT 2'-0"-AFF.
- P-60A 1/2" COLD WATER, STUB OUT WALL AT 1'-4"-AFF AND BRANCH TO CONNECTION AT ITEM 60-A, WATER AND ICE STATION, AT 2'-9"-AFF.
- P-61 3/4" COLD WATER, STUB OUT WALL AT 4'-0"-AFF AND BRANCH TO CONNECTION AT ITEM 61, COFFEE BREWER, AT 9'-3"-AFF.

LEGEND - PLUMBING CONNECTIONS

- HW-HOT WATER, OR CW-COLD WATER
- GAS
- WASTE, DIRECT-CONNECTED UNLESS NOTED "OPEN HUB"
- ⊞ FLOOR DRAIN
- ⊞ FLOOR DRAIN W/ATTACHED FUNNEL
- ⊞ FLOOR SINK WITH HALF GRATE UNLESS NOTED OTHERWISE
- FIELD CONNECTIONS

